

測定月報

測定日: 2016/08

(1/5)

日	モニタ											
	A001 正門警備所 (DM74)			A002 正門警備所 (DM44)			A003 免震重要棟(DM-46)			A004 免震重要棟(DM-47)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.25E-07	1.1	100	2.34E-07	1.2	100	3.52E-07	10.4	100	2.74E-07	9.4	100
2	3.83E-06	1.1	100	3.16E-06	1.3	100	2.86E-06	10.4	100	2.68E-06	9.6	100
3	7.62E-06	1.1	100	5.95E-06	1.2	100	6.91E-06	10.5	100	6.79E-06	9.4	100
4	7.30E-06	1.1	100	5.79E-06	1.2	100	6.62E-06	10.3	100	6.08E-06	9.6	100
5	*1 8.89E-06	1.1	100	7.26E-06	1.1	100	7.92E-06	10.4	100	7.65E-06	9.6	100
6	8.89E-06	1.1	100	7.29E-06	1.2	100	8.50E-06	10.5	100	8.56E-06	9.4	100
7	1.07E-05	1.0	100	8.24E-06	1.3	100	9.95E-06	10.6	100	9.31E-06	9.7	100
8	3.14E-06	1.1	100	2.49E-06	1.3	100	3.60E-06	10.4	100	3.30E-06	9.7	100
9	3.61E-06	1.1	100	2.89E-06	1.2	100	3.71E-06	10.4	100	3.49E-06	9.6	100
10	6.95E-06	1.1	100	5.56E-06	1.2	100	6.33E-06	10.6	100	6.29E-06	9.5	100
11	1.11E-05	1.2	100	8.88E-06	1.3	100	1.10E-05	10.7	100	1.09E-05	9.5	100
12	7.31E-06	1.1	100	5.93E-06	1.2	100	6.94E-06	10.6	100	6.48E-06	9.8	100
13	5.75E-06	1.1	100	4.62E-06	1.2	100	5.29E-06	10.5	100	4.91E-06	9.8	100
14	5.30E-06	1.0	100	4.04E-06	1.3	100	4.05E-06	10.7	100	3.95E-06	9.6	100
15	6.15E-06	1.1	100	4.97E-06	1.2	100	4.94E-06	10.7	100	4.77E-06	9.7	100
16	9.41E-07	1.0	100	7.22E-07	1.2	100	8.73E-07	10.5	100	8.58E-07	9.5	100
17	2.28E-06	1.0	100	1.86E-06	1.1	100	2.22E-06	10.4	100	2.33E-06	9.3	100
18	8.37E-06	1.1	100	6.71E-06	1.2	100	8.39E-06	10.2	100	8.09E-06	9.4	100
19	2.90E-06	1.1	100	2.25E-06	1.2	100	1.86E-06	10.6	100	1.81E-06	9.5	100
20	1.36E-07	1.0	100	8.49E-08	1.2	100	2.43E-07	10.2	100	1.13E-07	9.5	100
21	1.06E-06	1.0	100	8.04E-07	1.2	100	1.12E-06	10.2	100	1.01E-06	9.3	100
22	8.35E-07	1.0	100	6.30E-07	1.2	100	*1 8.17E-07	10.3	100	*1 9.31E-07	9.2	100
23	3.49E-06	1.0	100	2.74E-06	1.2	100	3.39E-06	10.3	100	3.32E-06	9.3	100
24	3.72E-06	1.1	100	*1 3.06E-06	1.2	100	3.82E-06	10.2	100	3.35E-06	9.6	100
25	1.60E-06	1.1	100	1.37E-06	1.1	100	1.36E-06	10.3	100	1.25E-06	9.4	100
26	2.33E-06	1.0	100	1.84E-06	1.3	100	2.33E-06	10.2	100	2.18E-06	9.4	100
27	2.90E-06	1.0	100	2.27E-06	1.2	100	3.19E-06	10.0	100	2.96E-06	9.2	100
28	2.31E-06	1.0	100	1.80E-06	1.2	100	2.10E-06	10.8	100	2.37E-06	9.2	100
29	4.63E-07	1.0	100	3.63E-07	1.1	100	6.28E-07	10.2	100	4.21E-07	9.4	100
30	*1 9.75E-07	1.0	100	7.29E-07	1.2	100	1.13E-06	10.2	100	9.14E-07	9.4	100
31	6.13E-06	1.1	100	4.98E-06	1.2	100	6.32E-06	10.3	100	5.93E-06	9.4	100
1ヶ月値	4.43E-06	1.1	100	3.53E-06	1.2	100	4.16E-06	10.4	100	3.98E-06	9.5	100
最大値	3.22E-05	1.2	102	3.26E-05	1.3	102	3.55E-05	10.8	102	1.17E-04	9.9	102
最大値日時	08/06 00:24	08/11 00:12	08/01 10:08	08/11 04:15	08/02 03:57	08/01 08:11	08/26 00:27	08/28 00:27	08/01 14:21	08/22 14:29	08/12 04:12	08/03 03:44
最小値	0.00E+00	1.0	98	0.00E+00	1.1	98	0.00E+00	10.0	98	0.00E+00	8.9	98
最小値日時	08/01 03:32	08/05 14:06	08/01 01:37	08/01 03:41	08/05 03:57	08/01 11:42	08/01 00:28	08/27 00:27	08/01 14:22	08/01 01:07	08/22 14:29	08/03 02:41

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日：2016/08

(2/5)

日	モニタ											
	A005 5/6号警備所前(DM48)			A006 5/6号警備所前(DM49)			A007 1号北側法面上(旧厚生棟)(DM-50)			A008 1号北側法面上(旧厚生棟)(DM-51)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.90E-07	2.0	100	2.49E-07	1.4	100	1.66E-07	13.3	100	2.96E-07	9.9	100
2	2.00E-06	1.9	100	1.37E-06	1.6	100	2.10E-06	13.0	100	1.90E-06	9.8	100
3	7.53E-06	1.9	100	6.09E-06	1.5	100	6.62E-06	13.0	100	6.90E-06	10.0	100
4	6.91E-06	2.1	100	5.76E-06	1.5	100	6.17E-06	12.6	100	5.85E-06	10.3	100
5	8.25E-06	1.9	100	6.84E-06	1.6	100	7.59E-06	12.4	100	6.92E-06	10.5	100
6	9.55E-06	2.1	100	7.97E-06	1.6	100	8.72E-06	12.5	100	8.41E-06	10.4	100
7	1.01E-05	2.1	100	8.33E-06	1.6	100	9.38E-06	12.3	100	8.92E-06	10.1	100
8	3.58E-06	2.1	100	2.94E-06	1.6	100	3.35E-06	12.7	100	3.34E-06	10.2	100
9	3.89E-06	1.8	100	3.18E-06	1.5	100	3.52E-06	12.6	100	3.48E-06	10.4	100
10	6.50E-06	2.0	100	5.44E-06	1.5	100	6.24E-06	12.5	100	5.96E-06	10.3	100
11	1.14E-05	1.9	100	9.49E-06	1.6	100	1.05E-05	12.6	100	1.01E-05	10.4	100
12	7.25E-06	2.0	100	6.09E-06	1.6	100	6.70E-06	12.3	100	6.47E-06	10.4	100
13	4.92E-06	2.0	100	4.15E-06	1.6	100	5.04E-06	12.5	100	4.98E-06	10.2	100
14	4.53E-06	2.0	100	3.84E-06	1.6	100	3.88E-06	12.6	100	3.96E-06	10.1	100
15	4.67E-06	2.0	100	3.90E-06	1.6	100	4.60E-06	12.4	100	4.62E-06	10.1	100
16	7.50E-07	2.0	100	6.56E-07	1.5	100	7.90E-07	12.5	100	7.62E-07	10.3	100
17	2.27E-06	1.7	100	2.14E-06	0.9	100	2.07E-06	12.3	100	2.27E-06	9.8	100
18	8.33E-06	1.9	100	7.14E-06	1.4	100	8.07E-06	12.0	100	8.05E-06	9.9	100
19	2.18E-06	1.8	100	1.70E-06	1.5	100	*1 1.89E-06	12.3	100	*1 1.82E-06	9.8	100
20	1.37E-07	1.8	100	2.65E-07	1.2	100	2.99E-07	12.0	100	2.81E-07	9.6	100
21	1.22E-06	1.8	100	9.94E-07	1.4	100	1.11E-06	12.2	100	1.23E-06	9.7	100
22	4.78E-07	2.0	100	4.89E-07	1.4	100	5.13E-07	12.5	100	6.35E-07	9.9	100
23	3.72E-06	1.4	100	2.93E-06	1.4	100	3.42E-06	12.0	100	3.13E-06	9.7	100
24	*1 3.56E-06	1.9	100	*1 3.20E-06	1.4	100	3.75E-06	12.0	100	3.41E-06	9.6	100
25	1.30E-06	1.9	100	1.13E-06	1.5	100	1.25E-06	12.2	100	1.30E-06	9.6	100
26	2.20E-06	1.9	100	1.98E-06	1.5	100	2.19E-06	12.1	100	2.12E-06	9.8	100
27	3.10E-06	1.4	100	2.67E-06	1.2	100	2.68E-06	12.2	100	2.86E-06	9.6	100
28	2.24E-06	2.0	100	2.09E-06	1.3	100	2.19E-06	12.2	100	2.20E-06	9.7	100
29	6.17E-07	1.8	100	3.74E-07	1.5	100	4.44E-07	12.2	100	4.45E-07	9.7	100
30	8.42E-07	1.8	100	7.16E-07	1.4	100	1.06E-06	12.0	100	8.57E-07	9.9	100
31	5.97E-06	1.8	100	5.23E-06	1.4	100	6.21E-06	12.0	100	5.89E-06	9.7	100
1ヶ月値	4.26E-06	1.9	100	3.53E-06	1.5	100	3.95E-06	12.4	100	3.85E-06	10.0	100
最大値	3.11E-05	2.1	102	3.27E-05	1.6	103	4.38E-05	13.3	102	3.69E-05	10.5	102
最大値日時	08/06 01:00	08/04 00:42	08/01 03:12	08/11 04:39	08/01 00:01	08/01 00:33	08/11 00:57	08/01 00:57	08/01 08:58	08/07 04:45	08/05 04:42	08/01 10:53
最小値	0.00E+00	1.4	98	0.00E+00	0.8	96	0.00E+00	12.0	97	0.00E+00	9.5	98
最小値日時	08/01 00:42	08/23 00:42	08/01 05:18	08/01 02:12	08/17 04:27	08/15 23:33	08/01 00:57	08/18 00:57	08/12 05:04	08/01 00:48	08/27 04:42	08/01 02:50

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/08

(3/5)

日	モニタ											
	A009 1/2号西側法面上(DM75)			A010 1/2号西側法面上(DM65)			A011 3/4号西側法面上(DM45)			A012 3/4号西側法面上(DM54)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.87E-07	7.6	100	2.20E-07	9.1	100	1.61E-07	6.9	100	1.20E-07	7.7	100
2	2.69E-06	7.7	100	1.85E-06	9.0	100	2.15E-06	6.7	100	1.77E-06	7.6	100
3	7.97E-06	7.5	100	5.84E-06	8.9	100	5.72E-06	6.7	100	5.53E-06	7.8	100
4	7.22E-06	7.7	100	5.31E-06	8.7	100	5.18E-06	6.8	100	5.16E-06	7.6	100
5	8.82E-06	7.7	100	6.72E-06	8.6	100	6.30E-06	6.7	100	6.42E-06	7.4	100
6	9.80E-06	7.6	100	7.35E-06	8.8	100	6.85E-06	6.6	100	6.79E-06	7.5	100
7	1.08E-05	7.4	100	7.82E-06	8.7	100	7.65E-06	6.5	100	7.53E-06	7.3	100
8	*1 4.00E-06	7.5	100	*1 2.93E-06	8.7	100	2.51E-06	6.7	100	*1 2.44E-06	7.5	100
9	4.19E-06	7.5	100	3.11E-06	8.8	100	2.85E-06	6.8	100	2.83E-06	7.7	100
10	7.12E-06	7.5	100	5.45E-06	8.6	100	5.22E-06	6.5	100	5.30E-06	7.3	100
11	1.22E-05	7.5	100	9.08E-06	8.8	100	8.48E-06	6.5	100	8.42E-06	7.4	100
12	7.47E-06	7.7	100	5.68E-06	8.7	100	5.34E-06	6.7	100	5.46E-06	7.2	100
13	5.99E-06	7.6	100	4.43E-06	8.7	100	4.23E-06	6.2	100	4.12E-06	7.1	100
14	4.60E-06	7.5	100	3.37E-06	8.6	100	3.48E-06	6.4	100	3.39E-06	7.2	100
15	5.15E-06	7.7	100	3.99E-06	8.6	100	3.94E-06	6.4	100	3.89E-06	7.2	100
16	8.55E-07	7.6	100	6.65E-07	8.7	100	5.47E-07	6.6	100	5.91E-07	7.3	100
17	2.41E-06	7.6	100	1.91E-06	8.5	100	1.75E-06	6.4	100	1.92E-06	6.8	100
18	9.32E-06	7.4	100	7.03E-06	8.2	100	6.39E-06	6.3	100	6.48E-06	6.9	100
19	2.27E-06	7.6	100	1.64E-06	8.6	100	1.79E-06	6.2	100	1.75E-06	7.2	100
20	1.85E-07	7.4	100	1.55E-07	8.5	100	1.69E-07	6.1	100	1.44E-07	6.9	100
21	1.22E-06	7.4	100	8.44E-07	8.6	100	8.63E-07	6.2	100	7.85E-07	7.0	100
22	8.40E-07	7.4	100	6.35E-07	8.4	100	6.48E-07	6.1	100	4.53E-07	7.1	100
23	3.94E-06	7.4	100	2.81E-06	8.5	100	2.63E-06	6.2	100	2.53E-06	7.0	100
24	4.00E-06	7.5	100	2.91E-06	8.5	100	*1 2.90E-06	6.1	100	2.80E-06	6.9	100
25	1.38E-06	7.5	100	9.81E-07	8.6	100	1.02E-06	6.2	100	1.03E-06	6.8	100
26	2.31E-06	7.6	100	1.75E-06	8.6	100	1.81E-06	6.1	100	1.67E-06	7.0	100
27	3.43E-06	7.2	100	2.22E-06	8.7	100	2.33E-06	6.0	100	2.23E-06	6.9	100
28	2.56E-06	7.5	100	1.84E-06	8.5	100	1.75E-06	6.2	100	1.75E-06	6.8	100
29	4.80E-07	7.5	100	3.53E-07	8.6	100	3.89E-07	6.2	100	4.51E-07	6.8	100
30	9.32E-07	7.5	100	7.78E-07	8.5	100	6.73E-07	6.7	100	8.30E-07	7.0	100
31	6.35E-06	7.5	100	4.71E-06	8.6	100	4.70E-06	6.6	100	4.76E-06	7.0	100
1ヶ月値	4.54E-06	7.5	100	3.37E-06	8.6	100	3.24E-06	6.4	100	3.21E-06	7.2	100
最大値	3.92E-05	7.8	102	4.74E-05	9.2	102	2.55E-05	7.0	102	3.10E-05	7.9	102
最大値日時	08/05 01:27	08/01 00:01	08/01 06:34	08/18 04:57	08/01 00:01	08/02 07:41	08/05 01:34	08/01 00:01	08/04 12:50	08/07 05:23	08/01 00:01	08/01 13:07
最小値	0.00E+00	7.2	97	0.00E+00	8.2	98	0.00E+00	6.0	98	0.00E+00	6.7	98
最小値日時	08/01 01:12	08/27 01:12	08/21 18:36	08/01 00:35	08/18 04:57	08/01 09:17	08/01 01:28	08/24 01:27	08/02 09:29	08/01 00:51	08/17 05:12	08/02 20:15

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/08

(4/5)

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM58)			4号南側法面上[3号南側](DM56)			登録S休憩所 (DM52)			登録S休憩所 (DM77)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.99E-07	1.6	100	2.29E-07	1.2	100	2.41E-07	2.6	100	4.00E-07	2.3	100
2	2.14E-06	1.6	100	1.92E-06	1.3	100	3.23E-06	2.4	100	3.79E-06	2.5	100
3	6.07E-06	1.9	100	5.94E-06	1.5	100	5.80E-06	2.6	100	7.51E-06	2.6	100
4	5.32E-06	1.9	100	5.25E-06	1.4	100	5.65E-06	2.6	100	7.42E-06	2.4	100
5	6.47E-06	1.8	100	*1 6.58E-06	1.4	100	*1 6.93E-06	2.7	100	*1 9.60E-06	2.4	100
6	6.84E-06	1.8	100	6.88E-06	1.4	100	7.31E-06	2.5	100	1.02E-05	2.4	100
7	7.73E-06	1.8	100	7.66E-06	1.5	100	8.15E-06	2.6	100	1.14E-05	2.4	100
8	2.62E-06	1.8	100	2.53E-06	1.4	100	2.49E-06	2.6	100	3.48E-06	2.4	100
9	3.03E-06	1.8	100	2.97E-06	1.5	100	2.80E-06	2.5	100	3.90E-06	2.4	100
10	5.58E-06	1.7	100	5.44E-06	1.4	100	5.19E-06	2.6	100	7.07E-06	2.5	100
11	8.51E-06	1.8	100	8.37E-06	1.4	100	8.87E-06	2.6	100	1.22E-05	2.4	100
12	5.75E-06	1.8	100	5.49E-06	1.4	100	5.78E-06	2.6	100	7.83E-06	2.5	100
13	4.02E-06	1.9	100	3.86E-06	1.4	100	4.58E-06	2.6	100	6.16E-06	2.5	100
14	3.55E-06	1.8	100	3.39E-06	1.5	100	3.82E-06	2.6	100	5.10E-06	2.5	100
15	3.79E-06	1.8	100	3.73E-06	1.4	100	4.84E-06	2.6	100	6.82E-06	2.5	100
16	6.26E-07	1.8	100	5.81E-07	1.5	100	7.25E-07	2.6	100	1.06E-06	2.5	100
17	1.83E-06	1.7	100	1.77E-06	1.3	100	1.78E-06	2.5	100	2.45E-06	2.3	100
18	6.86E-06	1.7	100	6.66E-06	1.3	100	6.59E-06	2.5	100	8.85E-06	2.3	100
19	1.97E-06	1.7	100	2.07E-06	1.3	100	2.26E-06	2.5	100	2.86E-06	2.5	100
20	1.52E-07	1.6	100	1.13E-07	1.3	100	1.39E-07	2.5	100	1.49E-07	2.4	100
21	8.47E-07	1.7	100	8.55E-07	1.3	100	8.64E-07	2.4	100	1.10E-06	2.4	100
22	5.24E-07	1.8	100	5.72E-07	1.3	100	6.39E-07	2.5	100	8.59E-07	2.4	100
23	2.66E-06	1.7	100	2.81E-06	1.2	100	2.63E-06	2.6	100	3.64E-06	2.5	100
24	*1 2.92E-06	1.5	100	2.89E-06	1.1	100	2.81E-06	2.5	100	3.89E-06	2.5	100
25	1.06E-06	1.5	100	9.65E-07	1.2	100	1.17E-06	2.7	100	1.65E-06	2.5	100
26	1.83E-06	1.4	100	1.65E-06	1.2	100	1.84E-06	2.4	100	2.49E-06	2.4	100
27	2.43E-06	1.5	100	2.35E-06	1.1	100	2.14E-06	2.5	100	2.98E-06	2.4	100
28	1.83E-06	1.6	100	1.81E-06	1.2	100	1.66E-06	2.6	100	2.44E-06	2.3	100
29	3.73E-07	1.5	100	3.63E-07	1.2	100	2.52E-07	2.7	100	5.08E-07	2.4	100
30	8.47E-07	1.5	100	*1 8.19E-07	1.1	100	*1 6.98E-07	2.6	100	*1 1.04E-06	2.3	100
31	5.10E-06	1.6	100	4.80E-06	1.2	100	4.70E-06	2.6	100	6.47E-06	2.4	100
1ヶ月値	3.34E-06	1.7	100	3.27E-06	1.3	100	3.44E-06	2.6	100	4.68E-06	2.4	100
最大値	2.45E-05	1.9	102	2.61E-05	1.5	101	2.82E-05	2.7	102	4.26E-05	2.6	102
最大値日時	08/07 02:40	08/03 01:42	08/01 02:26	08/07 05:56	08/03 05:27	08/01 00:07	08/11 02:20	08/05 01:57	08/11 05:08	08/07 06:09	08/03 05:42	08/10 01:41
最小値	0.00E+00	1.4	97	0.00E+00	1.1	98	0.00E+00	2.4	98	0.00E+00	2.3	98
最小値日時	08/01 01:42	08/26 01:42	08/27 06:33	08/01 05:35	08/24 05:27	08/06 04:13	08/01 01:57	08/02 01:57	08/01 11:34	08/01 02:59	08/01 05:42	08/12 16:39

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/08

(5/5)

日	モニタ											
	A019 シールド中央制御室(DM-62)			A020 シールド中央制御室(DM-63)			A021 Hタンクエリア (DM76)			A022 Hタンクエリア (DM64)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.02E-07	3.3	100	2.78E-07	3.4	100	3.60E-07	3.3	100	1.99E-07	3.2	100
2	3.11E-06	3.2	100	2.83E-06	3.5	100	3.84E-06	3.5	100	2.70E-06	3.3	100
3	7.16E-06	3.3	100	6.54E-06	3.6	100	7.71E-06	3.5	100	5.87E-06	3.2	100
4	6.65E-06	3.3	100	6.20E-06	3.6	100	7.20E-06	3.4	100	5.52E-06	3.2	100
5	7.97E-06	3.3	100	7.49E-06	3.5	100	*1 9.05E-06	3.4	100	*1 6.80E-06	3.2	100
6	8.36E-06	3.5	100	7.95E-06	3.5	100	9.70E-06	3.5	100	7.16E-06	3.2	100
7	9.79E-06	3.3	100	8.95E-06	3.6	100	1.11E-05	3.6	100	8.06E-06	3.3	100
8	3.25E-06	3.2	100	2.84E-06	3.7	100	3.49E-06	3.5	100	2.60E-06	3.2	100
9	3.74E-06	3.2	100	3.38E-06	3.6	100	4.05E-06	3.5	100	2.95E-06	3.2	100
10	6.60E-06	3.3	100	6.30E-06	3.5	100	7.48E-06	3.4	100	5.43E-06	3.2	100
11	1.08E-05	3.1	100	1.01E-05	3.6	100	1.20E-05	3.6	100	8.99E-06	3.2	100
12	6.75E-06	3.3	100	6.37E-06	3.5	100	7.67E-06	3.5	100	5.70E-06	3.3	100
13	4.98E-06	3.2	100	4.78E-06	3.4	100	5.95E-06	3.4	100	4.33E-06	3.3	100
14	4.30E-06	3.4	100	4.21E-06	3.5	100	4.95E-06	3.6	100	3.62E-06	3.3	100
15	4.50E-06	3.6	100	4.47E-06	3.5	100	5.75E-06	3.5	100	4.04E-06	3.4	100
16	8.44E-07	3.1	100	7.20E-07	3.6	100	9.42E-07	3.4	100	6.16E-07	3.4	100
17	2.20E-06	3.2	100	1.98E-06	3.5	100	2.50E-06	3.2	100	1.74E-06	3.1	100
18	8.16E-06	3.3	100	7.86E-06	3.4	100	9.14E-06	3.3	100	6.65E-06	3.0	100
19	2.44E-06	3.1	100	2.27E-06	3.5	100	2.55E-06	3.4	100	1.80E-06	3.1	100
20	1.23E-07	3.2	100	1.26E-07	3.4	100	1.13E-07	3.3	100	1.20E-07	3.1	100
21	9.86E-07	3.2	100	9.78E-07	3.4	100	1.09E-06	3.4	100	8.74E-07	3.1	100
22	*1 7.95E-07	3.1	100	*1 7.71E-07	3.4	100	7.02E-07	3.4	100	6.26E-07	3.0	100
23	3.36E-06	3.3	100	3.23E-06	3.4	100	3.76E-06	3.3	100	2.82E-06	3.1	100
24	3.68E-06	3.2	100	3.50E-06	3.4	100	4.14E-06	3.2	100	3.03E-06	3.0	100
25	1.34E-06	3.2	100	1.23E-06	3.4	100	1.58E-06	3.3	100	1.15E-06	3.1	100
26	2.09E-06	3.3	100	2.05E-06	3.4	100	2.54E-06	3.3	100	1.78E-06	3.1	100
27	2.92E-06	3.2	100	2.80E-06	3.3	100	3.27E-06	3.0	100	2.27E-06	3.1	100
28	2.32E-06	3.2	100	2.21E-06	3.4	100	2.45E-06	3.4	100	1.94E-06	2.9	100
29	4.56E-07	3.2	100	5.03E-07	3.3	100	3.71E-07	3.4	100	4.23E-07	2.9	100
30	1.01E-06	3.1	100	8.14E-07	3.5	100	*1 1.04E-06	3.2	100	*1 6.75E-07	3.1	100
31	6.04E-06	3.2	100	5.68E-06	3.5	100	7.04E-06	3.2	100	4.92E-06	3.1	100
1ヶ月値	4.09E-06	3.2	100	3.85E-06	3.5	100	4.63E-06	3.4	100	3.40E-06	3.2	100
最大値	3.87E-05	3.6	102	3.53E-05	3.7	102	4.04E-05	3.6	102	2.80E-05	3.4	102
最大値日時	08/07 02:44	08/15 02:27	08/01 01:08	08/07 06:24	08/08 06:12	08/01 02:14	08/07 03:00	08/07 02:42	08/18 00:49	08/07 06:34	08/15 06:27	08/07 18:35
最小値	0.00E+00	3.1	97	0.00E+00	3.3	97	0.00E+00	3.0	98	0.00E+00	2.8	98
最小値日時	08/01 02:02	08/11 02:27	08/17 23:45	08/01 02:18	08/22 13:55	08/05 15:25	08/01 02:46	08/27 02:42	08/04 09:46	08/01 04:51	08/28 06:27	08/01 06:53

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする