

# 測定月報

測定日: 2017/07

(1/7)

日	モニタ											
	A001 正門警備所 (DM76)			A002 正門警備所 (DM74)			A003 免震重要棟(DM-45)			A004 免震重要棟(DM-52)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	7.14E-06	0.9	100	7.11E-06	1.1	100	7.15E-06	7.7	100	6.54E-06	6.9	100
2	3.71E-06	0.9	100	3.66E-06	1.1	100	3.54E-06	7.9	100	3.40E-06	6.8	100
3	4.75E-06	1.0	100	4.73E-06	1.1	100	4.56E-06	7.6	100	4.32E-06	6.8	100
4	2.84E-06	1.0	100	2.85E-06	1.1	100	2.68E-06	7.9	100	2.66E-06	6.8	100
5	2.93E-06	1.0	100	2.99E-06	1.1	100	2.69E-06	7.8	100	2.68E-06	7.0	100
6	6.85E-06	1.0	100	6.74E-06	1.1	100	6.51E-06	7.9	100	6.36E-06	6.8	100
7	*1 8.64E-06	1.0	100	8.26E-06	1.2	100	7.29E-06	8.0	100	*1 7.03E-06	6.8	100
8	9.43E-06	0.9	100	9.44E-06	1.1	100	7.75E-06	7.7	100	7.79E-06	7.1	100
9	1.04E-05	0.9	100	1.02E-05	1.2	100	8.46E-06	7.7	100	8.25E-06	6.9	100
10	1.12E-05	1.1	100	1.13E-05	1.2	100	1.04E-05	7.7	100	1.02E-05	7.0	100
11	3.03E-06	0.9	100	2.85E-06	1.1	100	2.03E-06	7.9	100	2.09E-06	7.0	100
12	*9 4.27E-06	0.9	100	4.06E-06	1.1	100	3.76E-06	7.9	100	3.76E-06	7.0	100
13	8.14E-06	0.9	100	8.03E-06	1.1	100	7.37E-06	7.9	100	7.39E-06	7.0	100
14	5.29E-06	0.9	100	5.20E-06	1.1	100	*1 4.47E-06	8.0	100	4.63E-06	7.0	100
15	4.32E-06	0.9	100	4.34E-06	1.1	100	3.98E-06	8.2	100	4.06E-06	7.0	100
16	7.09E-06	0.9	100	7.23E-06	1.1	100	6.65E-06	8.2	100	6.76E-06	7.0	100
17	4.94E-06	0.9	100	5.04E-06	1.1	100	4.44E-06	8.2	100	4.59E-06	7.0	100
18	7.15E-06	0.9	100	7.41E-06	1.1	100	7.01E-06	8.2	100	7.11E-06	7.0	100
19	2.41E-06	0.9	100	2.44E-06	1.1	100	2.08E-06	8.2	100	2.19E-06	7.0	100
20	3.76E-06	0.9	100	3.77E-06	1.1	100	3.09E-06	8.2	100	3.05E-06	7.0	100
21	2.21E-06	0.9	100	*1 2.16E-06	1.1	100	1.86E-06	8.2	100	1.96E-06	7.0	100
22	3.50E-06	0.9	100	3.59E-06	1.1	100	3.03E-06	8.2	100	3.15E-06	7.0	100
23	3.97E-06	0.9	100	3.97E-06	1.1	100	3.27E-06	8.2	100	3.33E-06	7.0	100
24	6.09E-06	0.9	100	6.02E-06	1.1	100	5.24E-06	8.2	100	5.15E-06	7.0	100
25	5.19E-06	0.9	100	5.28E-06	1.1	100	4.66E-06	8.2	100	4.73E-06	7.0	100
26	4.24E-06	0.9	100	4.21E-06	1.1	100	3.78E-06	8.2	100	3.87E-06	7.0	100
27	3.92E-06	0.9	100	4.05E-06	1.1	100	4.05E-06	8.2	100	3.94E-06	7.0	100
28	3.22E-06	0.9	100	3.24E-06	1.1	100	2.92E-06	8.2	100	2.83E-06	7.0	100
29	3.04E-06	0.9	100	3.01E-06	1.1	100	2.50E-06	8.2	100	2.67E-06	7.0	100
30	1.27E-06	0.9	100	1.28E-06	1.1	100	1.06E-06	8.2	100	1.18E-06	7.0	100
31	1.47E-06	0.9	100	1.49E-06	1.1	100	8.51E-07	8.2	100	9.64E-07	7.0	100
1ヶ月値	5.04E-06	0.9	100	5.03E-06	1.1	100	4.48E-06	8.0	100	4.47E-06	7.0	100
*2 最大値	3.25E-05	1.1	102	4.34E-05	1.2	102	3.37E-05	8.2	102	6.95E-05	7.1	103
最大値日時	07/10 05:06	07/10 00:12	07/01 09:39	07/10 04:29	07/07 03:57	07/01 02:28	07/10 05:02	07/14 15:22	07/04 21:41	07/11 16:38	07/08 04:12	07/23 09:38
*2 最小値	0.00E+00	0.9	98	0.00E+00	1.1	98	0.00E+00	7.6	97	0.00E+00	6.7	96
最小値日時	07/04 00:13	07/01 00:12	07/03 05:23	07/21 14:08	07/01 00:01	07/01 05:58	07/02 00:28	07/03 00:27	07/05 04:14	07/02 04:12	07/06 04:12	07/24 10:45

\*1:ろ紙交換 \*9:その他

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(2/7)

日	モニタ											
	A005 5/6号警備所前(DM61)			A006 5/6号警備所前(DM54)			A007 1号北側法面上(旧厚生棟)(DM-70)			A008 1号北側法面上(旧厚生棟)(DM-75)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.26E-06	1.7	100	6.75E-06	2.0	100	6.20E-06	9.4	100	6.77E-06	8.2	100
2	3.53E-06	1.5	100	3.99E-06	1.8	100	3.48E-06	9.7	100	3.86E-06	8.0	100
3	3.92E-06	1.6	100	4.36E-06	1.8	100	3.99E-06	9.8	100	4.45E-06	8.2	100
4	2.36E-06	1.6	100	2.50E-06	1.8	100	2.68E-06	9.4	100	2.73E-06	8.0	100
5	2.45E-06	1.5	100	2.64E-06	1.8	100	2.52E-06	9.5	100	2.83E-06	8.0	100
6	5.87E-06	1.6	100	6.72E-06	1.8	100	5.79E-06	9.9	100	6.54E-06	8.1	100
7	*1 6.96E-06	1.6	100	7.60E-06	1.8	100	*1 6.75E-06	9.6	100	7.45E-06	8.0	100
8	6.90E-06	1.8	100	8.29E-06	1.9	100	7.35E-06	9.4	100	7.95E-06	8.1	100
9	6.96E-06	1.6	100	8.24E-06	1.8	100	6.96E-06	10.0	100	7.37E-06	8.2	100
10	9.33E-06	1.7	100	1.12E-05	1.9	100	9.80E-06	9.6	100	1.03E-05	8.3	100
11	1.33E-06	1.5	100	1.45E-06	1.9	100	1.47E-06	9.5	100	1.39E-06	8.3	100
12	2.38E-06	1.5	100	2.64E-06	1.9	100	3.06E-06	9.5	100	3.12E-06	8.3	100
13	4.54E-06	1.5	100	5.11E-06	1.9	100	5.53E-06	9.5	100	5.92E-06	8.3	100
14	2.29E-06	1.5	100	2.61E-06	1.9	100	3.29E-06	9.5	100	*1 3.47E-06	8.2	100
15	2.57E-06	1.5	100	3.02E-06	1.9	100	3.27E-06	9.5	100	3.82E-06	8.0	100
16	5.81E-06	1.5	100	6.92E-06	1.9	100	6.31E-06	9.5	100	7.17E-06	8.0	100
17	4.05E-06	1.5	100	4.58E-06	1.9	100	4.16E-06	9.5	100	4.80E-06	8.0	100
18	6.38E-06	1.5	100	7.31E-06	1.9	100	6.47E-06	9.5	100	7.64E-06	8.0	100
19	2.01E-06	1.5	100	2.26E-06	1.9	100	2.19E-06	9.5	100	2.46E-06	8.0	100
20	2.61E-06	1.5	100	2.99E-06	1.9	100	2.93E-06	9.5	100	3.31E-06	8.0	100
21	1.72E-06	1.5	100	1.88E-06	1.9	100	1.98E-06	9.5	100	2.21E-06	8.0	100
22	1.92E-06	1.5	100	2.15E-06	1.9	100	2.65E-06	9.5	100	2.95E-06	8.0	100
23	1.71E-06	1.5	100	1.92E-06	1.9	100	2.62E-06	9.5	100	2.88E-06	8.0	100
24	2.81E-06	1.5	100	*1 3.27E-06	1.8	100	4.05E-06	9.5	100	4.44E-06	8.0	100
25	4.02E-06	1.5	100	4.79E-06	1.7	100	4.57E-06	9.5	100	5.17E-06	8.0	100
26	3.55E-06	1.5	100	4.24E-06	1.7	100	3.84E-06	9.5	100	4.47E-06	8.0	100
27	3.66E-06	1.5	100	4.47E-06	1.7	100	3.93E-06	9.5	100	4.51E-06	8.0	100
28	1.99E-06	1.5	100	3.08E-06	1.7	100	2.80E-06	9.5	100	3.16E-06	8.0	100
29	2.13E-06	1.5	100	2.57E-06	1.7	100	2.39E-06	9.5	100	2.70E-06	8.0	100
30	1.21E-06	1.5	100	1.49E-06	1.7	100	1.38E-06	9.5	100	1.55E-06	8.0	100
31	8.44E-07	1.5	100	1.02E-06	1.7	100	9.58E-07	9.5	100	1.01E-06	8.0	100
1ヶ月値	3.70E-06	1.5	100	4.26E-06	1.8	100	4.04E-06	9.5	100	4.46E-06	8.1	100
*2 最大値	3.07E-05	1.8	103	4.35E-05	2.0	102	2.90E-05	10.0	102	5.13E-05	8.3	102
最大値日時	07/10 05:49	07/08 00:42	07/05 22:12	07/10 04:42	07/01 04:27	07/02 06:47	07/01 00:42	07/09 00:42	07/01 01:26	07/10 04:49	07/01 00:01	07/01 20:16
*2 最小値	0.00E+00	1.5	97	0.00E+00	1.7	98	0.00E+00	9.4	97	0.00E+00	8.0	97
最小値日時	07/05 00:42	07/02 00:42	07/19 18:49	07/01 04:27	07/02 04:27	07/04 02:10	07/03 00:43	07/01 00:42	07/05 17:48	07/02 04:43	07/02 04:42	07/02 05:00

\*1:ろ紙交換

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(3/7)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上(DM46)			1/2号西側法面上(DM65)			3/4号西側法面上(DM48)			3/4号西側法面上(DM51)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.94E-06	8.0	100	6.63E-06	7.4	100	6.53E-06	5.2	100	6.51E-06	5.6	100
2	3.82E-06	7.8	100	3.54E-06	7.4	100	3.41E-06	5.2	100	3.48E-06	5.5	100
3	4.72E-06	7.6	100	4.20E-06	7.3	100	4.26E-06	5.0	100	4.15E-06	5.5	100
4	2.63E-06	7.9	100	2.57E-06	7.4	100	2.42E-06	5.4	100	2.48E-06	5.5	100
5	3.03E-06	7.8	100	2.55E-06	7.5	100	2.60E-06	5.1	100	2.63E-06	5.3	100
6	6.74E-06	8.0	100	6.12E-06	7.4	100	6.28E-06	5.2	100	6.16E-06	5.5	100
7	*1 8.20E-06	7.8	100	7.34E-06	7.2	100	7.50E-06	5.2	100	7.25E-06	5.4	100
8	7.59E-06	7.8	100	7.48E-06	7.3	100	7.44E-06	5.5	100	7.71E-06	5.4	100
9	7.63E-06	7.9	100	7.48E-06	7.5	100	7.86E-06	5.2	100	7.82E-06	5.6	100
10	9.68E-06	7.6	100	9.58E-06	7.3	100	9.64E-06	5.2	100	9.11E-06	5.7	100
11	1.66E-06	7.9	100	1.73E-06	7.3	100	1.99E-06	5.1	100	2.10E-06	5.4	100
12	3.35E-06	7.9	100	3.39E-06	7.3	100	3.35E-06	5.1	100	3.49E-06	5.3	100
13	6.26E-06	7.9	100	6.36E-06	7.3	100	6.43E-06	5.1	100	6.55E-06	5.3	100
14	3.75E-06	7.9	100	3.78E-06	7.3	100	*1 3.90E-06	5.1	100	*1 3.96E-06	5.3	100
15	3.62E-06	7.9	100	3.67E-06	7.3	100	3.48E-06	5.2	100	3.86E-06	5.4	100
16	6.19E-06	7.9	100	6.25E-06	7.3	100	6.16E-06	5.2	100	6.61E-06	5.4	100
17	4.35E-06	7.9	100	4.40E-06	7.3	100	4.24E-06	5.2	100	4.57E-06	5.4	100
18	6.82E-06	7.9	100	6.66E-06	7.3	100	6.30E-06	5.2	100	6.62E-06	5.4	100
19	2.16E-06	7.9	100	2.16E-06	7.3	100	2.02E-06	5.2	100	2.22E-06	5.4	100
20	2.89E-06	7.9	100	2.97E-06	7.3	100	2.86E-06	5.2	100	3.06E-06	5.4	100
21	1.92E-06	7.9	100	1.92E-06	7.3	100	1.83E-06	5.2	100	1.95E-06	5.4	100
22	2.97E-06	7.9	100	2.89E-06	7.3	100	2.81E-06	5.2	100	3.03E-06	5.4	100
23	3.07E-06	7.9	100	2.96E-06	7.3	100	2.85E-06	5.2	100	3.04E-06	5.4	100
24	4.68E-06	7.9	100	*1 4.57E-06	7.4	100	4.51E-06	5.2	100	4.66E-06	5.4	100
25	4.58E-06	7.9	100	4.59E-06	7.5	100	4.45E-06	5.2	100	4.78E-06	5.4	100
26	3.90E-06	7.9	100	3.70E-06	7.5	100	3.51E-06	5.2	100	3.84E-06	5.4	100
27	3.93E-06	7.9	100	3.76E-06	7.5	100	3.58E-06	5.2	100	3.85E-06	5.4	100
28	2.80E-06	7.9	100	2.73E-06	7.5	100	2.64E-06	5.2	100	2.85E-06	5.4	100
29	2.44E-06	7.9	100	2.39E-06	7.5	100	2.36E-06	5.2	100	2.50E-06	5.4	100
30	1.25E-06	7.9	100	1.18E-06	7.5	100	1.08E-06	5.2	100	1.22E-06	5.4	100
31	9.34E-07	7.9	100	8.49E-07	7.5	100	9.20E-07	5.2	100	9.84E-07	5.4	100
1ヶ月値	4.33E-06	7.9	100	4.20E-06	7.4	100	4.16E-06	5.2	100	4.29E-06	5.4	100
*2 最大値	3.09E-05	8.0	102	4.22E-05	7.5	102	3.00E-05	5.5	102	3.32E-05	5.7	102
最大値日時	07/10 05:09	07/01 00:01	07/02 02:31	07/10 05:07	07/01 00:01	07/04 23:26	07/10 04:55	07/08 01:27	07/01 01:42	07/10 05:20	07/10 05:12	07/02 06:39
*2 最小値	0.00E+00	7.6	98	0.00E+00	7.1	98	0.00E+00	5.0	98	0.00E+00	5.3	98
最小値日時	07/01 01:13	07/03 01:12	07/02 02:09	07/04 05:01	07/07 04:57	07/01 00:40	07/04 01:27	07/03 01:27	07/01 00:13	07/01 05:12	07/05 05:12	07/01 00:24

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(4/7)

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM69)			4号南側法面上[3号南側](DM62)			登録S休憩所 (DM50)			登録S休憩所 (DM68)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.81E-06	0.9	100	6.74E-06	1.2	100	6.95E-06	2.6	100	6.22E-06	2.1	100
2	3.62E-06	0.8	100	3.66E-06	1.1	100	3.55E-06	2.5	100	3.20E-06	2.2	100
3	*1 4.23E-06	0.9	100	4.40E-06	1.1	100	*1 4.44E-06	2.5	100	*1 4.17E-06	2.2	100
4	2.68E-06	0.8	100	2.83E-06	1.1	100	2.72E-06	2.5	100	2.66E-06	2.1	100
5	2.73E-06	0.8	100	2.79E-06	1.0	100	2.70E-06	2.6	100	2.60E-06	2.2	100
6	6.76E-06	0.9	100	6.51E-06	1.0	100	6.42E-06	2.6	100	6.12E-06	2.2	100
7	7.73E-06	0.9	100	*1 7.68E-06	1.0	100	7.65E-06	2.5	100	7.42E-06	2.1	100
8	8.45E-06	0.9	100	8.27E-06	1.1	100	8.32E-06	2.7	100	8.08E-06	2.1	100
9	8.30E-06	1.0	100	7.92E-06	1.0	100	9.61E-06	2.5	100	9.36E-06	2.1	100
10	1.07E-05	0.9	100	9.67E-06	1.2	100	1.06E-05	2.5	100	9.90E-06	2.2	100
11	1.86E-06	0.9	100	1.78E-06	1.1	100	2.71E-06	2.6	100	2.64E-06	2.2	100
12	3.70E-06	0.9	100	3.47E-06	1.1	100	3.92E-06	2.6	100	3.73E-06	2.2	100
13	7.21E-06	0.9	100	6.97E-06	1.1	100	7.69E-06	2.6	100	7.49E-06	2.2	100
14	4.05E-06	0.9	100	3.85E-06	1.1	100	5.02E-06	2.6	100	4.57E-06	2.2	100
15	3.81E-06	0.9	100	3.61E-06	1.1	100	4.10E-06	2.6	100	3.89E-06	2.2	100
16	6.80E-06	0.9	100	6.55E-06	1.1	100	6.68E-06	2.6	100	6.28E-06	2.2	100
17	4.58E-06	0.9	100	4.32E-06	1.1	100	4.61E-06	2.6	100	4.43E-06	2.2	100
18	6.91E-06	0.9	100	6.52E-06	1.1	100	7.07E-06	2.6	100	6.61E-06	2.2	100
19	2.25E-06	0.9	100	2.16E-06	1.1	100	2.29E-06	2.6	100	2.13E-06	2.2	100
20	3.09E-06	0.9	100	2.96E-06	1.1	100	3.46E-06	2.6	100	3.39E-06	2.2	100
21	1.99E-06	0.9	100	1.95E-06	1.1	100	2.04E-06	2.6	100	1.97E-06	2.2	100
22	3.01E-06	0.9	100	2.97E-06	1.1	100	3.33E-06	2.6	100	3.22E-06	2.2	100
23	3.12E-06	0.9	100	3.09E-06	1.1	100	3.73E-06	2.6	100	3.56E-06	2.2	100
24	4.79E-06	0.9	100	4.80E-06	1.1	100	5.65E-06	2.6	100	5.50E-06	2.2	100
25	4.95E-06	0.9	100	4.68E-06	1.1	100	4.99E-06	2.6	100	4.72E-06	2.2	100
26	3.98E-06	0.9	100	3.76E-06	1.1	100	3.93E-06	2.6	100	3.74E-06	2.2	100
27	3.96E-06	0.9	100	3.77E-06	1.1	100	3.76E-06	2.6	100	3.62E-06	2.2	100
28	*1 2.92E-06	0.9	100	2.76E-06	1.1	100	*1 3.02E-06	2.6	100	*1 2.84E-06	2.2	100
29	2.66E-06	0.8	100	2.50E-06	1.1	100	3.09E-06	2.5	100	2.67E-06	2.1	100
30	1.37E-06	0.8	100	1.23E-06	1.1	100	1.31E-06	2.5	100	1.19E-06	2.1	100
31	1.09E-06	0.8	100	9.55E-07	1.1	100	1.36E-06	2.5	100	1.28E-06	2.1	100
1ヶ月値	4.52E-06	0.9	100	4.35E-06	1.1	100	4.73E-06	2.6	100	4.49E-06	2.2	100
*1 最大値	3.24E-05	1.0	108	3.63E-05	1.2	102	3.16E-05	2.7	102	3.31E-05	2.4	102
最大値日時	07/10 05:04	07/09 01:42	07/11 16:49	07/10 05:40	07/01 00:01	07/01 01:25	07/10 05:26	07/01 00:01	07/26 17:59	07/10 05:59	07/03 05:42	07/01 15:26
*2 最小値	1.59E-07	0.8	98	5.28E-08	1.0	98	0.00E+00	2.5	98	0.00E+00	2.1	98
最小値日時	07/11 15:35	07/02 01:42	07/01 16:37	07/31 18:25	07/05 05:27	07/01 07:42	07/03 14:47	07/02 01:57	07/05 00:18	07/02 05:42	07/01 05:42	07/02 01:38

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(5/7)

日	モニタ											
	A019			A020			A021			A022		
	シールド中央制御室(DM-49)			シールド中央制御室(DM-60)			Hタンクエリア (DM67)			Hタンクエリア (DM55)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.80E-06	2.5	100	6.41E-06	2.9	100	6.90E-06	2.2	100	6.57E-06	2.8	100
2	3.01E-06	2.5	100	3.52E-06	2.8	100	3.49E-06	2.2	100	3.48E-06	2.7	100
3	3.67E-06	2.5	100	4.30E-06	2.7	100	*1 4.70E-06	2.1	100	4.39E-06	2.6	100
4	2.19E-06	2.5	100	2.51E-06	2.8	100	2.86E-06	2.1	100	2.75E-06	2.5	100
5	2.39E-06	2.4	100	2.55E-06	3.0	100	2.82E-06	2.2	100	2.75E-06	2.6	100
6	5.45E-06	2.5	100	6.21E-06	3.0	100	6.92E-06	2.2	100	6.63E-06	2.8	100
7	6.64E-06	2.4	100	*1 7.41E-06	2.9	100	7.79E-06	2.2	100	7.46E-06	2.8	100
8	7.06E-06	2.5	100	8.03E-06	2.9	100	8.69E-06	2.3	100	8.00E-06	2.8	100
9	6.95E-06	2.6	100	8.40E-06	2.9	100	9.17E-06	2.2	100	8.91E-06	2.9	100
10	8.40E-06	2.6	100	1.00E-05	3.0	100	1.07E-05	2.2	100	1.02E-05	2.8	100
11	1.82E-06	2.5	100	2.05E-06	2.9	100	2.56E-06	2.2	100	2.24E-06	2.7	100
12	3.07E-06	2.5	100	3.69E-06	2.8	100	4.15E-06	2.2	100	3.89E-06	2.7	100
13	5.98E-06	2.5	100	7.13E-06	2.8	100	7.87E-06	2.2	100	7.47E-06	2.7	100
14	3.41E-06	2.5	100	4.22E-06	2.8	100	4.73E-06	2.2	100	4.65E-06	2.7	100
15	3.26E-06	2.5	100	4.06E-06	2.8	100	4.09E-06	2.2	100	3.93E-06	2.7	100
16	5.81E-06	2.5	100	6.89E-06	2.8	100	6.85E-06	2.2	100	6.48E-06	2.7	100
17	3.85E-06	2.5	100	4.56E-06	2.8	100	4.81E-06	2.2	100	4.67E-06	2.7	100
18	5.67E-06	2.5	100	6.84E-06	2.8	100	7.17E-06	2.2	100	6.98E-06	2.7	100
19	1.91E-06	2.5	100	2.34E-06	2.8	100	2.37E-06	2.2	100	2.30E-06	2.7	100
20	2.68E-06	2.5	100	3.27E-06	2.8	100	3.52E-06	2.2	100	3.42E-06	2.7	100
21	*1 1.67E-06	2.5	100	2.06E-06	2.8	100	2.21E-06	2.2	100	2.06E-06	2.7	100
22	2.56E-06	2.5	100	3.16E-06	2.8	100	3.40E-06	2.2	100	3.32E-06	2.7	100
23	2.66E-06	2.5	100	3.25E-06	2.8	100	3.66E-06	2.2	100	3.42E-06	2.7	100
24	4.12E-06	2.5	100	5.01E-06	2.8	100	5.54E-06	2.2	100	*1 5.36E-06	2.6	100
25	4.17E-06	2.5	100	5.03E-06	2.8	100	4.87E-06	2.2	100	4.77E-06	2.5	100
26	3.37E-06	2.5	100	3.97E-06	2.8	100	4.04E-06	2.2	100	3.85E-06	2.5	100
27	3.39E-06	2.5	100	4.00E-06	2.8	100	3.84E-06	2.2	100	3.72E-06	2.5	100
28	2.53E-06	2.5	100	2.97E-06	2.8	100	*1 3.07E-06	2.2	100	2.95E-06	2.5	100
29	2.27E-06	2.5	100	2.74E-06	2.8	100	2.90E-06	2.1	100	2.69E-06	2.5	100
30	1.06E-06	2.5	100	1.32E-06	2.8	100	1.29E-06	2.1	100	1.25E-06	2.5	100
31	9.78E-07	2.5	100	1.19E-06	2.8	100	1.28E-06	2.1	100	1.26E-06	2.5	100
1ヶ月値	3.80E-06	2.5	100	4.48E-06	2.8	100	4.78E-06	2.2	100	4.57E-06	2.7	100
最大値	2.94E-05	2.6	102	3.47E-05	3.1	102	3.64E-05	2.3	102	3.17E-05	2.9	101
最大値日時	07/09 02:46	07/09 02:27	07/01 00:02	07/10 06:48	07/05 06:12	07/02 02:15	07/10 02:57	07/08 02:42	07/01 00:32	07/10 06:40	07/09 06:27	07/01 00:44
最小値	0.00E+00	2.4	97	0.00E+00	2.7	98	0.00E+00	2.1	98	0.00E+00	2.5	99
最小値日時	07/03 02:27	07/05 02:27	07/06 01:09	07/01 06:12	07/02 06:12	07/01 04:27	07/01 02:42	07/03 02:42	07/01 06:04	07/02 06:27	07/04 06:27	07/01 00:59

\*1:ろ紙交換

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(6/7)

日	モニタ											
	A027			A028			A029			A030		
	1号機海側4m盤(DM-71)			1号機海側4m盤(DM-72)			3号機海側4m盤(DM-63)			3号機海側4m盤(DM-66)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.93E-06	5.9	100	6.64E-06	7.5	100	6.00E-06	6.1	100	6.37E-06	3.9	100
2	3.75E-06	5.9	100	3.51E-06	7.5	100	3.47E-06	6.1	100	3.75E-06	3.9	100
3	4.08E-06	5.9	100	3.85E-06	7.5	100	3.81E-06	6.1	100	4.00E-06	3.9	100
4	*1 2.20E-06	5.9	100	*1 2.23E-06	7.3	100	*1 2.07E-06	6.1	100	*1 2.28E-06	4.0	100
5	2.01E-06	5.9	100	2.17E-06	7.0	100	1.97E-06	6.1	100	2.09E-06	4.2	100
6	5.69E-06	5.9	100	5.64E-06	7.0	100	5.05E-06	6.1	100	5.37E-06	4.2	100
7	6.88E-06	5.9	100	7.10E-06	7.0	100	6.90E-06	6.1	100	7.07E-06	4.2	100
8	6.50E-06	5.9	100	6.78E-06	7.0	100	6.47E-06	6.1	100	6.72E-06	4.2	100
9	6.38E-06	5.9	100	6.78E-06	7.0	100	6.61E-06	6.1	100	6.71E-06	4.2	100
10	8.61E-06	5.9	100	8.80E-06	7.0	100	8.72E-06	6.1	100	9.25E-06	4.2	100
11	9.74E-07	5.9	100	1.17E-06	7.0	100	9.98E-07	6.1	100	1.01E-06	4.2	100
12	2.13E-06	5.9	100	2.24E-06	7.0	100	2.07E-06	6.1	100	2.13E-06	4.2	100
13	4.13E-06	5.9	100	4.20E-06	7.0	100	4.00E-06	6.1	100	4.14E-06	4.2	100
14	1.87E-06	5.9	100	2.00E-06	7.0	100	1.83E-06	6.1	100	1.95E-06	4.2	100
15	2.25E-06	5.9	100	2.50E-06	7.0	100	2.31E-06	6.1	100	2.41E-06	4.2	100
16	6.48E-06	5.9	100	6.86E-06	7.0	100	6.42E-06	6.1	100	6.79E-06	4.2	100
17	3.52E-06	5.9	100	3.75E-06	7.0	100	3.48E-06	6.1	100	3.64E-06	4.2	100
18	6.07E-06	5.9	100	6.30E-06	7.0	100	5.97E-06	6.1	100	6.19E-06	4.2	100
19	1.87E-06	5.9	100	2.06E-06	7.0	100	1.96E-06	6.1	100	2.04E-06	4.2	100
20	2.53E-06	5.9	100	2.74E-06	7.0	100	2.46E-06	6.1	100	2.61E-06	4.2	100
21	1.47E-06	5.9	100	1.69E-06	7.0	100	1.57E-06	6.1	100	1.66E-06	4.2	100
22	1.56E-06	5.9	100	1.73E-06	7.0	100	1.58E-06	6.1	100	1.65E-06	4.2	100
23	1.30E-06	5.9	100	1.42E-06	7.0	100	1.30E-06	6.1	100	1.38E-06	4.2	100
24	2.10E-06	5.9	100	2.31E-06	7.0	100	2.07E-06	6.1	100	2.22E-06	4.2	100
25	3.72E-06	5.9	100	3.97E-06	7.0	100	3.81E-06	6.1	100	4.02E-06	4.2	100
26	3.30E-06	5.9	100	3.59E-06	7.0	100	3.57E-06	6.1	100	3.63E-06	4.2	100
27	3.43E-06	5.9	100	3.86E-06	7.0	100	3.76E-06	6.1	100	3.92E-06	4.2	100
28	2.33E-06	5.9	100	2.61E-06	7.0	100	2.54E-06	6.1	100	2.61E-06	4.2	100
29	1.97E-06	5.9	100	2.17E-06	7.0	100	2.11E-06	6.1	100	2.22E-06	4.2	100
30	1.08E-06	5.9	100	1.25E-06	7.0	100	1.23E-06	6.1	100	1.30E-06	4.2	100
31	5.82E-07	5.9	100	7.86E-07	7.0	100	7.22E-07	6.1	100	7.79E-07	4.2	100
1ヶ月値	3.47E-06	5.9	100	3.64E-06	7.1	100	3.45E-06	6.1	100	3.61E-06	4.2	100
*2 最大値	2.73E-05	5.9	102	2.77E-05	7.5	102	2.75E-05	6.1	102	2.94E-05	4.2	102
最大値日時	07/10 08:11	07/01 00:01	07/04 05:46	07/10 08:37	07/01 00:01	07/01 15:15	07/10 08:28	07/01 00:01	07/01 01:11	07/10 08:52	07/04 14:53	07/01 13:42
*2 最小値	0.00E+00	5.9	98	0.00E+00	7.0	1	0.00E+00	6.1	97	0.00E+00	3.9	98
最小値日時	07/04 14:42	07/01 00:01	07/02 05:09	07/04 15:06	07/04 15:02	07/11 17:08	07/04 14:34	07/01 00:01	07/14 05:22	07/04 14:53	07/01 00:01	07/01 06:10

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2017/07

(7/7)

日	モニタ											
	A031 HTI南側(DM-73)			A032 HTI南側(DM-77)								
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.56E-06	11.6	100	6.84E-06	9.4	100						
2	3.70E-06	11.6	100	3.82E-06	9.4	100						
3	4.26E-06	11.6	100	4.30E-06	9.4	100						
4	2.52E-06	11.6	100	2.45E-06	9.4	100						
5	2.50E-06	11.6	100	2.52E-06	9.4	100						
6	5.85E-06	11.6	100	5.93E-06	9.4	100						
7	7.25E-06	11.6	100	7.34E-06	9.4	100						
8	7.96E-06	11.6	100	8.19E-06	9.4	100						
9	7.92E-06	11.6	100	7.89E-06	9.4	100						
10	9.94E-06	11.6	100	1.02E-05	9.4	100						
11	1.70E-06	11.6	100	1.62E-06	9.4	100						
12	3.22E-06	11.6	100	3.19E-06	9.4	100						
13	5.42E-06	11.6	100	5.38E-06	9.4	100						
14	3.12E-06	11.6	100	3.10E-06	9.4	100						
15	3.55E-06	11.6	100	3.59E-06	9.4	100						
16	7.22E-06	11.6	100	7.43E-06	9.4	100						
17	4.43E-06	11.6	100	4.27E-06	9.4	100						
18	6.42E-06	11.6	100	6.31E-06	9.4	100						
19	2.09E-06	11.6	100	2.05E-06	9.4	100						
20	2.85E-06	11.6	100	2.83E-06	9.4	100						
21	1.85E-06	11.6	100	1.80E-06	9.4	100						
22	2.47E-06	11.6	100	2.43E-06	9.4	100						
23	2.19E-06	11.6	100	2.18E-06	9.4	100						
24	*1 3.34E-06	11.4	100	*1 3.38E-06	9.2	100						
25	4.85E-06	11.2	100	5.17E-06	8.9	100						
26	4.06E-06	11.2	100	4.34E-06	8.9	100						
27	3.90E-06	11.2	100	4.22E-06	8.9	100						
28	3.04E-06	11.2	100	3.06E-06	8.9	100						
29	2.62E-06	11.2	100	2.60E-06	8.9	100						
30	1.31E-06	11.2	100	1.28E-06	8.9	100						
31	1.25E-06	11.2	100	1.21E-06	8.9	100						
1ヶ月値	4.17E-06	11.5	100	4.22E-06	9.3	100						
*2 最大値	3.07E-05	11.6	102	3.20E-05	9.4	102						
最大値日時	07/10 05:08	07/01 00:01	07/02 06:21	07/10 05:00	07/01 00:01	07/04 21:38						
*2 最小値	0.00E+00	11.2	98	0.00E+00	8.9	97						
最小値日時	07/11 15:48	07/24 14:33	07/01 10:36	07/11 14:11	07/24 14:56	07/24 07:29						

\*1:ろ紙交換

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする