

# 測定月報

測定日：2016/04

(1/5)

日	モニタ											
	A001 正門警備所 (DM74)			A002 正門警備所 (DM44)			A003 免震重要棟(DM-46)			A004 免震重要棟(DM-47)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.01E-06	1.2	100	6.04E-06	1.2	100	6.05E-06	11.0	100	5.94E-06	9.9	100
2	2.91E-06	1.2	100	2.90E-06	1.2	100	2.46E-06	11.0	100	2.31E-06	10.0	100
3	*3 2.74E-06	1.2	100	2.78E-06	1.2	100	2.47E-06	11.1	100	2.45E-06	10.0	100
4	1.79E-06	1.2	100	1.87E-06	1.2	100	1.73E-06	11.1	100	1.81E-06	9.8	100
5	3.34E-06	1.1	100	3.54E-06	1.1	100	3.67E-06	10.7	100	3.47E-06	9.8	100
6	3.85E-06	1.1	100	4.02E-06	1.1	100	3.59E-06	11.1	100	3.48E-06	10.0	100
7	4.14E-06	1.1	100	4.38E-06	1.1	100	3.55E-06	11.1	100	3.41E-06	10.0	100
8	2.80E-06	1.1	100	2.91E-06	1.1	100	2.80E-06	11.0	100	2.64E-06	10.1	100
9	5.07E-06	1.1	100	5.07E-06	1.2	100	4.75E-06	11.1	100	4.81E-06	9.9	100
10	5.45E-06	1.1	100	*3 5.70E-06	1.2	100	5.41E-06	11.0	100	5.61E-06	9.7	100
11	3.29E-06	1.1	100	3.09E-06	1.2	100	3.44E-06	10.8	100	3.23E-06	10.1	100
12	3.20E-06	1.2	100	2.50E-06	1.3	100	3.52E-06	10.8	100	3.27E-06	10.0	100
13	2.48E-06	1.1	100	1.91E-06	1.3	100	2.59E-06	11.0	100	2.68E-06	9.9	100
14	3.42E-06	1.1	100	2.66E-06	1.2	100	3.22E-06	10.7	100	3.13E-06	9.8	100
15	3.63E-06	1.1	100	2.86E-06	1.2	100	3.72E-06	10.8	100	3.60E-06	9.9	100
16	3.84E-06	1.1	100	2.99E-06	1.3	100	3.94E-06	10.8	100	3.69E-06	10.1	100
17	2.51E-06	1.1	100	1.91E-06	1.3	100	2.56E-06	10.9	100	2.33E-06	10.3	100
18	*9 3.64E-06	1.0	100	*9 2.90E-06	1.2	100	*1 3.63E-06	10.9	100	*1 3.49E-06	10.1	100
19	*2 4.43E-06	1.1	100	*2 3.61E-06	1.1	100	*9 4.41E-06	10.8	100	*9 4.23E-06	10.0	100
20	3.49E-06	1.2	100	2.87E-06	1.3	100	3.18E-06	11.2	100	3.23E-06	10.2	100
21	3.81E-06	1.1	100	3.12E-06	1.2	100	4.05E-06	10.7	100	3.84E-06	10.0	100
22	3.27E-06	1.1	100	*1 2.57E-06	1.2	100	2.78E-06	11.3	100	3.02E-06	9.9	100
23	2.98E-06	1.1	100	2.36E-06	1.2	100	2.57E-06	10.9	100	2.47E-06	9.9	100
24	5.80E-06	1.0	100	4.46E-06	1.1	100	5.23E-06	11.1	100	5.43E-06	9.8	100
25	6.88E-06	1.0	100	5.22E-06	1.3	100	6.33E-06	11.1	100	6.50E-06	9.8	100
26	6.11E-06	1.1	100	4.61E-06	1.3	100	5.19E-06	11.2	100	5.29E-06	10.0	100
27	*1 4.30E-06	1.0	100	3.24E-06	1.2	100	4.20E-06	10.7	100	3.92E-06	10.0	100
28	2.61E-06	1.0	100	1.95E-06	1.2	100	2.38E-06	11.0	100	2.53E-06	9.8	100
29	1.91E-06	1.1	100	1.45E-06	1.2	100	1.88E-06	10.9	100	1.74E-06	10.0	100
30	3.72E-06	1.1	100	2.74E-06	1.3	100	3.44E-06	11.0	100	3.27E-06	10.0	100
31												
1ヶ月値	3.78E-06	1.1	100	3.28E-06	1.2	100	3.62E-06	11.0	100	3.56E-06	10.0	100
※4最大値	1.70E-05	1.3	103	1.86E-05	1.3	116	6.49E-05	11.3	102	3.99E-05	10.3	102
最大値日時	04/26 00:30	04/04 00:12	04/11 05:10	04/10 04:14	04/11 14:04	04/11 14:04	04/18 14:14	04/22 00:27	04/03 09:09	04/01 04:12	04/17 04:12	04/01 18:25
最小値	0.00E+00	1.0	97	0.00E+00	1.1	98	0.00E+00	10.7	98	0.00E+00	9.7	98
最小値日時	04/02 00:13	04/18 00:12	04/24 22:28	04/03 04:00	04/05 03:57	04/01 01:54	04/01 00:27	04/05 00:27	04/02 20:34	04/02 04:12	04/01 00:01	04/01 00:56

\*3: 年次点検 \*9: その他 \*1: ろ紙交換 \*2: 電源停止切替

※4: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2016/04

(2/5)

日	モニタ											
	A005 5/6号警備所前(DM48)			A006 5/6号警備所前(DM49)			A007 1号北側法面上(旧厚生棟)(DM-50)			A008 1号北側法面上(旧厚生棟)(DM-51)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.74E-06	2.0	100	5.71E-06	1.7	100	5.54E-06	13.7	100	5.54E-06	10.6	100
2	2.21E-06	2.0	100	2.22E-06	1.6	100	2.12E-06	13.5	100	2.11E-06	10.5	100
3	2.55E-06	2.0	100	2.52E-06	1.6	100	2.45E-06	13.6	100	2.54E-06	10.5	100
4	1.64E-06	1.9	100	1.56E-06	1.6	100	1.56E-06	13.5	100	1.89E-06	10.3	100
5	3.29E-06	1.8	100	3.16E-06	1.7	100	3.34E-06	13.2	100	3.25E-06	10.4	100
6	3.45E-06	2.0	100	3.47E-06	1.6	100	3.71E-06	13.1	100	3.31E-06	10.6	100
7	3.44E-06	1.9	100	3.34E-06	1.6	100	3.59E-06	13.4	100	3.47E-06	10.4	100
8	2.69E-06	1.9	100	2.60E-06	1.5	100	2.60E-06	13.5	100	2.71E-06	10.4	100
9	4.53E-06	2.0	100	4.45E-06	1.6	100	4.74E-06	13.4	100	4.25E-06	11.0	100
10	5.23E-06	1.9	100	5.05E-06	1.6	100	5.43E-06	13.2	100	5.13E-06	10.6	100
11	3.27E-06	1.9	100	3.03E-06	1.7	100	3.24E-06	13.3	100	3.09E-06	10.5	100
12	3.30E-06	1.8	100	3.13E-06	1.6	100	3.08E-06	13.5	100	3.03E-06	10.5	100
13	2.66E-06	2.0	100	2.54E-06	1.7	100	2.64E-06	13.5	100	2.56E-06	10.6	100
14	3.08E-06	1.7	100	3.08E-06	1.2	100	*1 2.92E-06	13.2	100	*1 2.92E-06	10.4	100
15	3.48E-06	1.9	100	3.41E-06	1.5	100	3.30E-06	13.2	100	3.42E-06	10.2	100
16	3.86E-06	1.9	100	3.69E-06	1.7	100	3.38E-06	13.5	100	3.39E-06	10.6	100
17	2.49E-06	1.9	100	2.41E-06	1.6	100	2.80E-06	13.2	100	2.43E-06	10.5	100
18	3.58E-06	1.8	100	3.37E-06	1.6	100	3.01E-06	14.3	100	3.35E-06	10.4	100
19	*9 4.33E-06	1.9	100	4.19E-06	1.6	100	4.14E-06	13.2	100	3.97E-06	10.5	100
20	3.31E-06	2.0	100	3.27E-06	1.6	100	*9 3.29E-06	13.3	100	4.27E-06	10.3	100
21	3.64E-06	2.1	100	3.64E-06	1.6	100	3.67E-06	13.6	100	3.75E-06	10.5	100
22	*1 3.07E-06	1.8	100	*1 2.89E-06	1.5	100	2.91E-06	13.5	100	2.93E-06	10.4	100
23	2.25E-06	1.9	100	2.10E-06	1.6	100	2.51E-06	13.1	100	2.25E-06	10.3	100
24	5.19E-06	1.9	100	4.90E-06	1.5	100	5.07E-06	13.6	100	5.36E-06	10.1	100
25	6.75E-06	1.8	100	6.16E-06	1.6	100	6.36E-06	13.4	100	6.23E-06	10.5	100
26	5.92E-06	1.9	100	5.36E-06	1.6	100	5.14E-06	13.4	100	4.99E-06	10.4	100
27	4.02E-06	1.9	100	3.72E-06	1.6	100	3.87E-06	13.4	100	3.90E-06	10.4	100
28	2.27E-06	1.8	100	2.02E-06	1.6	100	2.31E-06	13.5	100	2.40E-06	10.4	100
29	1.91E-06	1.8	100	1.70E-06	1.6	100	1.74E-06	13.4	100	1.55E-06	10.7	100
30	3.31E-06	1.9	100	2.92E-06	1.7	100	3.13E-06	13.5	100	3.25E-06	10.3	100
31												
1ヶ月値	3.55E-06	1.9	100	3.39E-06	1.6	100	3.45E-06	13.4	100	3.44E-06	10.5	100
最大値	1.62E-05	2.1	102	1.63E-05	1.7	103	3.98E-05	14.3	103	1.28E-03	11.1	102
最大値日時	04/26 01:08	04/21 00:42	04/01 01:41	04/26 04:51	04/01 00:01	04/01 03:06	04/19 00:57	04/18 00:57	04/04 19:07	04/20 14:54	04/09 04:42	04/01 11:51
最小値	0.00E+00	1.7	97	0.00E+00	1.1	97	0.00E+00	13.1	97	0.00E+00	10.1	97
最小値日時	04/02 00:42	04/14 00:42	04/03 06:46	04/04 04:28	04/14 04:27	04/01 22:39	04/01 00:59	04/06 00:57	04/02 10:03	04/02 04:43	04/24 04:42	04/20 05:30

\*1:ろ紙交換 \*9:その他

※2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2016/04

(3/5)

日	モニタ											
	A009 1/2号西側法面上(DM75)			A010 1/2号西側法面上(DM65)			A011 3/4号西側法面上(DM45)			A012 3/4号西側法面上(DM54)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.29E-06	7.4	100	6.20E-06	13.7	100	5.42E-06	9.6	100	5.85E-06	8.1	100
2	2.60E-06	7.5	100	2.53E-06	13.6	100	2.28E-06	9.3	100	2.30E-06	8.2	100
3	2.89E-06	7.5	100	2.68E-06	13.8	100	2.52E-06	9.2	100	2.71E-06	8.0	100
4	1.84E-06	7.8	100	1.77E-06	13.7	100	1.49E-06	9.6	100	1.69E-06	8.1	100
5	3.41E-06	7.8	100	3.51E-06	13.5	100	3.27E-06	9.0	100	3.29E-06	8.0	100
6	3.71E-06	7.8	100	3.75E-06	13.6	100	3.53E-06	9.1	100	3.58E-06	8.0	100
7	3.83E-06	7.6	100	3.77E-06	13.6	100	3.54E-06	9.0	100	3.48E-06	8.1	100
8	*1: 2.99E-06	7.7	100	2.63E-06	14.0	100	2.53E-06	9.5	100	2.56E-06	8.3	100
9	5.25E-06	7.6	100	5.06E-06	13.5	100	4.75E-06	9.2	100	4.71E-06	8.2	100
10	5.61E-06	7.8	100	5.84E-06	13.4	100	5.24E-06	9.1	100	5.35E-06	7.9	100
11	3.49E-06	7.8	100	3.51E-06	13.4	100	2.97E-06	9.4	100	3.25E-06	7.9	100
12	3.59E-06	7.5	100	3.44E-06	13.3	100	2.91E-06	9.2	100	3.06E-06	8.1	100
13	2.82E-06	7.7	100	2.43E-06	13.8	100	2.55E-06	9.0	100	2.44E-06	8.0	100
14	3.05E-06	7.9	100	3.17E-06	13.3	100	2.56E-06	9.3	100	2.90E-06	7.8	100
15	3.71E-06	7.8	100	3.79E-06	13.2	100	3.36E-06	9.0	100	3.52E-06	7.8	100
16	3.99E-06	7.8	100	4.02E-06	13.1	100	3.59E-06	8.9	100	3.81E-06	7.6	100
17	2.73E-06	7.7	100	2.63E-06	13.3	100	2.63E-06	8.9	100	2.63E-06	7.8	100
18	3.75E-06	7.8	100	*3: 3.69E-06	13.4	100	*3: 3.44E-06	9.0	100	3.60E-06	7.8	100
19	4.66E-06	7.7	100	4.36E-06	11.9	100	3.97E-06	8.5	100	4.23E-06	7.8	100
20	*9: 3.63E-06	7.6	100	2.71E-06	10.2	100	2.88E-06	7.4	100	*9: 3.50E-06	7.4	100
21	4.23E-06	7.5	100	*9: 3.22E-06	10.0	100	*9: 3.20E-06	7.4	100	3.71E-06	7.5	100
22	3.33E-06	7.6	100	2.53E-06	10.0	100	*1: 2.52E-06	7.3	100	*1: 3.03E-06	7.3	100
23	2.54E-06	7.8	100	1.89E-06	10.0	100	2.00E-06	7.2	100	2.29E-06	7.1	100
24	5.76E-06	7.7	100	4.45E-06	10.0	100	4.34E-06	7.2	100	5.64E-06	6.9	100
25	7.17E-06	7.6	100	5.73E-06	9.8	100	5.26E-06	7.2	100	*3: 6.91E-06	6.9	100
26	5.80E-06	7.7	100	4.69E-06	9.8	100	4.30E-06	7.3	100	5.31E-06	7.6	100
27	4.31E-06	7.7	100	3.39E-06	10.0	100	3.10E-06	7.3	100	3.10E-06	8.5	100
28	2.67E-06	7.7	100	2.12E-06	9.9	100	1.90E-06	7.3	100	1.95E-06	8.2	100
29	2.12E-06	7.5	100	1.62E-06	9.9	100	1.35E-06	7.6	100	1.35E-06	8.5	100
30	3.61E-06	7.7	100	2.93E-06	9.8	100	2.72E-06	7.2	100	2.79E-06	8.0	100
31												
1ヶ月値	3.85E-06	7.7	100	3.47E-06	12.2	100	3.20E-06	8.5	100	3.48E-06	7.9	100
最大値	3.47E-05	7.9	103	5.46E-05	14.1	103	4.02E-05	9.6	102	2.76E-05	8.7	122
最大値日時	04/16 01:12	04/08 15:36	04/11 15:40	04/19 04:57	04/08 04:57	04/01 06:53	04/01 01:27	04/01 01:27	04/01 05:45	04/18 05:13	04/26 14:58	04/20 16:02
最小値	0.00E+00	7.4	97	0.00E+00	9.8	97	0.00E+00	7.2	97	0.00E+00	6.9	98
最小値日時	04/02 01:12	04/01 01:12	04/01 17:14	04/01 04:57	04/25 04:57	04/12 10:00	04/01 21:10	04/22 14:53	04/07 09:39	04/02 05:12	04/24 05:12	04/02 00:02

\*1:ろ紙交換 \*3:年次点検 \*9:その他

※2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2016/04

(4/5)

日	モニタ											
	A013 4号南側法面上[3号南側](DM58)			A014 4号南側法面上[3号南側](DM56)			A015 登録S休憩所 (DM52)			A016 登録S休憩所 (DM77)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.28E-06	1.2	100	6.13E-06	1.3	100	6.42E-06	3.6	100	5.69E-06	2.7	100
2	2.67E-06	1.4	100	2.77E-06	1.2	100	2.80E-06	3.5	100	2.54E-06	2.6	100
3	2.70E-06	1.2	100	2.69E-06	1.3	100	2.75E-06	3.4	100	*3 2.47E-06	2.6	100
4	1.85E-06	1.3	100	1.89E-06	1.2	100	2.00E-06	3.4	100	1.87E-06	2.5	100
5	3.50E-06	1.2	100	3.48E-06	1.2	100	3.60E-06	3.5	100	3.40E-06	2.5	100
6	3.82E-06	1.2	100	3.73E-06	1.3	100	4.09E-06	3.4	100	3.74E-06	2.5	100
7	3.83E-06	1.2	100	3.74E-06	1.3	100	4.51E-06	3.4	100	4.11E-06	2.5	100
8	2.95E-06	1.3	100	2.96E-06	1.2	100	3.02E-06	3.4	100	2.83E-06	2.4	100
9	5.24E-06	1.2	100	5.02E-06	1.3	100	5.48E-06	3.2	100	4.69E-06	2.5	100
10	5.87E-06	1.3	100	5.70E-06	1.3	100	*3 5.92E-06	3.4	100	5.35E-06	2.6	100
11	3.57E-06	1.2	100	3.43E-06	1.3	100	3.14E-06	3.1	100	3.29E-06	2.5	100
12	3.42E-06	1.1	100	3.34E-06	1.2	100	2.36E-06	2.7	100	3.26E-06	2.5	100
13	2.77E-06	1.2	100	2.67E-06	1.2	100	1.73E-06	2.8	100	2.48E-06	2.5	100
14	3.42E-06	1.1	100	*1 3.29E-06	1.1	100	2.43E-06	2.7	100	3.35E-06	2.5	100
15	3.85E-06	1.2	100	3.79E-06	1.2	100	2.64E-06	2.6	100	3.62E-06	2.4	100
16	3.99E-06	1.2	100	4.02E-06	1.2	100	2.73E-06	2.8	100	3.85E-06	2.6	100
17	2.69E-06	1.2	100	2.65E-06	1.2	100	1.74E-06	2.8	100	2.41E-06	2.6	100
18	*1 3.76E-06	1.2	100	3.76E-06	1.2	100	*9 2.63E-06	2.6	100	*9 3.52E-06	2.6	100
19	4.18E-06	1.4	100	4.41E-06	1.2	100	*2 3.29E-06	2.6	100	*2 4.45E-06	2.5	100
20	2.74E-06	1.7	100	*9 3.48E-06	1.2	100	2.63E-06	2.7	100	3.73E-06	2.4	100
21	*9 3.09E-06	1.7	100	3.81E-06	1.2	100	2.89E-06	2.6	100	3.87E-06	2.6	100
22	*1 2.51E-06	1.7	100	3.27E-06	1.1	100	2.52E-06	2.6	100	3.37E-06	2.5	100
23	1.97E-06	1.6	100	2.42E-06	1.2	100	2.34E-06	2.8	100	3.19E-06	2.5	100
24	4.48E-06	1.5	100	5.72E-06	1.1	100	4.10E-06	2.7	100	5.67E-06	2.5	100
25	5.36E-06	1.7	100	*3 6.81E-06	1.2	100	5.11E-06	2.7	100	7.05E-06	2.5	100
26	4.29E-06	1.6	100	5.33E-06	1.2	100	4.68E-06	2.7	100	6.39E-06	2.4	100
27	3.25E-06	1.6	100	3.12E-06	1.4	100	*1 3.03E-06	2.7	100	*1 4.23E-06	2.5	100
28	1.91E-06	1.7	100	1.82E-06	1.4	100	1.83E-06	2.7	100	2.57E-06	2.5	100
29	1.45E-06	1.7	100	1.41E-06	1.3	100	1.43E-06	2.6	100	1.97E-06	2.5	100
30	2.72E-06	1.6	100	2.66E-06	1.2	100	2.62E-06	2.7	100	3.59E-06	2.5	100
31												
1ヶ月値	3.47E-06	1.4	100	3.64E-06	1.2	100	3.22E-06	2.9	100	3.75E-06	2.5	100
最大値	2.15E-05	1.7	102	4.24E-05	1.4	102	2.04E-05	3.6	102	1.91E-05	2.7	102
最大値日時	04/01 02:00	04/19 15:21	04/01 22:26	04/18 14:34	04/27 05:27	04/02 14:49	04/01 02:16	04/01 00:01	04/01 11:16	04/26 06:01	04/01 05:42	04/03 07:19
最小値	0.00E+00	1.1	97	0.00E+00	1.1	98	0.00E+00	2.6	98	0.00E+00	2.3	98
最小値日時	04/02 01:42	04/12 01:42	04/22 16:57	04/11 05:27	04/14 05:27	04/01 19:46	04/02 01:58	04/15 01:57	04/01 03:22	04/01 05:42	04/04 15:29	04/01 00:13

\*3: 年次点検 \*1: ろ紙交換 \*9: その他 \*2: 電源停止切替

※4: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

測定日: 2016/04

(5/5)

日	モニタ											
	A019 シールド中央制御室(DM-62)			A020 シールド中央制御室(DM-63)			A021 Hタンクエリア (DM76)			A022 Hタンクエリア (DM64)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.66E-06	3.4	100	5.70E-06	3.6	100	6.09E-06	2.9	100	5.83E-06	4.1	100
2	2.64E-06	3.4	100	2.54E-06	3.7	100	2.60E-06	3.0	100	2.49E-06	3.9	100
3	2.47E-06	3.5	100	2.41E-06	3.8	100	*3 2.61E-06	3.0	100	2.67E-06	3.7	100
4	1.77E-06	3.4	100	1.78E-06	3.7	100	1.77E-06	3.2	100	1.78E-06	3.7	100
5	3.19E-06	3.4	100	3.18E-06	3.7	100	3.30E-06	3.5	100	3.57E-06	3.6	100
6	3.34E-06	3.5	100	3.45E-06	3.6	100	3.59E-06	3.7	100	3.82E-06	3.7	100
7	3.47E-06	3.4	100	3.49E-06	3.7	100	3.58E-06	3.7	100	3.91E-06	3.6	100
8	2.69E-06	3.4	100	2.66E-06	3.6	100	2.73E-06	3.6	100	2.99E-06	3.5	100
9	4.55E-06	3.5	100	4.43E-06	3.7	100	4.90E-06	3.5	100	4.87E-06	3.6	100
10	5.33E-06	3.3	100	5.03E-06	3.8	100	5.20E-06	3.8	100	*3 5.57E-06	3.7	100
11	3.07E-06	3.5	100	3.09E-06	3.7	100	3.11E-06	3.6	100	3.13E-06	3.6	100
12	3.15E-06	3.3	100	3.15E-06	3.6	100	3.00E-06	3.8	100	2.61E-06	3.4	100
13	2.43E-06	3.4	100	2.37E-06	3.6	100	2.43E-06	3.6	100	1.97E-06	3.5	100
14	*1 3.09E-06	3.3	100	*1 2.96E-06	3.6	100	3.11E-06	3.5	100	2.58E-06	3.3	100
15	3.42E-06	3.5	100	3.55E-06	3.5	100	3.53E-06	3.6	100	2.89E-06	3.4	100
16	3.62E-06	3.4	100	3.50E-06	3.7	100	3.66E-06	3.6	100	3.12E-06	3.4	100
17	2.39E-06	3.4	100	2.34E-06	3.7	100	2.38E-06	3.6	100	2.05E-06	3.4	100
18	3.47E-06	3.4	100	3.33E-06	3.6	100	*9 3.56E-06	3.6	100	*9 2.93E-06	3.4	100
19	4.19E-06	3.5	100	4.04E-06	3.6	100	4.38E-06	3.5	100	3.59E-06	3.4	100
20	*9 3.37E-06	3.3	100	*9 3.25E-06	3.6	100	3.37E-06	3.6	100	2.85E-06	3.4	100
21	3.74E-06	3.4	100	3.47E-06	3.7	100	3.64E-06	3.7	100	3.15E-06	3.4	100
22	3.08E-06	3.4	100	2.90E-06	3.8	100	3.24E-06	3.4	100	2.58E-06	3.5	100
23	2.63E-06	3.4	100	2.34E-06	3.8	100	2.58E-06	3.6	100	2.17E-06	3.4	100
24	5.39E-06	3.3	100	5.23E-06	3.7	100	5.48E-06	3.5	100	4.64E-06	3.5	100
25	6.53E-06	3.4	100	6.24E-06	3.7	100	6.57E-06	3.4	100	5.33E-06	3.5	100
26	5.49E-06	3.4	100	5.22E-06	3.7	100	5.43E-06	3.7	100	4.49E-06	3.4	100
27	4.04E-06	3.4	100	3.80E-06	3.7	100	*1 4.08E-06	3.7	100	*1 3.24E-06	3.4	100
28	2.39E-06	3.4	100	2.34E-06	3.6	100	2.47E-06	3.6	100	1.94E-06	3.5	100
29	1.88E-06	3.3	100	1.74E-06	3.7	100	2.04E-06	3.4	100	1.50E-06	3.5	100
30	3.30E-06	3.4	100	3.17E-06	3.7	100	3.58E-06	3.6	100	2.71E-06	3.5	100
31												
1ヶ月値	3.53E-06	3.4	100	3.42E-06	3.7	100	3.60E-06	3.5	100	3.23E-06	3.5	100
最大値	4.81E-05	3.5	102	1.59E-05	3.8	103	1.90E-05	3.8	102	1.66E-05	4.1	103
最大値日時	04/18 14:09	04/01 00:01	04/01 05:51	04/25 06:36	04/02 06:12	04/23 12:10	04/26 02:56	04/10 02:42	04/01 02:57	04/10 06:40	04/01 06:27	04/28 12:42
最小値	0.00E+00	3.2	97	0.00E+00	3.5	97	0.00E+00	2.9	98	0.00E+00	3.2	98
最小値日時	04/02 02:27	04/20 15:09	04/02 05:31	04/02 06:13	04/12 06:12	04/01 07:25	04/02 02:42	04/01 02:42	04/02 05:14	04/01 06:27	04/14 06:27	04/01 06:31

\*3:年次点検 \*1:ろ紙交換 \*9:その他

※2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする