

測定月報

測定日: 2017/04

(1/7)

日	モニタ											
	A001 正門警備所 (DM76)			A002 正門警備所 (DM74)			A003 免震重要棟(DM-45)			A004 免震重要棟(DM-52)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.63E-06	0.9	100	2.84E-06	1.1	100	2.24E-06	8.8	100	2.36E-06	7.0	100
2	4.06E-06	1.0	100	4.37E-06	1.1	100	3.81E-06	8.8	100	4.01E-06	7.0	100
3	4.23E-06	0.9	100	4.35E-06	1.1	100	3.87E-06	8.9	100	3.96E-06	7.1	100
4	5.18E-06	1.0	100	5.18E-06	1.2	100	4.57E-06	8.7	100	4.62E-06	7.2	100
5	7.31E-06	0.9	100	7.30E-06	1.1	100	6.54E-06	9.0	100	6.64E-06	7.0	100
6	*1 4.84E-06	1.0	100	4.91E-06	1.1	100	4.38E-06	9.0	100	4.38E-06	7.2	100
7	2.32E-06	0.9	100	2.29E-06	1.2	100	1.87E-06	8.8	100	1.85E-06	7.0	100
8	2.96E-06	0.9	100	3.00E-06	1.1	100	2.83E-06	8.8	100	2.83E-06	7.0	100
9	4.69E-06	1.0	100	4.89E-06	1.2	100	4.19E-06	9.0	100	4.40E-06	7.0	100
10	2.78E-06	1.0	100	2.85E-06	1.1	100	2.63E-06	8.9	100	2.58E-06	7.1	100
11	3.25E-06	0.9	100	3.09E-06	1.1	100	*1 2.65E-06	8.9	100	*1 2.64E-06	7.0	100
12	1.91E-06	1.0	100	1.93E-06	1.2	100	1.82E-06	8.9	100	1.74E-06	7.0	100
13	2.44E-06	0.9	100	2.42E-06	1.1	100	2.24E-06	9.0	100	2.26E-06	6.9	100
14	3.24E-06	0.9	100	3.28E-06	1.2	100	*3 3.13E-06	8.6	100	*3 3.20E-06	7.0	100
15	5.03E-06	1.0	100	5.16E-06	1.1	100	5.31E-06	8.0	100	4.93E-06	7.1	100
16	3.99E-06	1.0	100	4.17E-06	1.1	100	4.15E-06	7.9	100	3.75E-06	7.2	100
17	3.13E-06	1.0	100	*1 3.23E-06	1.1	100	2.99E-06	8.2	100	3.01E-06	7.2	100
18	1.81E-06	1.0	100	1.74E-06	1.1	100	1.70E-06	8.0	100	1.76E-06	6.8	100
19	2.67E-06	0.9	100	2.59E-06	1.1	100	2.68E-06	7.9	100	2.53E-06	7.0	100
20	2.09E-06	0.9	100	2.05E-06	1.1	100	1.96E-06	8.2	100	1.95E-06	7.1	100
21	4.82E-06	0.9	100	4.70E-06	1.1	100	4.53E-06	7.8	100	4.10E-06	7.1	100
22	4.77E-06	0.9	100	4.76E-06	1.2	100	4.63E-06	7.8	100	4.32E-06	6.9	100
23	2.66E-06	1.0	100	2.65E-06	1.1	100	2.56E-06	7.8	100	2.31E-06	7.1	100
24	2.70E-06	1.0	100	2.73E-06	1.1	100	2.31E-06	8.1	100	2.43E-06	7.0	100
25	1.93E-06	0.9	100	1.89E-06	1.1	100	1.81E-06	7.9	100	1.78E-06	6.9	100
26	*1 2.22E-06	0.9	100	2.10E-06	1.1	100	2.18E-06	7.8	100	*1 2.11E-06	7.0	100
27	2.75E-06	1.0	100	2.71E-06	1.1	100	2.61E-06	8.0	100	2.62E-06	6.9	100
28	3.06E-06	0.9	100	2.95E-06	1.1	100	2.97E-06	8.0	100	2.89E-06	7.1	100
29	5.41E-06	1.0	100	5.24E-06	1.2	100	5.26E-06	7.9	100	5.37E-06	7.0	100
30	4.10E-06	0.9	100	3.90E-06	1.2	100	4.01E-06	7.7	100	3.85E-06	7.0	100
31												
1ヶ月値	3.50E-06	0.9	100	3.51E-06	1.1	100	3.28E-06	8.4	100	3.24E-06	7.0	100
最大値	1.70E-05	1.0	102	1.91E-05	1.2	102	2.20E-05	9.0	103	7.26E-05	7.2	103
最大値日時	04/06 15:09	04/02 00:12	04/01 00:35	04/06 04:31	04/04 03:57	04/01 04:05	04/11 00:27	04/05 00:27	04/18 09:52	04/14 14:42	04/01 00:01	04/18 07:31
最小値	0.00E+00	0.9	98	0.00E+00	1.1	98	0.00E+00	7.7	98	0.00E+00	6.7	98
最小値日時	04/12 00:16	04/01 00:12	04/01 10:56	04/18 03:59	04/01 00:01	04/01 01:34	04/01 00:27	04/30 00:27	04/01 08:18	04/01 04:14	04/18 04:12	04/01 06:56

*1:ろ紙交換 *3:年次点検

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(2/7)

日	モニタ											
	A005			A006			A007			A008		
	5/6号警備所前(DM61)			5/6号警備所前(DM54)			1号北側法面上(旧厚生棟)(DM-70)			1号北側法面上(旧厚生棟)(DM-75)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.08E-06	1.6	100	2.08E-06	1.8	100	2.07E-06	10.9	100	2.48E-06	8.4	100
2	3.66E-06	1.6	100	3.63E-06	1.8	100	3.69E-06	11.0	100	4.09E-06	8.6	100
3	3.69E-06	1.6	100	3.68E-06	1.8	100	3.69E-06	10.9	100	3.88E-06	8.8	100
4	4.41E-06	1.8	100	4.45E-06	1.9	100	4.14E-06	11.2	100	5.09E-06	8.6	100
5	6.68E-06	1.7	100	6.49E-06	1.9	100	6.57E-06	11.0	100	7.36E-06	8.8	100
6	4.28E-06	1.8	100	4.27E-06	1.9	100	*1 4.55E-06	10.9	100	4.94E-06	8.7	100
7	*3 1.88E-06	1.6	100	1.85E-06	1.8	100	1.82E-06	10.8	100	2.08E-06	8.7	100
8	2.57E-06	1.7	100	2.55E-06	1.9	100	2.78E-06	10.6	100	2.87E-06	8.9	100
9	3.67E-06	1.8	100	3.60E-06	1.9	100	3.63E-06	11.0	100	4.34E-06	8.9	100
10	2.68E-06	1.6	100	2.40E-06	2.0	100	2.55E-06	10.8	100	2.95E-06	8.7	100
11	3.16E-06	1.7	100	2.83E-06	2.0	100	2.70E-06	10.9	100	*1 3.10E-06	8.8	100
12	1.94E-06	1.4	100	1.68E-06	1.9	100	1.62E-06	11.1	100	1.96E-06	8.7	100
13	2.27E-06	1.6	100	2.03E-06	1.9	100	2.06E-06	10.9	100	2.34E-06	8.9	100
14	3.19E-06	1.6	100	2.82E-06	2.0	100	3.07E-06	10.9	100	3.54E-06	8.7	100
15	4.92E-06	1.8	100	4.90E-06	1.9	100	4.76E-06	11.0	100	5.34E-06	8.9	100
16	3.92E-06	1.7	100	3.76E-06	1.9	100	3.76E-06	10.9	100	4.22E-06	8.8	100
17	2.90E-06	1.7	100	*1 2.87E-06	1.9	100	2.82E-06	10.9	100	3.14E-06	8.8	100
18	1.69E-06	1.5	100	1.79E-06	1.6	100	1.67E-06	10.7	100	1.96E-06	8.7	100
19	2.45E-06	1.7	100	2.42E-06	1.8	100	2.36E-06	10.9	100	2.80E-06	8.8	100
20	1.89E-06	1.7	100	*3 1.87E-06	2.0	100	1.92E-06	10.8	100	1.94E-06	9.1	100
21	3.93E-06	1.7	100	4.31E-06	1.9	100	3.75E-06	10.9	100	4.26E-06	8.8	100
22	4.11E-06	1.6	100	4.47E-06	2.0	100	3.88E-06	11.0	100	4.37E-06	8.9	100
23	2.32E-06	1.7	100	2.70E-06	1.9	100	2.34E-06	10.7	100	2.55E-06	8.8	100
24	*1 2.21E-06	1.7	100	2.49E-06	1.9	100	2.33E-06	10.7	100	2.52E-06	8.9	100
25	1.21E-06	1.8	100	2.14E-06	1.9	100	1.71E-06	10.9	100	1.80E-06	9.0	100
26	1.77E-06	1.7	100	1.92E-06	2.1	100	*1 2.02E-06	10.8	100	2.04E-06	8.8	100
27	2.31E-06	1.7	100	2.76E-06	1.9	100	2.17E-06	10.9	100	2.58E-06	8.9	100
28	2.69E-06	1.7	100	3.00E-06	1.9	100	2.59E-06	10.6	100	3.07E-06	8.7	100
29	5.11E-06	1.6	100	5.69E-06	2.0	100	5.07E-06	10.2	100	5.65E-06	8.6	100
30	3.53E-06	1.6	100	4.13E-06	1.8	100	3.50E-06	10.5	100	3.96E-06	8.6	100
31												
1ヶ月値	3.12E-06	1.7	100	3.19E-06	1.9	100	3.05E-06	10.8	100	3.44E-06	8.8	100
*2 最大値	1.32E-05	1.8	103	1.78E-05	2.1	104	9.63E-05	11.2	102	2.68E-05	9.2	103
最大値日時	04/06 01:08	04/04 00:42	04/10 05:05	04/22 04:47	04/26 04:27	04/05 06:25	04/26 13:58	04/04 00:42	04/01 03:17	04/21 04:42	04/20 04:42	04/25 08:34
*2 最小値	0.00E+00	1.4	97	0.00E+00	1.5	96	0.00E+00	10.2	97	0.00E+00	8.4	97
最小値日時	04/02 00:42	04/12 00:42	04/09 08:53	04/02 04:27	04/18 04:27	04/12 02:43	04/01 00:43	04/29 00:42	04/02 04:59	04/02 04:42	04/01 04:42	04/11 22:42

*1: ろ紙交換 *3: 年次点検

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(3/7)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上(DM46)			1/2号西側法面上(DM56)			3/4号西側法面上(DM48)			3/4号西側法面上(DM51)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.17E-06	8.2	100	2.24E-06	7.7	100	2.35E-06	4.6	100	2.26E-06	4.8	100
2	4.00E-06	8.1	100	3.97E-06	7.7	100	3.95E-06	4.7	100	3.96E-06	4.8	100
3	3.93E-06	8.2	100	3.92E-06	7.6	100	4.03E-06	4.7	100	3.84E-06	4.9	100
4	4.67E-06	8.2	100	5.02E-06	7.6	100	4.88E-06	4.8	100	4.64E-06	5.0	100
5	6.60E-06	8.0	100	7.02E-06	7.4	100	6.86E-06	4.8	100	6.55E-06	4.8	100
6	*1 4.56E-06	8.1	100	4.63E-06	7.6	100	4.56E-06	5.0	100	4.37E-06	5.0	100
7	1.75E-06	8.2	100	2.05E-06	7.4	100	2.09E-06	4.9	100	*1 1.95E-06	5.3	100
8	2.76E-06	8.0	100	3.06E-06	7.3	100	2.76E-06	5.0	100	2.74E-06	5.3	100
9	4.42E-06	8.0	100	4.32E-06	7.6	100	4.43E-06	5.0	100	4.02E-06	5.4	100
10	2.76E-06	8.0	100	2.74E-06	7.6	100	2.81E-06	4.8	100	2.55E-06	5.3	100
11	2.53E-06	8.2	100	*1 2.75E-06	7.6	100	*1 2.72E-06	4.8	100	2.80E-06	5.1	100
12	1.91E-06	8.0	100	1.91E-06	7.7	100	1.86E-06	4.8	100	1.81E-06	5.3	100
13	2.26E-06	8.1	100	2.40E-06	7.6	100	2.12E-06	4.8	100	2.39E-06	5.0	100
14	3.23E-06	7.9	100	3.42E-06	7.6	100	3.01E-06	4.8	100	3.29E-06	5.0	100
15	5.20E-06	8.0	100	5.71E-06	7.5	100	4.92E-06	5.1	100	5.00E-06	5.3	100
16	3.92E-06	8.2	100	4.31E-06	7.6	100	3.81E-06	5.0	100	3.74E-06	5.6	100
17	3.27E-06	7.8	100	3.37E-06	7.6	100	2.87E-06	5.0	100	3.00E-06	5.4	100
18	1.61E-06	8.3	100	1.90E-06	7.4	100	1.62E-06	5.1	100	1.70E-06	5.4	100
19	2.50E-06	8.1	100	2.73E-06	7.5	100	2.35E-06	5.2	100	2.48E-06	5.5	100
20	1.96E-06	8.1	100	*3 2.26E-06	8.0	100	1.77E-06	5.1	100	1.92E-06	5.3	100
21	4.11E-06	8.0	100	4.00E-06	9.1	100	3.86E-06	5.0	100	4.09E-06	5.3	100
22	4.24E-06	8.0	100	4.02E-06	9.3	100	3.99E-06	4.9	100	4.09E-06	5.4	100
23	2.40E-06	8.2	100	2.30E-06	9.3	100	2.37E-06	4.9	100	2.43E-06	5.3	100
24	2.29E-06	8.3	100	2.26E-06	9.4	100	2.28E-06	5.0	100	2.39E-06	5.2	100
25	1.66E-06	8.2	100	1.66E-06	9.3	100	1.65E-06	4.9	100	1.84E-06	5.1	100
26	*1 2.04E-06	8.1	100	1.84E-06	9.4	100	1.88E-06	5.1	100	1.96E-06	5.3	100
27	2.55E-06	8.2	100	2.44E-06	9.3	100	2.24E-06	5.3	100	2.53E-06	5.2	100
28	2.95E-06	8.2	100	2.88E-06	9.1	100	2.54E-06	5.3	100	2.71E-06	5.4	100
29	5.38E-06	8.2	100	5.05E-06	9.2	100	4.76E-06	5.0	100	5.03E-06	5.6	100
30	3.81E-06	8.3	100	3.59E-06	9.2	100	3.55E-06	5.0	100	3.56E-06	5.5	100
31												
1ヶ月値	3.25E-06	8.1	100	3.33E-06	8.1	100	3.16E-06	4.9	100	3.19E-06	5.2	100
*2最大値	2.57E-05	8.3	102	2.24E-05	9.4	109	1.61E-05	5.3	102	1.84E-05	5.7	102
最大値日時	04/06 01:12	04/18 01:12	04/01 00:26	04/05 04:58	04/22 04:57	04/11 14:20	04/10 01:27	04/27 01:27	04/01 03:18	04/06 05:20	04/29 05:12	04/02 18:13
*2最小値	0.00E+00	7.8	98	0.00E+00	7.3	98	0.00E+00	4.6	98	0.00E+00	4.8	98
最小値日時	04/01 01:12	04/17 01:12	04/01 03:27	04/03 04:57	04/08 04:57	04/01 03:40	04/03 01:27	04/01 01:27	04/01 01:28	04/01 05:13	04/01 05:12	04/01 15:27

*1:ろ紙交換 *3:年次点検

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(4/7)

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM69)			4号南側法面上[3号南側](DM62)			登録S休憩所 (DM50)			登録S休憩所 (DM68)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.30E-06	0.9	100	2.20E-06	1.1	100	2.61E-06	2.7	100	2.49E-06	2.2	100
2	3.59E-06	0.9	100	3.71E-06	1.1	100	4.17E-06	2.7	100	4.23E-06	2.2	100
3	3.87E-06	0.8	100	3.82E-06	1.1	100	4.32E-06	2.7	100	4.46E-06	2.2	100
4	4.92E-06	0.9	100	4.70E-06	1.1	100	4.98E-06	2.6	100	4.97E-06	2.2	100
5	6.77E-06	0.8	100	6.61E-06	1.1	100	7.35E-06	2.7	100	7.26E-06	2.2	100
6	4.46E-06	0.9	100	*1 4.23E-06	1.1	100	5.03E-06	2.7	100	5.15E-06	2.2	100
7	2.07E-06	0.8	100	*3 2.03E-06	1.1	100	2.30E-06	2.7	100	2.26E-06	2.3	100
8	2.79E-06	0.8	100	2.93E-06	1.1	100	2.82E-06	2.6	100	2.90E-06	2.2	100
9	4.18E-06	0.9	100	4.37E-06	1.1	100	4.69E-06	2.7	100	4.65E-06	2.3	100
10	2.66E-06	0.9	100	2.87E-06	1.1	100	2.88E-06	2.6	100	2.87E-06	2.2	100
11	2.65E-06	0.9	100	2.95E-06	1.1	100	3.56E-06	2.6	100	3.56E-06	2.2	100
12	1.97E-06	0.8	100	1.93E-06	1.2	100	1.84E-06	2.7	100	1.85E-06	2.2	100
13	2.25E-06	0.9	100	2.40E-06	1.0	100	2.24E-06	2.9	100	2.31E-06	2.3	100
14	3.16E-06	0.8	100	3.30E-06	1.1	100	3.00E-06	2.8	100	3.18E-06	2.2	100
15	5.02E-06	0.8	100	5.33E-06	1.1	100	5.30E-06	2.6	100	5.33E-06	2.2	100
16	3.98E-06	0.8	100	4.18E-06	1.0	100	3.93E-06	2.7	100	3.91E-06	2.4	100
17	3.14E-06	0.9	100	3.25E-06	1.1	100	3.12E-06	2.7	100	3.08E-06	2.2	100
18	1.81E-06	0.8	100	1.87E-06	1.0	100	1.81E-06	2.6	100	1.82E-06	2.1	100
19	2.54E-06	0.8	100	2.65E-06	1.1	100	2.58E-06	2.7	100	2.49E-06	2.2	100
20	1.89E-06	1.0	100	2.09E-06	1.2	100	1.97E-06	2.8	100	2.00E-06	2.1	100
21	*1 4.35E-06	0.9	100	4.40E-06	1.2	100	*1 4.88E-06	2.7	100	*1 4.74E-06	2.2	100
22	4.46E-06	0.9	100	4.49E-06	1.1	100	4.70E-06	2.7	100	4.54E-06	2.2	100
23	2.54E-06	0.9	100	2.57E-06	1.1	100	2.71E-06	2.7	100	2.69E-06	2.2	100
24	2.66E-06	0.8	100	*1 2.49E-06	1.1	100	2.69E-06	2.6	100	2.65E-06	2.2	100
25	1.80E-06	0.8	100	1.71E-06	1.1	100	1.85E-06	2.6	100	1.89E-06	2.1	100
26	2.03E-06	0.8	100	2.05E-06	1.1	100	2.05E-06	2.8	100	2.09E-06	2.2	100
27	2.58E-06	1.0	100	2.65E-06	1.2	100	2.57E-06	2.7	100	2.69E-06	2.2	100
28	2.93E-06	0.9	100	2.79E-06	1.1	100	2.90E-06	2.7	100	3.03E-06	2.2	100
29	5.56E-06	0.8	100	5.25E-06	1.1	100	5.33E-06	2.7	100	5.45E-06	2.3	100
30	3.94E-06	0.9	100	3.94E-06	1.2	100	3.76E-06	2.7	100	3.82E-06	2.3	100
31												
1ヶ月値	3.30E-06	0.9	100	3.33E-06	1.1	100	3.46E-06	2.7	100	3.48E-06	2.2	100
X2 最大値	1.50E-05	1.0	102	1.81E-05	1.2	102	1.68E-05	2.9	102	2.00E-05	2.4	102
最大値日時	04/06 05:41	04/20 01:42	04/02 06:44	04/06 05:42	04/06 05:27	04/03 02:35	04/06 02:20	04/13 01:57	04/01 15:20	04/06 05:57	04/16 05:42	04/01 08:52
X2 最小値	0.00E+00	0.8	98	0.00E+00	1.0	97	0.00E+00	2.6	98	0.00E+00	2.1	98
最小値日時	04/20 01:42	04/03 01:42	04/01 00:07	04/06 14:47	04/13 05:27	04/11 23:52	04/01 01:57	04/04 01:57	04/01 04:14	04/02 05:42	04/18 05:42	04/01 01:04

*1:ろ紙交換 *3:年次点検

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(5/7)

日	モニタ											
	A019 シールド中央制御室(DM-49)			A020 シールド中央制御室(DM-60)			A021 Hタンクエリア (DM67)			A022 Hタンクエリア (DM55)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.15E-06	2.5	100	2.38E-06	2.9	100	2.56E-06	2.2	100	2.56E-06	2.8	100
2	3.35E-06	2.6	100	3.71E-06	3.0	100	4.14E-06	2.3	100	3.97E-06	2.9	100
3	3.57E-06	2.6	100	3.90E-06	3.1	100	4.15E-06	2.5	100	4.17E-06	2.9	100
4	4.38E-06	2.6	100	4.75E-06	3.0	100	5.07E-06	2.2	100	5.01E-06	2.8	100
5	6.03E-06	2.6	100	6.60E-06	3.1	100	6.77E-06	2.4	100	6.57E-06	2.9	100
6	3.74E-06	2.6	100	*1 4.40E-06	3.0	100	4.54E-06	2.4	100	4.68E-06	2.9	100
7	1.75E-06	2.6	100	2.00E-06	2.9	100	2.11E-06	2.4	100	2.12E-06	2.9	100
8	2.43E-06	2.6	100	2.73E-06	3.0	100	2.94E-06	2.3	100	2.93E-06	2.8	100
9	3.71E-06	2.6	100	4.28E-06	3.1	100	4.68E-06	2.3	100	4.59E-06	2.9	100
10	2.35E-06	2.5	100	2.60E-06	3.0	100	2.82E-06	2.4	100	2.86E-06	2.9	100
11	2.56E-06	2.5	100	2.72E-06	3.0	100	2.77E-06	2.4	100	2.95E-06	2.9	100
12	1.70E-06	2.5	100	1.80E-06	3.1	100	1.98E-06	2.2	100	1.91E-06	2.8	100
13	1.95E-06	2.6	100	2.19E-06	3.1	100	2.32E-06	2.2	100	2.36E-06	2.8	100
14	2.69E-06	2.6	100	3.00E-06	3.0	100	3.35E-06	2.3	100	3.31E-06	2.9	100
15	4.48E-06	2.6	100	4.96E-06	3.0	100	5.27E-06	2.3	100	5.39E-06	3.0	100
16	3.66E-06	2.5	100	4.07E-06	2.9	100	3.96E-06	2.4	100	3.89E-06	2.9	100
17	*1 2.82E-06	2.5	100	3.24E-06	2.9	100	3.26E-06	2.3	100	3.16E-06	2.9	100
18	1.68E-06	2.4	100	1.72E-06	3.0	100	1.86E-06	2.2	100	1.86E-06	2.7	100
19	2.25E-06	2.6	100	2.49E-06	2.9	100	2.68E-06	2.2	100	2.65E-06	2.7	100
20	1.78E-06	2.5	100	1.91E-06	2.9	100	2.06E-06	2.4	100	*3 2.06E-06	2.8	100
21	3.94E-06	2.6	100	4.31E-06	3.0	100	*1 4.77E-06	2.3	100	4.23E-06	2.8	100
22	3.94E-06	2.7	100	4.27E-06	3.0	100	4.56E-06	2.2	100	4.11E-06	2.8	100
23	2.33E-06	2.4	100	2.44E-06	3.0	100	2.49E-06	2.4	100	2.47E-06	2.8	100
24	2.28E-06	2.6	100	2.32E-06	3.1	100	2.69E-06	2.3	100	2.43E-06	2.8	100
25	1.58E-06	2.5	100	1.65E-06	3.0	100	1.83E-06	2.3	100	1.76E-06	2.8	100
26	1.81E-06	2.5	100	*1 1.97E-06	3.0	100	2.21E-06	2.1	100	2.01E-06	2.8	100
27	2.32E-06	2.6	100	2.63E-06	2.9	100	2.70E-06	2.3	100	2.63E-06	2.9	100
28	2.54E-06	2.5	100	2.85E-06	3.0	100	3.08E-06	2.3	100	2.90E-06	2.8	100
29	4.74E-06	2.6	100	5.13E-06	3.1	100	5.44E-06	2.3	100	5.00E-06	2.8	100
30	3.37E-06	2.7	100	3.69E-06	3.0	100	4.04E-06	2.3	100	3.59E-06	2.9	100
31												
1ヶ月値	2.93E-06	2.6	100	3.22E-06	3.0	100	3.44E-06	2.3	100	3.34E-06	2.9	100
※1 最大値	1.28E-05	2.7	103	1.93E-05	3.1	102	1.55E-05	2.5	102	1.71E-05	3.0	101
最大値日時	04/29 02:54	04/22 02:27	04/05 08:02	04/06 06:40	04/03 06:12	04/01 00:51	04/22 03:25	04/03 02:42	04/01 07:33	04/06 06:52	04/02 06:27	04/01 01:03
※2 最小値	0.00E+00	2.4	97	0.00E+00	2.8	98	0.00E+00	2.1	98	0.00E+00	2.6	98
最小値日時	04/01 02:27	04/18 02:27	04/06 08:00	04/01 06:12	04/19 06:12	04/01 04:44	04/01 02:42	04/26 02:42	04/01 04:36	04/03 06:27	04/18 06:27	04/23 19:08

*1: ろ紙交換 *3: 年次点検

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(6/7)

日	モニタ											
	A027			A028			A029			A030		
	1号機海側4m盤(DM-71)			1号機海側4m盤(DM-72)			3号機海側4m盤(DM-63)			3号機海側4m盤(DM-66)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.03E-06	5.9	100	2.01E-06	6.9	100	1.82E-06	6.8	100	2.00E-06	4.6	100
2	3.61E-06	5.9	100	3.69E-06	6.9	100	3.38E-06	6.8	100	3.64E-06	4.6	100
3	3.67E-06	5.9	100	3.80E-06	6.9	100	3.41E-06	6.8	100	3.61E-06	4.6	100
4	4.37E-06	5.9	100	4.40E-06	6.9	100	4.19E-06	6.8	100	4.47E-06	4.6	100
5	6.73E-06	5.9	100	6.82E-06	6.9	100	6.26E-06	6.8	100	6.66E-06	4.6	100
6	4.42E-06	5.9	100	4.50E-06	6.9	100	4.27E-06	6.8	100	4.46E-06	4.6	100
7	1.67E-06	5.9	100	1.73E-06	6.9	100	1.58E-06	6.8	100	1.72E-06	4.6	100
8	2.44E-06	5.9	100	2.44E-06	6.9	100	2.35E-06	6.8	100	2.53E-06	4.6	100
9	3.43E-06	5.9	100	3.36E-06	6.9	100	3.29E-06	6.8	100	3.48E-06	4.6	100
10	2.38E-06	5.9	100	2.37E-06	6.9	100	2.30E-06	6.8	100	2.46E-06	4.6	100
11	2.45E-06	5.9	100	2.37E-06	6.9	100	2.32E-06	6.8	100	2.49E-06	4.6	100
12	1.78E-06	5.9	100	1.72E-06	6.9	100	1.65E-06	6.8	100	1.81E-06	4.6	100
13	2.31E-06	5.9	100	2.28E-06	6.9	100	2.05E-06	6.8	100	2.14E-06	4.6	100
14	2.96E-06	5.9	100	2.93E-06	6.9	100	2.79E-06	6.8	100	3.00E-06	4.6	100
15	5.08E-06	5.9	100	5.06E-06	6.9	100	4.81E-06	6.8	100	5.07E-06	4.6	100
16	4.01E-06	5.9	100	4.06E-06	6.9	100	3.65E-06	6.8	100	3.94E-06	4.6	100
17	*1 3.04E-06	5.8	100	*1 2.96E-06	6.7	100	*1 2.85E-06	6.7	100	*1 3.03E-06	4.6	100
18	1.77E-06	5.6	100	1.79E-06	6.5	100	1.53E-06	6.6	100	1.59E-06	4.5	100
19	2.81E-06	5.6	100	2.92E-06	6.5	100	2.40E-06	6.6	100	2.43E-06	4.5	100
20	2.11E-06	5.6	100	2.41E-06	6.5	100	1.82E-06	6.6	100	1.85E-06	4.5	100
21	4.15E-06	5.6	100	4.34E-06	6.5	100	3.52E-06	6.6	100	3.49E-06	4.5	100
22	4.19E-06	5.6	100	4.51E-06	6.5	100	3.78E-06	6.6	100	3.93E-06	4.5	100
23	2.47E-06	5.6	100	2.74E-06	6.5	100	2.00E-06	6.6	100	2.15E-06	4.5	100
24	2.46E-06	5.6	100	2.77E-06	6.5	100	1.99E-06	6.6	100	2.08E-06	4.5	100
25	1.75E-06	5.6	100	2.05E-06	6.5	100	1.44E-06	6.6	100	1.53E-06	4.5	100
26	1.96E-06	5.6	100	2.29E-06	6.5	100	1.58E-06	6.6	100	1.69E-06	4.5	100
27	2.69E-06	5.6	100	3.01E-06	6.5	100	2.25E-06	6.6	100	2.33E-06	4.5	100
28	3.00E-06	5.6	100	3.42E-06	6.5	100	2.51E-06	6.6	100	2.62E-06	4.5	100
29	5.70E-06	5.6	100	5.89E-06	6.5	100	4.71E-06	6.6	100	4.81E-06	4.5	100
30	3.77E-06	5.6	100	4.07E-06	6.5	100	3.17E-06	6.6	100	3.36E-06	4.5	100
31												
1ヶ月値	3.17E-06	5.8	100	3.29E-06	6.7	100	2.86E-06	6.7	100	3.01E-06	4.6	100
※最大値	1.68E-05	5.9	102	1.34E-05	6.9	103	1.30E-05	6.8	102	1.33E-05	4.6	103
最大値日時	04/17 14:30	04/01 00:01	04/01 01:19	04/22 05:51	04/01 00:01	04/12 04:44	04/06 06:54	04/01 00:01	04/01 00:15	04/06 06:47	04/01 00:01	04/18 03:08
※最小値	2.13E-07	5.6	97	0.00E+00	6.5	97	5.20E-08	6.6	97	0.00E+00	4.5	98
最小値日時	04/11 20:12	04/17 14:29	04/01 18:29	04/17 15:05	04/17 15:01	04/01 11:02	04/26 16:27	04/17 14:21	04/01 21:37	04/17 14:53	04/17 14:53	04/01 00:25

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2017/04

(7/7)

日	モニタ											
	A031 HTI南側(DM-73)			A032 HTI南側(DM-77)								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.95E-06	12.5	100	2.02E-06	9.8	100						
2	3.54E-06	12.5	100	3.69E-06	9.8	100						
3	3.63E-06	12.5	100	3.82E-06	9.8	100						
4	4.56E-06	12.5	100	4.68E-06	9.8	100						
5	6.89E-06	12.5	100	7.05E-06	9.8	100						
6	4.50E-06	12.5	100	4.65E-06	9.8	100						
7	2.55E-06	12.5	100	2.71E-06	9.8	100						
8	2.50E-06	12.5	100	2.71E-06	9.8	100						
9	3.82E-06	12.5	100	4.00E-06	9.8	100						
10	2.43E-06	12.5	100	2.66E-06	9.8	100						
11	2.53E-06	12.5	100	2.64E-06	9.8	100						
12	1.62E-06	12.5	100	1.82E-06	9.8	100						
13	2.00E-06	12.5	100	2.17E-06	9.8	100						
14	3.02E-06	12.5	100	3.20E-06	9.8	100						
15	5.29E-06	12.5	100	5.52E-06	9.8	100						
16	4.08E-06	12.5	100	4.24E-06	9.8	100						
17	*1 3.12E-06	12.4	100	*1 3.42E-06	9.8	100						
18	1.57E-06	12.2	100	1.57E-06	9.7	100						
19	2.30E-06	12.2	100	2.40E-06	9.7	100						
20	1.88E-06	12.2	100	1.92E-06	9.7	100						
21	3.86E-06	12.2	100	4.07E-06	9.7	100						
22	3.95E-06	12.2	100	4.18E-06	9.7	100						
23	2.28E-06	12.2	100	2.35E-06	9.7	100						
24	2.26E-06	12.2	100	2.27E-06	9.7	100						
25	1.56E-06	12.2	100	1.59E-06	9.7	100						
26	1.78E-06	12.2	100	1.91E-06	9.7	100						
27	2.21E-06	12.2	100	2.35E-06	9.7	100						
28	2.45E-06	12.2	100	2.62E-06	9.7	100						
29	4.76E-06	12.2	100	4.97E-06	9.7	100						
30	3.43E-06	12.2	100	3.53E-06	9.7	100						
31												
1ヶ月値	3.08E-06	12.4	100	3.22E-06	9.8	100						
※1 最大値	1.41E-05	12.5	102	1.45E-05	9.8	102						
最大値日時	04/05 09:26	04/01 00:01	04/01 00:53	04/06 05:31	04/01 00:01	04/01 03:32						
※1 最小値	0.00E+00	12.2	98	0.00E+00	9.7	98						
最小値日時	04/01 16:40	04/17 14:18	04/01 00:18	04/11 14:23	04/17 14:45	04/01 01:58						

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする