

| 承認 | 審査 | 作成 |
|----------|----------|----------|
| | | |
| 129.6.21 | 129.6.21 | 129.6.20 |

測定場所：一時保管エリアG（G-28）


一時保管エリア状況確認 サーベイ記録

| | | | |
|------|--------------------------------------|-------|------------|
| 件名 | 伐採木一時保管槽メッシュサーベイ（減容後、一時保管槽収納後における測定） | | |
| 測定日時 | 平成29年6月19日 9:50 ~ 10:05 | | |
| 測定者 | | 計測器番号 | F1-ICW-117 |

1 F 構内 全体図



(C)GeoEye / 日本スペースイメージング)



入口線量率(BG): $1.0 \mu\text{Sv/h}$

①～⑨の測定結果は別紙参照

備考 測定前準備 ■ バッテリーチェック ■ ゼロ点チェック

単位: $\mu\text{Sv/h}$

| 列 | No. | 線量率 | 列 | No. | 線量率 | 列 | No. | 線量率 | 列 | No. | 線量率 |
|---|-----|-----|---|-----|-----|---|-----|-----|---|-----|-----|
| ① | 1 | 2.5 | ⑤ | 5 | 5.0 | ⑨ | 9 | 3.5 | | | |
| ① | 2 | 3.5 | ⑤ | 6 | 6.0 | | | | | | |
| ① | 3 | 3.5 | ⑤ | 7 | 5.5 | | | | | | |
| ① | 4 | 3.0 | ⑤ | 8 | 6.0 | | | | | | |
| ① | 5 | 3.0 | ⑤ | 9 | 4.5 | | | | | | |
| ① | 6 | 3.5 | ⑥ | 1 | 4.0 | | | | | | |
| ① | 7 | 3.5 | ⑥ | 2 | 5.0 | | | | | | |
| ① | 8 | 3.5 | ⑥ | 3 | 5.5 | | | | | | |
| ① | 9 | 3.0 | ⑥ | 4 | 6.0 | | | | | | |
| ② | 1 | 3.5 | ⑥ | 5 | 5.0 | | | | | | |
| ② | 2 | 5.5 | ⑥ | 6 | 4.5 | | | | | | |
| ② | 3 | 5.0 | ⑥ | 7 | 5.0 | | | | | | |
| ② | 4 | 5.5 | ⑥ | 8 | 4.5 | | | | | | |
| ② | 5 | 5.5 | ⑥ | 9 | 4.0 | | | | | | |
| ② | 6 | 5.5 | ⑦ | 1 | 4.0 | | | | | | |
| ② | 7 | 6.0 | ⑦ | 2 | 4.5 | | | | | | |
| ② | 8 | 5.0 | ⑦ | 3 | 4.0 | | | | | | |
| ② | 9 | 4.0 | ⑦ | 4 | 4.5 | | | | | | |
| ③ | 1 | 3.5 | ⑦ | 5 | 5.0 | | | | | | |
| ③ | 2 | 5.0 | ⑦ | 6 | 5.0 | | | | | | |
| ③ | 3 | 5.5 | ⑦ | 7 | 5.5 | | | | | | |
| ③ | 4 | 6.0 | ⑦ | 8 | 5.0 | | | | | | |
| ③ | 5 | 6.0 | ⑦ | 9 | 4.0 | | | | | | |
| ③ | 6 | 5.5 | ⑧ | 1 | 4.5 | | | | | | |
| ③ | 7 | 6.0 | ⑧ | 2 | 5.0 | | | | | | |
| ③ | 8 | 5.0 | ⑧ | 3 | 5.0 | | | | | | |
| ③ | 9 | 4.5 | ⑧ | 4 | 5.0 | | | | | | |
| ④ | 1 | 4.0 | ⑧ | 5 | 6.0 | | | | | | |
| ④ | 2 | 5.0 | ⑧ | 6 | 5.0 | | | | | | |
| ④ | 3 | 5.5 | ⑧ | 7 | 4.5 | | | | | | |
| ④ | 4 | 5.0 | ⑧ | 8 | 4.5 | | | | | | |
| ④ | 5 | 6.0 | ⑧ | 9 | 4.0 | | | | | | |
| ④ | 6 | 6.0 | ⑨ | 1 | 2.5 | | | | | | |
| ④ | 7 | 5.5 | ⑨ | 2 | 3.0 | | | | | | |
| ④ | 8 | 5.5 | ⑨ | 3 | 3.5 | | | | | | |
| ④ | 9 | 4.0 | ⑨ | 4 | 3.0 | | | | | | |
| ⑤ | 1 | 3.5 | ⑨ | 5 | 3.5 | | | | | | |
| ⑤ | 2 | 5.0 | ⑨ | 6 | 3.0 | | | | | | |
| ⑤ | 3 | 5.0 | ⑨ | 7 | 3.5 | | | | | | |
| ⑤ | 4 | 5.5 | ⑨ | 8 | 3.5 | | | | | | |