

測定月報

測定日：2018/12

(1/11)

日	モニタ									
	B001	B002	B003	B004	B005	B006	B007	B008	B009	B010
	入退域管理棟周辺 線量率 (μ Sv/h)	正門警備所周辺 線量率 (μ Sv/h)	環境管理棟周辺 線量率 (μ Sv/h)	車両スクリーニング場周辺 線量率 (μ Sv/h)	厚生棟休憩所周辺 線量率 (μ Sv/h)	登録センター休憩所周辺 線量率 (μ Sv/h)	5、6号機サービス建屋休憩所周辺 線量率 (μ Sv/h)	シールド中央制御室周辺 線量率 (μ Sv/h)	免震重要棟周辺 線量率 (μ Sv/h)	5、6号機防蔽本部周辺 線量率 (μ Sv/h)
1	0.219	0.520	1.859	0.465	0.545	1.454	1.138	2.345	5.980	1.484
2	0.217	0.513	1.854	0.462	0.543	1.458	1.132	2.339	5.947	1.477
3	0.219	0.508	1.860	0.465	0.544	1.442	1.146	2.350	5.977	1.491
4	0.223	0.510	1.856	0.467	0.542	1.443	1.142	2.353	6.036	1.487
5	0.221	0.508	1.864	0.467	0.548	1.448	1.142	2.369	6.022	1.486
6	0.218	0.500	1.842	0.460	0.536	1.431	1.109	2.301	5.889	1.436
7	0.215	0.505	1.848	0.460	0.534	1.431	1.122	2.312	5.954	1.447
8	0.215	0.500	1.849	0.458	0.535	1.434	1.117	2.311	5.901	1.441
9	0.211	0.475	1.843	0.455	0.533	1.430	1.110	2.300	5.842	1.424
10	0.208	0.492	1.844	0.454	0.533	1.423	*1	2.300	5.832	1.429
11	0.212	0.504	1.841	0.457	0.534	1.430		2.298	5.835	1.430
12	0.211	0.496	1.832	0.456	0.530	1.425	1.096	2.280	5.848	1.407
13	0.212	0.495	1.838	0.452	0.530	1.432		2.271	5.857	1.422
14	0.211	0.495	1.844	0.456	0.534	1.437		2.279	5.848	1.427
15	0.210	0.490	1.839	0.453	0.531	1.431		2.276	5.817	1.423
16	0.215	0.444	1.849	0.456	0.533	1.432		2.286	5.870	1.445
17	0.218	0.481	1.852	0.464	0.539	1.443		2.312	5.940	1.467
18	0.214	0.493	1.852	0.463	0.537	1.439		2.304	5.899	1.457
19	0.213	0.508	1.841	0.457	0.537	1.433		2.301	5.883	1.456
20	0.214	0.492	1.837	0.454	0.533	1.430		2.293	5.869	1.436
21	0.213	0.486	1.842	0.456	0.534	1.434		2.298	5.870	1.443
22	0.220	0.505	1.850	0.461	0.539	1.453		2.333	5.932	1.466
23	0.220	0.497	1.846	0.459	0.539	1.449		2.317	5.904	1.463
24	0.215	0.492	1.839	0.457	0.534	1.441		2.291	5.842	1.443
25	0.214	0.483	1.837	0.456	0.531	1.434		2.291	5.847	1.442
26	0.217	0.495	1.847	0.462	0.536	1.509		2.327	5.899	1.463
27	0.216	0.487	1.840	0.460	0.535	1.471		2.314	5.861	1.451
28	0.213	0.494	1.834	0.456	0.533	1.424		2.288	5.819	1.440
29	0.213	0.491	1.834	0.453	0.531	1.423		2.281	5.789	1.432
30	0.214	0.503	1.833	0.454	0.531	1.419		2.286	5.782	1.433
31	0.213	0.502	1.832	0.455	0.529	1.422		2.286	5.794	1.442
1ヶ月値	0.215	0.496	1.844	0.458	0.536	1.439	1.133	2.306	5.883	1.448
最大値	0.248	0.576	1.946	0.555	0.597	1.612	1.213	2.479	6.233	1.561
最大値日時	12/04 15:30	12/04 21:30	12/04 18:40	12/11 10:20	12/19 11:30	12/26 11:40	12/03 15:30	12/18 12:00	12/05 00:30	12/05 21:30
最小値	0.172	0.380	1.724	0.411	0.486	1.349	1.050	2.126	5.594	1.340
最小値日時	12/09 20:50	12/17 04:30	12/12 07:10	12/29 00:10	12/31 08:50	12/11 07:30	12/06 16:30	12/13 07:50	12/31 04:50	12/12 05:30

*1：バッテリー低下に伴う欠測

測定月報

測定日：2018/12

(2/11)

日	モニタ									
	B011	B012	B013	B014	B015	B016	B017	B018	B019	B020
	1号機北側法面上周辺	1、2号機西側法面上周辺	3、4号機西側法面上周辺	4号機南側法面上周辺	一般焼却炉周辺	車両整備場周辺	多核種除去施設周辺	キャスク仮保管施設周辺	野鳥の森五差路周辺	5、6号機西側周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	45.920	41.116	9.436	1.107	17.634	0.752	0.600	0.212	2.258	5.727
2	45.628	40.630	9.665	1.092	17.622	0.748	0.597	0.209	2.200	5.713
3	46.065	41.094	9.875	1.200	17.603	0.752	0.606	0.212	2.276	5.729
4	46.676	41.710	10.121	1.301	17.440	0.757	0.612	0.218	2.394	5.696
5	46.558	41.552	10.073	1.272	17.464	0.757	0.610	0.214	2.350	5.727
6	44.879	40.245	9.616	1.203	17.225	0.745	0.597	0.213	2.191	5.591
7	45.383	40.830	9.833	1.232	17.243	0.751	0.592	0.212	2.273	5.589
8	45.024	40.285	9.605	1.227	17.348	0.760	0.581	0.207	2.167	5.597
9	44.404	39.668	9.410	1.202	17.300	0.756	0.577	0.203	2.098	5.575
10	44.445	39.533	9.362	1.179	17.241	0.752	0.587	0.200	2.087	5.580
11	44.417	39.558	9.330	1.201	17.225	0.796	0.591	0.203	2.100	5.582
12	44.555	39.873	9.571	1.199	16.969	0.802	0.591	0.207	2.167	5.496
13	44.587	39.861	9.621	1.065	17.144	0.792	0.589	0.204	2.147	5.551
14	44.530	39.869	9.756	1.130	17.207	0.770	0.591	0.204	2.138	5.567
15	44.145	39.506	9.611	1.205	17.263	0.738	0.601	0.203	2.076	5.555
16	44.769	40.148	9.846	1.234	17.292	0.741	0.605	0.209	2.167	5.529
17	45.688	40.863	10.163	1.132	17.334	0.751	0.623	0.213	2.288	5.615
18	45.454	40.371	9.903	0.960	17.282	0.798	0.608	0.209	2.222	5.630
19	45.297	40.436	9.992	0.859	17.263	0.820	0.606	0.210	2.216	5.615
20	44.930	40.209	9.735	1.046	17.226	0.794	0.599	0.205	2.175	5.585
21	44.946	40.136	9.704	1.208	17.249	0.760	0.594	0.205	2.171	5.591
22	45.784	40.855	9.720	1.249	17.425	0.759	0.600	0.214	2.275	5.644
23	45.316	40.581	10.047	1.240	17.365	0.755	0.596	0.212	2.245	5.627
24	44.780	40.000	9.739	1.206	17.308	0.747	0.588	0.208	2.175	5.595
25	44.737	39.845	9.699	1.204	17.258	0.739	0.587	0.204	2.154	5.599
26	45.537	40.625	10.039	1.238	17.297	0.739	0.591	0.209	2.251	5.643
27	45.052	40.225	9.900	1.221	17.298	0.829	0.589	0.207	2.204	5.629
28	44.473	39.623	9.694	1.191	17.279	0.822	0.582	0.203	2.117	5.592
29	44.187	39.381	9.612	1.181	17.278	0.735	0.582	0.202	2.083	5.575
30	44.202	39.336	9.586	1.178	17.271	0.730	0.580	0.202	2.075	5.571
31	44.337	39.489	9.625	1.183	17.316	0.735	0.583	0.202	2.083	5.603
1ヶ月値	45.055	40.240	9.738	1.172	17.312	0.764	0.595	0.208	2.188	5.612
最大値	47.805	42.824	10.659	1.401	17.924	0.984	0.688	0.267	2.598	5.949
最大値日時	12/04 22:20	12/04 20:00	12/04 20:10	12/04 12:10	12/01 13:20	12/11 10:40	12/05 14:50	12/12 14:10	12/04 20:40	12/01 10:00
最小値	43.103	38.557	6.889	0.754	16.427	0.653	0.529	0.171	1.951	5.326
最小値日時	12/31 04:40	12/31 04:40	12/22 12:40	12/19 10:30	12/12 06:50	12/21 10:00	12/10 04:20	12/09 06:20	12/31 04:40	12/06 18:00

測定月報

測定日：2018/12

(3/11)

日	モニタ									
	B021	B022	B023	B024	B025	B026	B027	B028	B029	B030
	西門周辺	さくら通り正門側	増設多核種除去設備西側周辺	トクシンクスリア周辺(通風ダクトモニタ小室側)	1、2号機海側(4m盤)	3、4号機海側(4m盤)	固体廃棄物貯蔵庫管理棟周辺	高性能多核種除去設備周辺	サブドレン浄化設備周辺	給油所周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.425	0.831	0.310	5.511	*1	*1	8.705	1.148	0.294	0.382
2	1.420	0.826	0.307	5.497			8.680	1.143	0.292	0.382
3	1.426	0.832	0.312	5.513			8.705	1.155	0.295	0.383
4	1.425	0.836	0.325	5.489			8.697	1.165	0.298	0.387
5	1.428	0.839	0.319	5.497			8.740	1.161	0.297	0.388
6	1.406	0.826	0.310	5.416			8.560	1.138	0.294	0.381
7	1.403	0.831	0.313	5.409			8.570	1.146	0.295	0.376
8	1.403	0.833	0.306	5.418			8.564	1.136	0.290	0.375
9	1.402	0.829	0.297	5.402			8.534	1.123	0.288	0.372
10	1.397	0.838	0.298	5.407			8.544	1.126	0.290	0.371
11	1.403	0.866	0.301	5.393			8.549	1.124	0.287	0.375
12	1.391	0.841	0.308	5.352			8.475	1.127	0.291	0.374
13	1.391	0.814	0.303	5.388			8.522	1.127	0.289	0.372
14	1.400	0.818	0.302	5.400			8.538	1.126	0.289	0.370
15	1.392	0.815	0.298	5.386			8.515	1.120	0.288	0.372
16	1.399	0.819	0.304	5.414			8.593	1.127	0.294	0.375
17	1.409	0.821	0.317	5.436			8.671	1.147	0.299	0.382
18	1.404	0.824	0.312	5.423			8.654	1.138	0.296	0.378
19	1.405	0.822	0.309	5.429			8.688	1.134	0.298	0.379
20	1.402	0.818	0.304	5.411			8.639	1.132	0.293	0.376
21	1.401	0.823	0.302	5.422			8.676	1.130	0.291	0.378
22	1.416	0.836	0.312	5.448			8.791	1.144	0.298	0.385
23	1.417	0.834	0.311	5.425			8.726	1.136	0.297	0.383
24	1.410	0.829	0.305	5.403			8.659	1.126	0.294	0.378
25	1.403	0.820	0.301	5.410			8.672	1.129	0.294	0.377
26	1.410	0.822	0.310	5.436			8.732	1.146	0.298	0.383
27	1.403	0.815	0.305	5.423			8.694	1.143	0.296	0.379
28	1.406	0.812	0.299	5.404			8.641	1.134	0.296	0.377
29	1.402	0.812	0.295	5.393			8.631	1.128	0.294	0.376
30	1.403	0.809	0.295	5.405			8.631	1.125	0.293	0.375
31	1.401	0.809	0.297	5.406			8.667	1.128	0.295	0.379
1ヶ月値	1.407	0.826	0.306	5.425			8.634	1.136	0.294	0.378
最大値	1.511	0.932	0.364	5.662			9.064	1.228	0.370	0.427
最大値日時	12/05 22:40	12/11 13:30	12/04 21:30	12/02 09:10			12/22 11:10	12/04 14:40	12/28 18:00	12/06 06:00
最小値	1.320	0.760	0.252	5.169			8.249	1.030	0.252	0.329
最小値日時	12/10 01:50	12/29 10:10	12/31 03:30	12/12 03:30			12/06 16:40	12/12 06:50	12/12 12:10	12/15 10:10

*1：線量表示器の故障に伴う欠測

測定月報

測定日：2018/12

(4/11)

日	モニタ									
	B031	B032	B033	B034	B035	B036	B037	B038	B039	B040
	HIC保管エリア周辺	H8タンクエリア周辺	H4タンクエリア周辺	H5タンクエリア周辺	J2タンクエリア周辺	1、2号機S/B周辺	センタム吸着塔中間貯蔵施設周辺	2号機R/B西側	1号機R/B西側	1号機R/B北側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.425	0.479	2.135	0.671	1.480	2.241	0.671	77.614	66.693	51.981
2	0.417	0.478	2.096	0.670	1.480	2.237	0.662	77.095	66.353	51.680
3	0.426	0.480	2.147	0.685	1.487	2.245	0.674	77.332	66.755	52.004
4	0.438	0.478	2.207	0.717	1.491	2.236	0.684	76.583	67.021	51.718
5	0.433	0.476	2.181	0.731	1.488	2.244	0.676	74.745	67.089	51.665
6	0.421	0.468	2.085	0.719	1.461	2.181	0.660	75.535	65.153	50.162
7	0.424	0.467	2.132	0.720	1.463	2.175	0.662	71.082	65.933	50.277
8	0.414	0.464	2.073	0.716	1.459	2.183	0.655	64.561	65.643	50.186
9	0.408	0.461	2.026	0.714	1.451	2.171	0.645	63.927	64.897	49.926
10	0.407	0.462	2.030	0.714	1.451	2.177	0.646	70.035	64.523	49.974
11	0.408	0.466	2.061	0.711	1.451	2.183	0.645	74.611	64.624	50.032
12	0.414	0.464	2.030	0.710	1.446	2.146	0.643	71.634	65.243	49.290
13	0.409	0.464	2.019	0.710	1.441	2.152	0.641	*1	64.911	49.702
14	0.409	0.466	2.019	0.709	1.447	2.170	0.642		64.741	49.993
15	0.403	0.464	1.986	0.709	1.439	2.166	0.636		64.402	49.824
16	0.414	0.469	2.038	0.711	1.452	2.184	0.643		65.265	50.449
17	0.425	0.476	2.110	0.716	1.458	2.206	0.658		65.730	51.189
18	0.418	0.470	2.078	0.713	1.460	2.203	0.657		65.400	50.957
19	0.419	0.470	2.072	0.716	1.461	2.208	0.656		65.230	50.963
20	0.414	0.467	2.054	0.712	1.454	2.191	0.646	*2	1206.358	50.611
21	0.415	0.467	2.050	0.711	1.457	2.200	0.642		1215.090	50.668
22	0.427	0.474	2.124	0.716	1.470	2.235	0.648		1223.686	51.431
23	0.422	0.473	2.113	0.713	1.466	2.210	0.643		1221.312	51.133
24	0.414	0.465	2.066	0.712	1.448	2.194	0.637		1215.730	50.485
25	0.413	0.469	2.041	0.709	1.449	2.199	0.636		1215.193	50.577
26	0.426	0.473	2.120	0.717	1.461	2.224	0.652		1222.291	51.258
27	0.417	0.469	2.084	0.713	1.460	2.216	0.648		1217.536	50.915
28	0.411	0.466	2.033	0.705	1.449	2.205	0.636		1210.804	50.454
29	0.408	0.463	2.011	0.704	1.446	2.201	0.634		1208.510	50.244
30	0.406	0.461	2.006	0.704	1.447	2.200	0.630		1207.898	50.251
31	0.408	0.466	2.011	0.705	1.447	2.212	0.633		1210.704	50.432
1ヶ月値	0.416	0.469	2.072	0.709	1.459	2.200	0.650		645.144	50.659
最大値	0.484	0.562	2.337	0.779	1.572	2.351	0.736		1232.715	53.172
最大値日時	12/05 12:40	12/03 10:30	12/04 22:30	12/22 17:50	12/05 05:40	12/03 11:30	12/01 13:10		12/22 14:50	12/01 13:10
最小値	0.366	0.418	1.905	0.625	1.350	1.963	0.577		41.471	48.187
最小値日時	12/02 00:00	12/11 03:50	12/25 08:10	12/02 09:40	12/21 15:20	12/13 10:00	12/25 08:10		12/05 07:50	12/12 03:30

*1：配備箇所付近の工事に伴い撤去したことによる欠測

*2：12月20日からB038をB087の代替機として配備

測定月報

測定日：2018/12

(5/11)

日	モニタ									
	B041	B042	B043	B044	B045	B046	B047	B048	B049	B050
	集中RW西側法面上	大型メンテナンス建屋 東側	大熊通り中央付近	1～4号機PPゲート前	1、2号機S/B周辺	3、4号機S/B周辺	集中RW東側	集中RW南側(PSFモニタ近傍)	共用プール西側	4号機R／B西側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	3.179	4.006	3.057	18.657	36.811	77.363	7.527	8.774	30.044	8.848
2	3.137	3.968	3.039	18.441	36.654	77.294	7.564	8.744	29.991	8.782
3	3.194	4.007	3.063	18.754	36.833	77.766	7.458	8.764	30.051	8.836
4	3.273	4.084	3.079	19.016	36.936	77.486	7.244	8.513	29.777	8.921
5	3.239	4.044	3.067	18.917	36.882	77.944	7.334	8.619	29.953	8.894
6	3.114	3.940	2.981	18.191	35.587	75.682	7.960	8.206	29.105	8.627
7	3.187	4.005	2.991	18.490	35.842	74.314	8.110	8.397	29.376	8.752
8	3.105	3.959	2.966	18.277	35.926	74.768	8.367	8.539	29.474	8.678
9	3.056	4.007	2.946	17.956	35.647	74.735	8.190	8.508	29.391	8.568
10	3.042	4.070	2.949	17.943	35.574	74.865	7.529	8.458	29.402	8.541
11	3.039	3.998	2.954	17.960	35.706	75.007	7.815	8.291	29.370	8.564
12	3.080	3.948	2.939	18.091	35.342	72.421	7.428	8.227	28.669	8.537
13	3.066	4.002	2.940	18.069	35.487	72.752	7.647	8.381	29.265	8.551
14	3.072	3.952	2.936	18.037	35.591	73.671	8.082	8.393	29.337	8.559
15	3.025	3.981	2.924	17.879	35.419	75.050	8.159	8.440	29.315	8.489
16	3.102	3.989	2.962	18.166	35.832	75.849	7.892	8.535	29.511	8.634
17	3.197	3.975	3.012	18.614	36.146	76.135	7.494	8.636	29.724	8.792
18	3.141	3.932	2.997	18.448	36.021	76.004	8.076	8.566	29.616	8.723
19	3.142	3.968	2.987	18.375	35.895	76.319	7.790	8.619	29.633	8.709
20	3.106	3.926	2.966	18.226	35.903	76.381	7.873	8.426	29.449	8.628
21	3.102	3.937	2.971	18.206	35.932	76.927	8.089	8.507	29.540	8.628
22	3.187	3.954	3.022	18.591	36.430	77.824	8.224	8.692	29.803	8.777
23	3.161	3.950	3.002	18.459	36.273	77.441	7.795	8.631	29.660	8.700
24	3.101	3.956	2.974	18.196	35.755	76.922	7.787	8.566	29.471	8.593
25	3.089	4.013	2.973	18.110	35.440	77.147	7.442	8.565	29.528	8.610
26	3.165	3.963	3.012	18.482	35.792	77.694	7.954	8.597	29.730	8.718
27	3.120	3.940	2.997	18.257	35.496	77.488	7.517	8.592	29.612	8.629
28	3.063	3.991	2.963	17.947	35.197	77.166	7.840	8.597	29.465	8.504
29	3.033	4.019	2.949	17.785	35.077	77.045	7.816	8.575	29.389	8.446
30	3.023	4.068	2.951	17.783	35.126	77.114	7.623	8.583	29.395	8.454
31	3.032	3.968	2.953	17.864	35.310	77.405	7.965	8.597	29.467	8.477
1ヶ月値	3.115	3.985	2.985	18.264	35.867	76.193	7.793	8.534	29.533	8.651
最大値	3.452	4.417	3.210	19.978	37.875	78.914	8.767	8.999	30.515	9.199
最大値日時	12/04 22:00	12/10 07:30	12/04 22:10	12/07 18:30	12/05 00:40	12/03 16:30	12/22 12:50	12/01 11:10	12/01 10:30	12/04 21:20
最小値	2.864	3.717	2.818	17.335	34.349	69.986	6.545	6.434	27.565	8.174
最小値日時	12/30 06:30	12/15 17:00	12/12 03:30	12/31 04:50	12/30 03:40	12/12 10:00	12/17 08:00	12/25 10:30	12/06 16:20	12/30 08:00

測定月報

測定日：2018/12

(6/11)

日	モニタ									
	B051	B052	B053	B054	B055	B056	B057	B058	B059	B060
	3号機R/B西側	2号機R/B西側	1号機R/B西側	1号機R/B北側	物揚場周辺	固体庫1, 2棟周辺	旧事務本館北側	固体庫第9棟建設地周辺	危険物屋外貯蔵所周辺	6号機D/G建屋周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	115.954	78.616	69.603	52.786	5.334	4.571	9.360	0.428	1.877	2.053
2	115.537	78.056	69.246	52.482	5.283	4.532	9.264	0.426	1.883	2.053
3	115.937	78.262	69.662	52.829	5.644	4.594	9.307	0.429	1.888	2.058
4	116.027	77.615	69.846	52.621	5.989	4.594	8.517	0.432	1.873	2.009
5	116.305	75.939	69.961	52.546	6.147	4.589	9.102	0.431	1.873	2.023
6	114.076	76.484	67.925	51.067	5.069	4.441	8.710	0.422	1.838	1.924
7	114.239	73.908	68.710	51.264	5.161	4.479	8.875	0.420	1.816	1.936
8	113.692	69.475	68.418	51.136	5.058	4.435	8.699	0.416	1.830	1.943
9	113.029	68.762	67.660	50.812	4.973	4.362	8.555	0.414	1.824	1.941
10	113.107	72.363	67.295	50.902	5.019	4.372	8.456	0.414	1.820	1.946
11	112.714	75.582	67.391	50.886	5.075	4.380	8.876	0.416	1.829	1.950
12	113.249	73.598	68.065	50.293	5.490	4.364	9.505	0.414	1.791	1.830
13	113.762	*1	67.759	50.676	6.142	4.374	9.530	0.412	1.808	1.914
14	113.652		67.540	50.880	5.814	4.386	9.676	0.413	1.812	1.932
15	113.065		67.178	50.695	5.813	4.350	9.645	0.411	1.806	1.932
16	113.823		68.056	51.379	5.957	4.412	9.823	0.415	1.824	1.949
17	115.080		68.493	52.086	6.093	4.534	10.057	0.419	1.842	1.969
18	114.819		68.150	51.878	6.165	4.484	9.936	0.420	1.845	1.966
19	113.929		68.026	51.848	5.999	4.472	9.908	0.419	1.836	1.967
20	112.828		67.804	51.493	5.675	4.432	9.814	0.417	1.857	1.960
21	112.982		68.018	51.535	5.321	4.439	9.815	0.419	1.864	1.960
22	113.967		68.973	52.316	5.562	4.548	10.031	0.423	1.889	1.983
23	113.430		68.717	52.032	5.517	4.496	9.941	0.423	1.876	1.970
24	113.522		67.802	51.406	5.403	4.422	9.776	0.417	1.864	1.961
25	113.696		67.125	51.442	5.387	4.438	9.760	0.417	1.871	1.965
26	114.041		68.443	52.123	5.317	4.512	9.957	0.423	1.889	1.986
27	113.127		68.195	51.775	5.223	4.477	9.835	0.420	1.885	1.980
28	112.524		67.401	51.265	5.136	4.402	9.669	0.416	1.874	1.967
29	112.115		67.054	51.069	5.103	4.380	9.590	0.413	1.872	1.962
30	112.101		67.012	51.062	5.090	4.372	9.583	0.414	1.868	1.959
31	112.425		67.267	51.208	5.103	4.399	9.619	0.416	1.874	1.968
1ヶ月値	113.831	74.947	68.155	51.542	5.486	4.453	9.458	0.419	1.851	1.965
最大値	117.672	80.582	71.532	54.032	7.328	4.869	10.387	0.473	1.980	2.138
最大値日時	12/05 00:10	12/01 12:00	12/05 01:30	12/01 12:40	12/05 12:30	12/04 23:30	12/22 14:30	12/04 16:00	12/19 14:30	12/02 12:50
最小値	109.259	39.493	49.560	49.222	4.719	4.052	6.127	0.370	1.121	1.663
最小値日時	12/11 13:00	12/05 07:50	12/25 10:30	12/12 06:20	12/10 06:40	12/05 11:00	12/04 20:50	12/16 00:50	12/19 10:30	12/12 06:50

*1：配備箇所付近の工事に伴い撤去したことによる欠測

測定月報

測定日：2018/12

(7/11)

日	モニタ									
	B061	B062	B063	B064	B065	B066	B067	B068	B069	B070
	5、6号機放水口周辺	焼却設備建屋周辺	Fタンクエリア周辺	ヤード P1東側周辺	焼却設備建屋前道路カーブミラー脇	建設資材置場	一時保管エリアC周辺	ALPS連ダ周辺	一時保管エリアH1周辺	土捨場資材置場
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.753	1.725	30.336	11.642	2.546	2.290	1.517	0.363	3.195	0.549
2	0.751	1.717	30.276	11.631	2.540	2.287	1.516	0.357	3.190	0.546
3	0.757	1.729	30.358	11.661	2.555	2.293	1.532	0.362	3.202	0.549
4	0.755	1.734	30.365	11.661	2.557	2.295	1.509	0.370	3.183	0.552
5	0.755	1.737	30.409	11.684	2.556	2.317	1.513	0.367	3.197	0.549
6	0.732	1.697	30.222	11.549	2.507	2.278	1.481	0.359	3.135	0.540
7	0.724	1.698	30.226	11.543	2.501	2.278	1.466	0.360	3.095	0.531
8	0.725	1.694	30.201	11.530	2.501	2.275	1.466	0.355	3.117	0.530
9	0.722	1.683	30.114	11.492	2.483	2.261	1.457	0.349	3.119	0.528
10	0.721	1.677	30.077	11.479	2.483	2.260	1.468	0.349	3.120	0.527
11	0.725	1.683	30.104	11.509	2.489	2.270	1.476	0.352	3.131	0.531
12	0.713	1.669	30.107	11.459	2.467	2.238	1.436	0.351	3.049	0.525
13	0.715	1.672	30.071	11.454	2.472	2.310	1.416	0.348	3.079	0.524
14	0.721	1.680	30.080	11.450	2.482	2.350	1.416	0.349	3.093	0.526
15	0.717	1.672	30.016	11.435	2.478	2.365	1.416	0.346	3.099	0.524
16	0.724	1.686	30.049	11.443	2.486	2.380	1.427	0.353	3.116	0.530
17	0.733	1.703	30.121	11.510	2.509	2.386	1.445	0.359	3.137	0.541
18	0.732	1.696	30.060	11.486	2.506	2.342	1.429	0.356	3.138	0.537
19	0.731	1.698	30.040	11.500	2.507	2.254	1.414	0.356	3.144	0.538
20	0.726	1.687	29.998	11.463	2.493	2.210	1.426	0.351	3.136	0.533
21	0.725	1.687	30.052	11.477	2.497	2.212	1.453	0.350	3.138	0.537
22	0.739	1.716	30.220	11.555	2.527	2.232	1.480	0.358	3.174	0.544
23	0.739	1.707	30.144	11.504	2.515	2.215	1.475	0.358	3.163	0.543
24	0.726	1.687	30.038	11.458	2.495	2.200	1.461	0.351	3.143	0.538
25	0.728	1.689	30.039	11.466	2.492	2.229	1.448	0.352	3.149	0.537
26	0.740	1.705	30.099	11.511	2.519	2.255	1.471	0.359	3.160	0.546
27	0.737	1.701	30.017	11.461	2.500	2.238	1.458	0.356	3.162	0.542
28	0.727	1.684	29.920	11.413	2.487	2.223	1.448	0.348	3.156	0.539
29	0.728	1.675	29.866	11.395	2.485	2.220	1.442	0.347	3.147	0.537
30	0.727	1.670	29.857	11.389	2.481	2.217	1.447	0.344	3.150	0.536
31	0.730	1.689	29.936	11.445	2.490	2.228	1.453	0.346	3.164	0.537
1ヶ月値	0.732	1.695	30.111	11.505	2.503	2.271	1.460	0.354	3.141	0.537
最大値	0.922	1.834	30.711	11.883	2.681	2.507	1.606	0.404	3.319	0.600
最大値日時	12/27 12:20	12/05 16:20	12/03 14:20	12/01 14:10	12/04 20:20	12/17 11:30	12/03 12:10	12/03 11:40	12/02 11:30	12/26 12:30
最小値	0.664	1.582	29.485	11.133	2.353	2.109	1.282	0.305	2.948	0.480
最小値日時	12/07 05:20	12/10 02:10	12/30 05:30	12/30 03:20	12/16 05:00	12/25 03:50	12/20 09:00	12/15 06:00	12/12 05:00	12/15 20:50

測定月報

測定日：2018/12

(8/11)

日	モニタ									
	B071	B072	B073	B074	B075	B076	B077	B078	B079	B080
	土捨場東側資材置場 線量率 (μ Sv/h)	瓦礫保管Aテント周辺 線量率 (μ Sv/h)	覆土式瓦礫保管エリアL北側 線量率 (μ Sv/h)	覆土式瓦礫保管エリアL南側 線量率 (μ Sv/h)	一時保管エリアG2周辺 線量率 (μ Sv/h)	一時保管エリアG1周辺 線量率 (μ Sv/h)	5、6号機迂回道路付近 線量率 (μ Sv/h)	一時保管エリアM周辺 線量率 (μ Sv/h)	旧研修棟正面玄関前 線量率 (μ Sv/h)	3、4号機北面ダストモニタ周辺 線量率 (μ Sv/h)
1	1.865	22.358	4.364	0.675	0.351	0.988	3.270	1.508	32.934	9.877
2	1.862	22.346	4.358	0.671	0.346	0.984	3.258	1.500	32.836	9.704
3	1.869	22.379	4.409	0.676	0.351	0.991	3.271	1.515	33.062	9.959
4	1.877	22.145	4.399	0.677	0.354	0.983	3.250	1.510	33.156	10.378
5	1.876	22.284	4.416	0.677	0.353	0.984	3.281	1.518	33.025	10.280
6	1.839	21.871	4.294	0.651	0.346	0.964	3.185	1.474	32.071	9.718
7	1.835	21.772	4.228	0.634	0.343	0.958	3.162	1.451	32.326	10.009
8	1.832	21.940	4.254	0.624	0.340	0.961	3.181	1.460	32.136	9.732
9	1.817	21.914	4.246	0.618	0.337	0.951	3.165	1.450	31.899	9.464
10	1.812	21.973	4.282	0.618	0.334	0.952	3.125	1.458	31.959	9.442
11	1.820	21.898	4.307	0.605	0.340	0.955	3.130	1.456	32.005	9.471
12	1.810	21.590	4.233	0.590	0.336	0.942	3.087	1.424	31.709	9.684
13	1.807	21.739	4.228	0.593	0.339	0.951	3.096	1.433	32.031	9.610
14	1.809	21.836	4.237	0.596	0.339	0.952	3.122	1.445	32.094	9.595
15	1.806	21.826	4.233	0.590	0.336	0.952	3.122	1.442	32.149	9.406
16	1.820	21.933	4.244	0.598	0.340	0.956	3.139	1.451	32.529	9.687
17	1.838	22.009	4.291	0.611	0.348	0.970	3.171	1.470	32.896	10.105
18	1.830	21.977	4.302	0.606	0.344	0.964	3.168	1.472	32.830	9.909
19	1.798	22.014	4.308	0.587	0.345	0.967	3.169	1.470	32.763	9.875
20	1.761	21.967	4.270	0.563	0.342	0.964	3.195	1.461	32.525	9.749
21	1.762	22.024	4.281	0.564	0.340	0.962	3.239	1.462	32.614	9.715
22	1.787	22.237	4.318	0.578	0.349	0.977	3.300	1.486	33.040	10.084
23	1.781	22.152	4.298	0.574	0.348	0.971	3.286	1.474	32.799	9.944
24	1.758	22.056	4.269	0.560	0.339	0.959	3.254	1.463	32.452	9.714
25	1.766	22.134	4.287	0.562	0.341	0.963	3.257	1.466	32.516	9.661
26	1.778	22.443	4.326	0.576	0.346	0.975	3.297	1.483	32.831	9.995
27	1.763	22.881	4.296	0.564	0.345	0.972	3.283	1.481	32.685	9.822
28	1.763	22.820	4.270	0.552	0.340	0.968	3.265	1.472	32.424	9.542
29	1.759	22.799	4.263	0.550	0.336	0.963	3.261	1.466	32.269	9.434
30	1.757	22.790	4.256	0.548	0.336	0.958	3.253	1.469	32.253	9.402
31	1.770	22.849	4.277	0.550	0.338	0.964	3.269	1.477	32.369	9.451
1ヶ月値	1.807	22.160	4.292	0.601	0.343	0.965	3.210	1.470	32.490	9.755
最大値	1.955	23.244	4.540	0.740	0.388	1.053	3.422	1.596	33.825	10.968
最大値日時	12/05 00:20	12/28 13:50	12/03 13:40	12/04 21:10	12/16 11:50	12/04 23:20	12/26 14:10	12/05 08:10	12/22 13:50	12/04 20:10
最小値	1.590	20.608	4.066	0.503	0.293	0.874	2.790	1.351	30.587	9.062
最小値日時	12/10 11:40	12/07 10:40	12/06 18:00	12/30 19:50	12/14 21:10	12/12 04:50	12/05 09:00	12/12 02:40	12/14 08:50	12/31 06:30

測定月報

測定日：2018/12

(9/11)

日	モニタ									
	B081 事務本館南	B082 大型メンテナンス建屋周辺	B083 2、3号機前道路西側(10m盤)	B084 3、4号機海側	B085 中央交差点	B086 No.4倉庫周辺	B087 1、2号機排気筒西側	B088 1、2号機海側(4m盤)	B089 線量表示器89	B090 線量表示器90
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	10.288	1.137	79.988	11.308	0.386	12.212	1211.940			
2	10.071	1.121	79.407	11.202	0.382	12.193	*1			
3	10.331	1.145	79.854	11.347	0.387	12.240				
4	10.699	1.170	79.608	11.507	0.389	12.151				
5	10.559	1.158	77.185	11.400	0.389	12.226				
6	9.995	1.114	78.436	10.858	0.382	11.920				
7	10.285	1.127	64.769	10.911	0.379	11.939	1199.315			
8	9.958	1.106	47.994	10.737	0.377	11.994	1195.952			
9	9.693	1.089	47.464	10.589	0.373	11.940	1191.995			
10	9.662	1.084	66.153	10.603	0.372	11.940	1192.754			
11	9.691	1.095	77.289	10.610	0.376	11.940	1194.062			
12	9.932	1.060	73.691	10.676	0.375	11.762	1189.185			
13	9.868	1.036	72.829	10.807	0.373	11.874	1190.941			
14	9.851	1.108	59.506	10.805	0.375	11.921				
15	9.647	1.130	44.196	10.708	0.372	11.911				
16	9.947	1.152	44.583	10.885	0.375	11.968	1198.503			
17	10.332	1.187	65.048	11.127	0.381	12.012	1199.545	*2	11.521	*2 12.274
18	10.129	1.172	78.170	11.054	0.381	11.975	1197.037		11.516	12.299
19	10.126	1.165	62.762	11.042	0.382	12.024	1197.708			
20	9.983	1.160	49.915	10.974	0.377	11.920				
21	9.976	1.156	49.860	11.022	0.379	11.944				
22	10.300	1.186	50.686	11.261	0.384	12.110				
23	10.187	1.174	50.329	11.156	0.384	12.024				
24	9.936	1.155	65.911	10.962	0.376	11.959				
25	9.896	1.154	76.906	10.877	0.377	11.959				
26	10.216	1.179	65.049	11.058	0.381	12.069				
27	10.014	1.159	48.747	10.950	0.381	12.050				
28	9.755	1.141	48.149	10.833	0.374	11.996				
29	9.635	1.130	47.906	10.750	0.376	11.963				
30	9.603	1.122	47.878	10.750	0.374	11.942				
31	9.641	1.132	48.071	10.804	0.375	11.998				
1ヶ月値	10.007	1.136	62.204	10.954	0.379	12.002	1196.403		11.518	12.288
最大値	11.210	1.249	82.006	11.866	0.430	12.529	1220.473		11.746	12.535
最大値日時	12/04 19:50	12/17 13:20	12/01 12:00	12/04 23:50	12/22 19:40	12/01 09:50	12/01 13:30		12/18 10:30	12/18 09:50
最小値	9.223	0.950	43.403	10.184	0.331	11.405	1180.761		10.382	9.869
最小値日時	12/31 04:50	12/12 09:20	12/16 00:20	12/12 05:00	12/14 10:30	12/12 03:40	12/12 07:00		12/17 16:00	12/17 16:00

*1：バッテリー低下に伴う欠測

*2：モニタリングポスト近傍の通信確認のための一時的な利用

測定月報

測定日：2018/12

(10/11)

日	モニタ									
	B091	B092	B093	B094	B095	B096	B097	B098	B099	B100
	2号機西側連ダカバー内 線量率 (μ Sv/h)	携行利用型線量表示器92 線量率 (μ Sv/h)	携行利用型線量表示器93 線量率 (μ Sv/h)	携行利用型線量表示器94 線量率 (μ Sv/h)	携行利用型線量表示器95 線量率 (μ Sv/h)	3号機海側連ダ小屋内 線量率 (μ Sv/h)	1、2号機海側 線量率 (μ Sv/h)	携行利用型線量表示器98 線量率 (μ Sv/h)	携行利用型線量表示器99 線量率 (μ Sv/h)	携行利用型線量表示器100 線量率 (μ Sv/h)
1	57.192					12.255	12.055			
2	56.868					12.131	11.899			
3	56.858					12.242	12.134			
4	56.873					12.530	12.479			
5	56.779					12.558	12.362			
6	55.751					11.997	11.712			
7	55.778					12.178	11.993			
8	55.637					12.017	11.762			
9	55.099					11.814	11.487			
10	54.877					11.847	11.499			
11	54.838					11.867	11.508	*1 4.045		
12	55.018					11.883	11.640	1.258		
13	54.454					11.872	11.643			
14	54.474					11.849	11.629			
15	54.738					11.733	11.438			
16	55.070					11.953	11.733			
17	55.661					12.293	12.108			
18	55.632					12.176	11.963			
19	57.850					12.185	11.884			
20	55.235					12.107	11.812			
21	55.215					12.170	11.809			
22	55.930					12.469	12.158			
23	55.708					12.398	12.043			
24	55.277					12.175	11.769			
25	55.244					12.119	11.644			
26	56.959					12.358	11.943			
27	57.738					12.248	11.707			
28	57.162					12.060	11.470			
29	56.893					11.943	11.331			
30	56.803					11.933	11.320			
31	57.001					11.979	11.375			
1ヶ月値	55.955					12.108	11.784	3.116		
最大値	66.207					13.094	13.022	5.793		
最大値日時	12/19 15:40					12/22 13:50	12/04 20:30	12/11 15:50		
最小値	52.992					11.426	10.944	1.258		
最小値日時	12/13 09:20					12/15 06:50	12/31 05:20	12/12 11:00		

*1：モニタリングポスト近傍の通信確認のための一時的な利用