

承認	審査	作成
2019.8.8	2019.8.7	2019.8.7

各建屋滞留水移送ライン近傍線量率データ(月報)

2019年 7月分

各建屋滞留水移送ライン近傍線量率データ(2019年7月分)

月日	2号T/B出口 ($\mu\text{Sv/h}$)	3号T/B入口 ($\mu\text{Sv/h}$)	4号T/B出口 ($\mu\text{Sv/h}$)	HTI建屋入口 ($\mu\text{Sv/h}$)	プロセス主建屋入口 ($\mu\text{Sv/h}$)	焼却工作建屋出口 ($\mu\text{Sv/h}$)	備考
7/1	1.25E+02	7.32E+02	4.92E+01	7.01E+01	2.96E+01	4.07E+01	
7/2	1.34E+02	1.04E+03	5.26E+01	6.44E+01	2.95E+01	3.70E+01	
7/3	1.35E+02	1.00E+03	5.16E+01	6.83E+01	2.94E+01	3.82E+01	
7/4	1.26E+02	8.20E+02	5.15E+01	8.14E+01	3.19E+01	4.78E+01	
7/5	1.27E+02	7.38E+02	4.97E+01	7.17E+01	3.01E+01	4.14E+01	
7/6	1.42E+02	1.10E+03	4.21E+01	6.45E+01	2.74E+01	3.49E+01	
7/7	1.35E+02	9.51E+02	5.17E+01	8.64E+01	3.28E+01	4.93E+01	
7/8	1.24E+02	7.18E+02	4.92E+01	7.05E+01	2.95E+01	4.13E+01	
7/9	1.27E+02	7.78E+02	3.73E+01	4.63E+01	2.41E+01	2.53E+01	
7/10	1.24E+02	6.23E+02	4.82E+01	6.72E+01	2.89E+01	3.83E+01	
7/11	1.28E+02	7.96E+02	4.87E+01	6.86E+01	2.95E+01	3.96E+01	
7/12	1.27E+02	6.88E+02	4.11E+01	5.16E+01	2.57E+01	2.94E+01	
7/13	1.48E+02	1.20E+03	5.59E+01	5.91E+01	2.57E+01	3.84E+01	
7/14	1.29E+02	7.96E+02	4.49E+01	5.83E+01	2.74E+01	3.40E+01	
7/15	1.42E+02	1.10E+03	5.46E+01	7.82E+01	3.30E+01	4.86E+01	
7/16	1.24E+02	7.01E+02	3.39E+01	6.79E+01	2.09E+01	3.54E+01	
7/17	1.39E+02	9.94E+02	3.83E+01	6.80E+01	2.04E+01	3.50E+01	
7/18	1.44E+02	1.00E+03	3.59E+01	6.86E+01	2.11E+01	3.49E+01	
7/19	1.19E+02	6.31E+02	3.55E+01	6.78E+01	2.03E+01	3.46E+01	
7/20	1.44E+02	1.10E+03	3.13E+01	6.80E+01	1.83E+01	3.46E+01	
7/21	1.38E+02	9.88E+02	3.84E+01	6.66E+01	2.21E+01	3.44E+01	
7/22	1.20E+02	6.46E+02	3.76E+01	6.70E+01	2.20E+01	3.46E+01	
7/23	1.37E+02	1.00E+03	3.84E+01	6.57E+01	2.26E+01	3.42E+01	
7/24	1.43E+02	1.10E+03	4.27E+01	6.70E+01	2.47E+01	3.48E+01	
7/25	1.26E+02	7.21E+02	4.71E+01	6.77E+01	2.75E+01	3.88E+01	
7/26	1.39E+02	9.35E+02	4.43E+01	5.74E+01	2.55E+01	3.24E+01	
7/27	1.50E+02	1.20E+03	5.61E+01	7.08E+01	2.95E+01	4.15E+01	
7/28	1.49E+02	1.20E+03	4.26E+01	5.56E+01	2.49E+01	3.21E+01	
7/29	1.20E+02	5.95E+02	4.37E+01	5.78E+01	2.53E+01	3.30E+01	
7/30	1.48E+02	1.10E+03	5.24E+01	7.89E+01	3.03E+01	4.85E+01	
7/31	1.21E+02	6.56E+02	4.34E+01	5.51E+01	2.54E+01	3.41E+01	