

水処理運転管理部 水処理運営G

承認	審査	作成
2019.10.16	2019.10.16	2019.10.16

各建屋滞留水移送ライン近傍線量率データ(月報)

2019年 9月分

各建屋滞留水移送ライン近傍線量率データ(2019年9月分)

月日	2号T／B出口 ($\mu\text{Sv/h}$)	3号T／B入口 ($\mu\text{Sv/h}$)	4号T／B出口 ($\mu\text{Sv/h}$)	HTI建屋入口 ($\mu\text{Sv/h}$)	プロセス主建屋入口 ($\mu\text{Sv/h}$)	焼却工作建屋出口 ($\mu\text{Sv/h}$)	備考
9/1	1.66E+02	1.40E+03	5.32E+01	7.18E+01	3.13E+01	3.98E+01	
9/2	1.24E+02	6.51E+02	3.95E+01	7.23E+01	2.27E+01	3.96E+01	
9/3	1.62E+02	1.40E+03	4.52E+01	7.18E+01	2.58E+01	3.97E+01	
9/4	1.26E+02	7.20E+02	4.14E+01	7.06E+01	2.39E+01	3.93E+01	
9/5	1.21E+02	6.10E+02	3.81E+01	7.04E+01	2.17E+01	3.96E+01	
9/6	1.66E+02	1.50E+03	5.14E+01	7.08E+01	3.01E+01	3.94E+01	
9/7	1.66E+02	1.40E+03	4.48E+01	7.11E+01	2.54E+01	3.96E+01	
9/8	1.62E+02	1.30E+03	4.41E+01	1.11E+01	2.52E+01	3.97E+01	
9/9	1.54E+02	1.30E+03	5.57E+01	6.11E+01	3.31E+01	3.90E+01	
9/10	1.64E+02	1.40E+03	4.95E+01	6.97E+01	2.98E+01	3.92E+01	
9/11	1.21E+02	6.10E+02	3.71E+01	6.28E+01	2.50E+01	4.05E+01	
9/12	1.63E+02	1.40E+03	4.92E+01	5.83E+01	2.42E+01	3.70E+01	
9/13	1.55E+02	1.20E+03	3.76E+01	5.40E+01	2.07E+01	3.20E+01	
9/14	1.64E+02	1.40E+03	4.84E+01	5.93E+01	2.46E+01	3.82E+01	
9/15	1.42E+02	8.81E+02	3.17E+01	5.28E+01	1.96E+01	2.95E+01	
9/16	1.27E+02	8.07E+02	3.73E+01	5.74E+01	2.18E+01	3.50E+01	
9/17	1.25E+02	6.92E+02	3.64E+01	6.19E+01	2.18E+01	3.64E+01	
9/18	1.21E+02	6.07E+02	3.45E+01	5.51E+01	2.00E+01	3.10E+01	
9/19	1.38E+02	7.58E+02	4.00E+01	5.92E+01	2.13E+01	3.42E+01	
9/20	1.67E+02	1.40E+03	4.85E+01	6.07E+01	2.43E+01	3.88E+01	
9/21	1.47E+02	1.00E+03	3.54E+01	5.94E+01	2.10E+01	3.30E+01	
9/22	1.30E+02	7.96E+02	3.81E+01	6.94E+01	2.27E+01	3.96E+01	
9/23	1.51E+02	1.30E+03	5.30E+01	8.19E+01	2.77E+01	4.86E+01	
9/24	1.63E+02	1.40E+03	3.94E+01	5.10E+01	2.41E+01	2.96E+01	
9/25	1.71E+02	1.60E+03	4.90E+01	5.20E+01	2.46E+01	2.90E+01	
9/26	1.54E+02	1.10E+03	4.35E+01	5.26E+01	2.36E+01	2.97E+01	
9/27	1.24E+02	6.57E+02	3.38E+01	5.25E+01	1.93E+01	2.94E+01	
9/28	1.71E+02	1.50E+03	4.03E+01	5.29E+01	2.44E+01	2.94E+01	
9/29	1.25E+02	6.64E+02	3.29E+01	5.24E+01	1.96E+01	2.95E+01	
9/30	1.31E+02	7.94E+02	3.65E+01	5.29E+01	2.10E+01	2.94E+01	