

運用部 運用支援G

承認	審査	作成
2021.4.16	2021.4.15	2021.4.14

## 各建屋滞留水移送ライン近傍線量率データ(月報)

2021年 3月分

各建屋滞留水移送ライン近傍線量率データ(2021年3月分)

月日	2号T／B出口 ( $\mu\text{Sv/h}$ )	3号T／B入口 ( $\mu\text{Sv/h}$ )	4号T／B出口 ( $\mu\text{Sv/h}$ )	HTI建屋入口 ( $\mu\text{Sv/h}$ )	プロセス主建屋入口 ( $\mu\text{Sv/h}$ )	焼却工作建屋出口 ( $\mu\text{Sv/h}$ )	備考
3/1	3.29E+02	1.87E+02	3.10E+01	4.35E+01	1.62E+01	5.65E+01	
3/2	3.30E+02	1.92E+02	3.15E+01	4.34E+01	1.71E+01	5.65E+01	
3/3	3.31E+02	2.11E+02	2.97E+01	4.33E+01	1.51E+01	5.59E+01	
3/4	4.05E+02	4.92E+02	5.61E+01	4.29E+01	3.20E+01	5.63E+01	
3/5	3.65E+02	3.29E+02	3.57E+01	4.31E+01	1.90E+01	5.63E+01	
3/6	3.83E+02	3.89E+02	3.84E+01	4.34E+01	2.02E+01	5.66E+01	
3/7	3.73E+02	3.63E+02	3.73E+01	4.29E+01	1.92E+01	5.65E+01	
3/8	3.69E+02	3.49E+02	3.64E+01	4.27E+01	1.89E+01	5.62E+01	
3/9	3.68E+02	3.44E+02	3.67E+01	4.31E+01	1.88E+01	5.66E+01	
3/10	3.67E+02	3.31E+02	3.57E+01	4.32E+01	1.86E+01	5.67E+01	
3/11	3.66E+02	3.34E+02	3.58E+01	4.32E+01	1.82E+01	5.67E+01	
3/12	3.57E+02	2.97E+02	3.39E+01	4.33E+01	1.86E+01	5.70E+01	
3/13	3.54E+02	3.26E+02	3.46E+01	4.18E+01	1.80E+01	5.57E+01	
3/14	3.30E+02	2.09E+02	3.01E+01	4.13E+01	1.54E+01	5.64E+01	
3/15	3.46E+02	2.62E+02	3.12E+01	4.31E+01	1.60E+01	5.43E+01	
3/16	3.37E+02	2.28E+02	3.08E+01	4.29E+01	1.57E+01	5.64E+01	
3/17	3.43E+02	2.52E+02	3.06E+01	4.30E+01	1.57E+01	4.91E+01	
3/18	3.47E+02	2.57E+02	3.06E+01	4.32E+01	1.59E+01	4.97E+01	
3/19	3.32E+02	2.03E+02	2.96E+01	4.33E+01	1.50E+01	4.98E+01	
3/20	3.37E+02	2.24E+02	3.23E+01	4.30E+01	1.63E+01	4.98E+01	
3/21	3.47E+02	2.86E+02	3.24E+01	4.32E+01	1.69E+01	4.98E+01	
3/22	3.49E+02	2.83E+02	3.25E+01	4.23E+01	1.61E+01	4.95E+01	
3/23	3.41E+02	2.47E+02	3.09E+01	4.38E+01	1.60E+01	5.04E+01	
3/24	3.51E+02	2.75E+02	3.24E+01	4.40E+01	1.67E+01	5.01E+01	
3/25	3.49E+02	2.68E+02	3.21E+01	4.42E+01	1.72E+01	5.06E+01	
3/26	3.59E+02	3.00E+02	3.20E+01	4.43E+01	1.68E+01	5.01E+01	
3/27	3.44E+02	2.48E+02	3.37E+01	4.40E+01	1.73E+01	4.99E+01	
3/28	3.53E+02	2.81E+02	3.32E+01	4.40E+01	1.73E+01	4.99E+01	
3/29	3.43E+02	2.55E+02	3.17E+01	4.23E+01	1.58E+01	5.01E+01	
3/30	3.39E+02	2.31E+02	3.10E+01	4.41E+01	1.64E+01	5.01E+01	
3/31	3.48E+02	2.64E+02	3.21E+01	4.40E+01	1.65E+01	5.01E+01	