

構内連続ダストモニタ測定記録(2022 年 6 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2022/06

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.52E-06	2.8	100	2.73E-06	1.1	100	2.40E-06	6.7	100	2.33E-06	5.7	100
2	4.36E-06	2.8	100	4.64E-06	1.1	100	4.17E-06	6.7	100	4.22E-06	5.7	100
3	3.93E-06	2.8	100	4.38E-06	1.1	100	3.85E-06	6.7	100	3.90E-06	5.7	100
4	3.40E-06	2.8	100	3.67E-06	1.1	100	3.07E-06	6.7	100	3.12E-06	5.7	100
5	2.52E-06	2.8	100	2.70E-06	1.1	100	2.13E-06	6.7	100	2.20E-06	5.7	100
6	3.51E-07	2.8	100	4.44E-07	1.1	100	3.50E-07	6.7	100	2.87E-07	5.7	100
7	2.49E-07	2.8	100	3.44E-07	1.1	100	2.11E-07	6.7	100	1.43E-07	5.7	100
8	4.69E-07	2.8	100	5.78E-07	1.1	100	*1 4.72E-07	6.6	100	3.77E-07	5.7	100
9	8.79E-07	2.8	100	1.00E-06	1.1	100	7.76E-07	6.6	100	7.08E-07	5.7	100
10	2.40E-06	2.8	100	2.67E-06	1.1	100	2.07E-06	6.6	100	2.15E-06	5.7	100
11	5.35E-06	2.8	100	5.85E-06	1.1	100	4.34E-06	6.6	100	4.50E-06	5.7	100
12	3.54E-06	2.8	100	3.80E-06	1.1	100	3.19E-06	6.6	100	3.26E-06	5.7	100
13	1.13E-06	2.8	100	1.32E-06	1.1	100	1.09E-06	6.6	100	1.04E-06	5.7	100
14	4.51E-07	2.8	100	5.56E-07	1.1	100	3.91E-07	6.6	100	3.59E-07	5.6	100
15	1.80E-06	2.8	100	1.94E-06	1.1	100	1.69E-06	6.6	100	1.59E-06	5.6	100
16	5.05E-06	2.8	100	5.56E-06	1.1	100	4.98E-06	6.6	100	4.64E-06	5.6	100
17	7.05E-06	2.8	100	7.48E-06	1.1	100	6.89E-06	6.6	100	6.42E-06	5.6	100
18	6.56E-06	2.8	100	6.89E-06	1.1	100	6.58E-06	6.6	100	6.01E-06	5.6	100
19	8.40E-06	2.8	100	9.08E-06	1.1	100	7.36E-06	6.6	100	6.88E-06	5.6	100
20	5.52E-06	2.8	100	5.92E-06	1.1	100	5.17E-06	6.6	100	4.70E-06	5.6	100
21	*1 6.25E-06	2.7	100	6.60E-06	1.1	100	6.25E-06	6.6	100	5.76E-06	5.6	100
22	2.77E-06	2.7	100	*1 2.96E-06	1.1	100	2.72E-06	6.6	100	2.52E-06	5.6	100
23	1.14E-06	2.7	100	1.21E-06	1.2	100	1.18E-06	6.6	100	1.10E-06	5.6	100
24	2.24E-06	2.7	100	2.37E-06	1.2	100	1.89E-06	6.6	100	1.75E-06	5.6	100
25	4.21E-06	2.7	100	4.41E-06	1.2	100	3.87E-06	6.6	100	3.60E-06	5.6	100
26	4.58E-06	2.7	100	4.86E-06	1.2	100	4.65E-06	6.6	100	4.21E-06	5.6	100
27	3.49E-06	2.7	100	3.72E-06	1.2	100	3.54E-06	6.6	100	3.19E-06	5.6	100
28	3.03E-06	2.7	100	3.23E-06	1.2	100	3.06E-06	6.6	100	2.78E-06	5.6	100
29	6.81E-06	2.7	100	7.32E-06	1.2	100	6.67E-06	6.6	100	6.11E-06	5.6	100
30	2.71E-06	2.7	100	2.82E-06	1.2	100	2.88E-06	6.6	100	2.57E-06	5.6	100
31												
1ヶ月値	3.44E-06	2.8	100	3.70E-06	1.1	100	3.26E-06	6.6	100	3.08E-06	5.6	100
最大値	2.13E-05	2.8	102	2.39E-05	1.2	102	1.95E-05	6.7	101	1.99E-05	5.7	102
最大値日時	06/19 04:05	06/01 00:01	06/14 08:58	06/19 04:13	06/22 13:16	06/03 20:02	06/19 02:47	06/01 00:01	06/01 00:35	06/12 02:49	06/01 00:01	06/05 00:48
最小値	0.00E+00	2.7	98	0.00E+00	1.1	98	0.00E+00	6.6	98	0.00E+00	5.6	98
最小値日時	06/06 08:14	06/21 10:10	06/01 18:50	06/22 13:16	06/01 00:01	06/01 03:19	06/06 01:17	06/08 09:43	06/14 23:03	06/06 05:42	06/14 10:33	06/02 06:20

*1: ろ紙交換

測定月報

測定日：2022/06

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.19E-06	1.6	100	2.21E-06	6.2	100	2.17E-06	7.0	100	2.27E-06	6.3	100
2	4.00E-06	1.6	100	3.88E-06	6.2	100	3.87E-06	7.0	100	4.00E-06	6.3	100
3	3.68E-06	1.6	100	3.61E-06	6.2	100	3.44E-06	7.0	100	3.54E-06	6.3	100
4	2.94E-06	1.6	100	2.80E-06	6.2	100	2.83E-06	7.0	100	2.86E-06	6.3	100
5	2.09E-06	1.6	100	2.11E-06	6.2	100	1.92E-06	7.0	100	1.97E-06	6.3	100
6	2.25E-07	1.6	100	2.72E-07	6.2	100	3.45E-07	7.0	100	4.27E-07	6.3	100
7	1.05E-07	1.6	100	1.51E-07	6.2	100	2.23E-07	7.0	100	2.99E-07	6.3	100
8	3.28E-07	1.6	100	3.62E-07	6.2	100	3.80E-07	7.0	100	4.72E-07	6.3	100
9	6.64E-07	1.6	100	7.01E-07	6.2	100	6.83E-07	7.0	100	7.67E-07	6.3	100
10	1.99E-06	1.6	100	1.92E-06	6.2	100	1.92E-06	7.0	100	1.99E-06	6.3	100
11	4.10E-06	1.6	100	4.01E-06	6.2	100	3.91E-06	7.0	100	3.90E-06	6.3	100
12	3.01E-06	1.6	100	3.03E-06	6.2	100	3.04E-06	7.0	100	3.07E-06	6.3	100
13	9.59E-07	1.6	100	*1 1.03E-06	6.1	100	*1 1.05E-06	6.9	100	1.06E-06	6.3	100
14	1.93E-07	1.6	100	2.88E-07	6.1	100	3.35E-07	6.9	100	3.77E-07	6.3	100
15	1.64E-06	1.6	100	1.63E-06	6.1	100	1.65E-06	6.9	100	1.62E-06	6.3	100
16	5.10E-06	1.6	100	4.73E-06	6.1	100	5.14E-06	6.9	100	4.97E-06	6.3	100
17	6.75E-06	1.6	100	6.40E-06	6.1	100	6.95E-06	6.9	100	6.48E-06	6.3	100
18	6.92E-06	1.6	100	6.46E-06	6.1	100	6.71E-06	6.9	100	6.35E-06	6.3	100
19	6.69E-06	1.6	100	6.31E-06	6.1	100	6.97E-06	6.9	100	6.50E-06	6.3	100
20	4.55E-06	1.6	100	4.38E-06	6.1	100	4.65E-06	6.9	100	4.39E-06	6.3	100
21	6.63E-06	1.6	100	6.46E-06	6.1	100	6.41E-06	6.9	100	5.97E-06	6.3	100
22	*1 2.50E-06	1.5	100	2.43E-06	6.1	100	2.55E-06	6.9	100	2.41E-06	6.3	100
23	1.05E-06	1.4	100	9.88E-07	6.1	100	1.12E-06	6.9	100	1.07E-06	6.3	100
24	1.32E-06	1.4	100	1.26E-06	6.1	100	1.51E-06	6.9	100	1.45E-06	6.3	100
25	3.49E-06	1.4	100	3.27E-06	6.1	100	3.55E-06	6.9	100	3.32E-06	6.3	100
26	4.27E-06	1.4	100	4.12E-06	6.1	100	4.39E-06	6.9	100	4.16E-06	6.3	100
27	3.97E-06	1.4	100	3.81E-06	6.1	100	3.69E-06	6.9	100	*1 3.51E-06	6.2	100
28	3.14E-06	1.4	100	3.07E-06	6.1	100	3.15E-06	6.9	100	2.87E-06	6.2	100
29	7.24E-06	1.4	100	6.90E-06	6.1	100	7.02E-06	6.9	100	6.24E-06	6.2	100
30	2.67E-06	1.4	100	2.60E-06	6.1	100	2.73E-06	6.9	100	2.47E-06	6.2	100
31												
1ヶ月値	3.15E-06	1.5	100	3.04E-06	6.1	100	3.14E-06	6.9	100	3.03E-06	6.3	100
最大値	1.94E-05	1.6	102	1.91E-05	6.2	102	2.17E-05	7.0	102	1.83E-05	6.3	102
最大値日時	06/19 03:20	06/01 00:01	06/14 07:26	06/12 02:58	06/01 00:01	06/01 21:00	06/19 03:01	06/01 00:01	06/01 05:35	06/12 03:00	06/01 00:01	06/01 00:30
最小値	0.00E+00	1.4	98	0.00E+00	6.1	98	0.00E+00	6.9	97	0.00E+00	6.2	97
最小値日時	06/06 08:24	06/22 13:06	06/02 20:18	06/06 04:55	06/13 09:53	06/01 02:48	06/05 22:05	06/13 09:10	06/03 18:06	06/06 06:45	06/27 11:08	06/29 12:04

*1: ろ紙交換

測定月報

測定日：2022/06

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.29E-06	6.4	100	2.45E-06	5.9	100	2.29E-06	2.8	100	2.33E-06	2.6	100
2	4.06E-06	6.4	100	4.25E-06	5.9	100	3.94E-06	2.8	100	4.00E-06	2.6	100
3	3.71E-06	6.4	100	3.89E-06	5.9	100	3.54E-06	2.8	100	3.61E-06	2.6	100
4	2.98E-06	6.4	100	3.11E-06	5.9	100	2.88E-06	2.8	100	2.98E-06	2.6	100
5	2.05E-06	6.4	100	2.20E-06	5.9	100	2.00E-06	2.8	100	2.14E-06	2.6	100
6	3.22E-07	6.4	100	4.33E-07	5.9	100	3.24E-07	2.8	100	3.58E-07	2.6	100
7	2.01E-07	6.4	100	2.89E-07	5.9	100	2.03E-07	2.8	100	2.38E-07	2.6	100
8	3.87E-07	6.4	100	5.02E-07	5.9	100	3.32E-07	2.8	100	3.74E-07	2.6	100
9	*1 7.64E-07	6.3	100	8.18E-07	5.9	100	6.69E-07	2.8	100	7.12E-07	2.6	100
10	2.26E-06	6.3	100	2.28E-06	5.9	100	1.97E-06	2.8	100	2.10E-06	2.6	100
11	4.45E-06	6.3	100	4.36E-06	5.9	100	4.15E-06	2.8	100	4.37E-06	2.6	100
12	3.33E-06	6.3	100	3.29E-06	5.9	100	2.98E-06	2.8	100	3.11E-06	2.6	100
13	1.13E-06	6.3	100	1.18E-06	5.9	100	9.94E-07	2.8	100	1.02E-06	2.6	100
14	3.21E-07	6.3	100	3.57E-07	5.9	100	2.83E-07	2.8	100	2.99E-07	2.6	100
15	1.69E-06	6.3	100	1.65E-06	5.9	100	1.46E-06	2.8	100	1.54E-06	2.6	100
16	5.42E-06	6.3	100	5.24E-06	5.9	100	4.82E-06	2.8	100	4.92E-06	2.6	100
17	7.31E-06	6.3	100	7.22E-06	5.9	100	6.48E-06	2.8	100	6.93E-06	2.6	100
18	6.97E-06	6.3	100	6.62E-06	5.9	100	5.98E-06	2.8	100	6.42E-06	2.6	100
19	7.49E-06	6.3	100	7.42E-06	5.9	100	6.76E-06	2.8	100	7.07E-06	2.6	100
20	5.14E-06	6.3	100	5.05E-06	5.9	100	4.71E-06	2.8	100	4.81E-06	2.6	100
21	6.53E-06	6.3	100	6.45E-06	5.9	100	5.81E-06	2.8	100	5.99E-06	2.6	100
22	2.68E-06	6.3	100	2.64E-06	5.9	100	2.33E-06	2.8	100	*1 2.43E-06	2.6	100
23	1.13E-06	6.3	100	1.14E-06	5.9	100	1.05E-06	2.8	100	1.08E-06	2.6	100
24	1.78E-06	6.3	100	1.85E-06	5.9	100	1.69E-06	2.8	100	1.70E-06	2.6	100
25	3.96E-06	6.3	100	3.90E-06	5.9	100	3.63E-06	2.8	100	3.73E-06	2.6	100
26	4.77E-06	6.3	100	4.63E-06	5.9	100	4.20E-06	2.8	100	4.23E-06	2.6	100
27	3.82E-06	6.3	100	*1 3.75E-06	5.9	100	*1 3.46E-06	2.9	100	3.37E-06	2.6	100
28	3.27E-06	6.3	100	3.13E-06	5.9	100	2.72E-06	2.9	100	2.91E-06	2.6	100
29	7.13E-06	6.3	100	6.98E-06	5.9	100	6.21E-06	2.9	100	6.50E-06	2.6	100
30	2.95E-06	6.3	100	2.78E-06	5.9	100	2.52E-06	2.9	100	2.65E-06	2.6	100
31												
1ヶ月値	3.34E-06	6.3	100	3.33E-06	5.9	100	3.01E-06	2.8	100	3.13E-06	2.6	100
最大値	2.05E-05	6.4	102	2.05E-05	5.9	102	1.82E-05	2.9	102	1.91E-05	2.6	101
最大値日時	06/19 03:08	06/01 00:01	06/11 01:31	06/19 03:32	06/01 00:01	06/08 02:40	06/19 03:43	06/27 10:43	06/03 21:13	06/19 03:44	06/01 00:01	06/01 00:09
最小値	0.00E+00	6.3	98	0.00E+00	5.9	98	0.00E+00	2.8	98	0.00E+00	2.6	98
最小値日時	06/06 02:57	06/09 10:10	06/02 03:01	06/06 07:13	06/01 00:01	06/01 06:36	06/06 08:38	06/01 00:01	06/01 00:16	06/06 08:51	06/01 00:01	06/02 04:33

*1: ろ紙交換

測定月報

測定日：2022/06

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.27E-06	1.3	100	2.47E-06	0.9	100	2.39E-06	2.4	100	2.44E-06	2.0	100
2	4.09E-06	1.3	100	4.33E-06	0.9	100	4.06E-06	2.4	100	4.16E-06	2.0	100
3	3.71E-06	1.3	100	3.93E-06	0.9	100	3.83E-06	2.4	100	3.88E-06	2.0	100
4	2.94E-06	1.3	100	3.08E-06	0.9	100	3.20E-06	2.4	100	3.26E-06	2.0	100
5	2.07E-06	1.3	100	2.22E-06	0.9	100	2.36E-06	2.4	100	2.51E-06	2.0	100
6	3.95E-07	1.3	100	4.42E-07	0.9	100	3.35E-07	2.4	100	3.29E-07	2.0	100
7	2.76E-07	1.3	100	3.26E-07	0.9	100	2.43E-07	2.4	100	2.39E-07	2.0	100
8	4.29E-07	1.3	100	4.78E-07	0.9	100	4.43E-07	2.4	100	4.39E-07	2.0	100
9	*1 7.86E-07	1.2	100	8.20E-07	0.9	100	8.37E-07	2.4	100	8.30E-07	2.0	100
10	2.04E-06	1.2	100	2.16E-06	0.9	100	2.39E-06	2.4	100	2.42E-06	2.0	100
11	4.30E-06	1.2	100	4.55E-06	0.9	100	5.08E-06	2.4	100	5.19E-06	2.0	100
12	3.04E-06	1.2	100	3.30E-06	0.9	100	3.34E-06	2.4	100	3.39E-06	2.0	100
13	1.11E-06	1.2	100	*1 1.15E-06	1.0	100	1.06E-06	2.4	100	*1 1.14E-06	1.9	100
14	3.90E-07	1.2	100	3.52E-07	1.0	100	4.50E-07	2.4	100	5.40E-07	1.8	100
15	1.55E-06	1.2	100	1.58E-06	0.9	100	1.73E-06	2.4	100	1.77E-06	1.8	100
16	4.85E-06	1.2	100	5.08E-06	0.9	100	5.01E-06	2.4	100	4.94E-06	1.8	100
17	6.77E-06	1.2	100	7.05E-06	0.9	100	7.00E-06	2.4	100	6.90E-06	1.8	100
18	6.16E-06	1.2	100	6.53E-06	0.9	100	6.47E-06	2.4	100	6.32E-06	1.8	100
19	7.18E-06	1.2	100	7.36E-06	0.9	100	8.24E-06	2.4	100	8.21E-06	1.8	100
20	4.78E-06	1.2	100	4.94E-06	0.9	100	5.12E-06	2.4	100	5.25E-06	1.8	100
21	5.92E-06	1.2	100	6.16E-06	0.9	100	6.02E-06	2.4	100	6.13E-06	1.8	100
22	2.46E-06	1.2	100	2.51E-06	0.9	100	*1 2.76E-06	2.4	100	2.76E-06	1.8	100
23	1.07E-06	1.2	100	1.09E-06	0.9	100	1.18E-06	2.3	100	1.19E-06	1.8	100
24	1.79E-06	1.2	100	1.82E-06	0.9	100	2.11E-06	2.3	100	2.11E-06	1.8	100
25	3.70E-06	1.2	100	3.82E-06	0.9	100	4.05E-06	2.3	100	4.06E-06	1.8	100
26	4.19E-06	1.2	100	4.35E-06	0.9	100	4.64E-06	2.3	100	4.55E-06	1.8	100
27	3.53E-06	1.2	100	3.66E-06	0.9	100	3.39E-06	2.3	100	3.44E-06	1.8	100
28	2.89E-06	1.2	100	3.00E-06	0.9	100	3.01E-06	2.3	100	3.02E-06	1.8	100
29	6.36E-06	1.2	100	6.68E-06	0.9	100	6.48E-06	2.3	100	6.49E-06	1.8	100
30	2.65E-06	1.2	100	2.75E-06	0.9	100	2.72E-06	2.3	100	2.69E-06	1.8	100
31												
1ヶ月値	3.12E-06	1.2	100	3.27E-06	0.9	100	3.33E-06	2.4	100	3.35E-06	1.9	100
最大値	1.94E-05	1.3	102	2.01E-05	2.2	102	2.10E-05	2.4	102	2.13E-05	2.0	101
最大値日時	06/19 03:42	06/01 00:01	06/03 01:59	06/19 04:02	06/14 10:11	06/02 02:31	06/19 02:50	06/01 00:01	06/01 14:18	06/19 03:00	06/01 00:01	06/01 00:06
最小値	0.00E+00	1.2	98	0.00E+00	0.9	98	0.00E+00	2.3	98	0.00E+00	1.8	98
最小値日時	06/15 16:42	06/09 10:23	06/01 08:48	06/13 10:38	06/01 00:01	06/01 04:56	06/06 09:29	06/22 12:53	06/01 00:11	06/06 06:31	06/13 10:21	06/04 05:16

*1: ろ紙交換

測定月報

測定日：2022/06

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シーールド中央制御室			A020 シーールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.62E-06	4.9	100	2.70E-06	4.1	100	2.44E-06	2.8	100	2.38E-06	2.4	100
2	4.47E-06	4.9	100	4.78E-06	4.1	100	4.44E-06	2.8	100	4.13E-06	2.4	100
3	4.02E-06	4.9	100	4.13E-06	4.1	100	3.96E-06	2.8	100	3.84E-06	2.4	100
4	3.28E-06	4.9	100	3.43E-06	4.1	100	3.20E-06	2.8	100	3.14E-06	2.4	100
5	2.29E-06	4.9	100	2.37E-06	4.1	100	2.31E-06	2.8	100	2.24E-06	2.4	100
6	4.95E-07	4.9	100	4.43E-07	4.1	100	3.98E-07	2.8	100	3.79E-07	2.4	100
7	3.76E-07	4.9	100	3.21E-07	4.1	100	2.93E-07	2.8	100	2.76E-07	2.4	100
8	5.55E-07	4.9	100	*1 5.52E-07	4.0	100	4.59E-07	2.8	100	4.38E-07	2.4	100
9	9.05E-07	4.9	100	9.15E-07	4.0	100	8.17E-07	2.8	100	*1 7.43E-07	2.5	100
10	2.31E-06	4.9	100	2.38E-06	4.0	100	2.23E-06	2.8	100	2.07E-06	2.5	100
11	4.60E-06	4.9	100	4.73E-06	4.0	100	4.90E-06	2.8	100	4.64E-06	2.5	100
12	3.47E-06	4.9	100	3.60E-06	4.0	100	3.38E-06	2.8	100	3.12E-06	2.5	100
13	1.26E-06	4.9	100	1.28E-06	4.0	100	1.13E-06	2.8	100	1.05E-06	2.5	100
14	4.26E-07	4.9	100	4.04E-07	4.0	100	3.92E-07	2.8	100	3.12E-07	2.5	100
15	1.82E-06	4.9	100	1.92E-06	4.0	100	1.64E-06	2.8	100	1.54E-06	2.5	100
16	5.39E-06	4.9	100	5.63E-06	4.0	100	5.19E-06	2.8	100	5.03E-06	2.5	100
17	7.29E-06	4.9	100	7.57E-06	4.0	100	7.30E-06	2.8	100	6.98E-06	2.5	100
18	7.03E-06	4.9	100	7.51E-06	4.0	100	6.57E-06	2.8	100	6.34E-06	2.5	100
19	7.31E-06	4.9	100	7.74E-06	4.0	100	8.12E-06	2.8	100	7.63E-06	2.5	100
20	5.06E-06	4.9	100	5.26E-06	4.0	100	5.38E-06	2.8	100	5.02E-06	2.5	100
21	6.72E-06	4.9	100	6.86E-06	4.0	100	6.33E-06	2.8	100	6.04E-06	2.5	100
22	2.81E-06	4.9	100	2.83E-06	4.0	100	*1 2.67E-06	2.8	100	2.54E-06	2.5	100
23	1.25E-06	4.9	100	1.26E-06	4.0	100	1.08E-06	2.9	100	1.04E-06	2.5	100
24	1.77E-06	4.9	100	1.81E-06	4.0	100	1.90E-06	2.9	100	1.83E-06	2.5	100
25	4.05E-06	4.9	100	4.02E-06	4.0	100	3.89E-06	2.9	100	3.82E-06	2.5	100
26	4.77E-06	4.9	100	4.92E-06	4.0	100	4.38E-06	2.9	100	4.31E-06	2.5	100
27	*1 3.97E-06	4.9	100	4.17E-06	4.0	100	3.46E-06	2.9	100	3.48E-06	2.5	100
28	3.28E-06	4.9	100	3.41E-06	4.0	100	2.96E-06	2.9	100	2.92E-06	2.5	100
29	7.01E-06	4.9	100	7.60E-06	4.0	100	6.75E-06	2.9	100	6.63E-06	2.5	100
30	3.01E-06	4.9	100	3.13E-06	4.0	100	2.68E-06	2.9	100	2.69E-06	2.5	100
31												
1ヶ月値	3.45E-06	4.9	100	3.59E-06	4.0	100	3.35E-06	2.8	100	3.22E-06	2.5	100
最大値	2.18E-05	4.9	101	2.12E-05	4.1	101	2.22E-05	2.9	101	2.11E-05	2.5	102
最大値日時	06/27 10:09	06/01 00:01	06/01 00:20	06/19 03:29	06/01 00:01	06/01 00:06	06/19 03:32	06/22 13:26	06/01 01:58	06/19 04:02	06/09 10:29	06/04 05:14
最小値	0.00E+00	4.9	99	0.00E+00	4.0	99	0.00E+00	2.8	99	0.00E+00	2.4	98
最小値日時	06/06 09:47	06/01 00:01	06/01 00:17	06/06 06:13	06/08 10:13	06/01 00:01	06/06 10:21	06/01 00:01	06/01 00:13	06/06 09:56	06/01 00:01	06/01 08:05

*1:ろ紙交換

測定月報

測定日：2022/06

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.64E-06	2.1	100	2.39E-06	2.8	100	2.87E-06	11.9	100	2.49E-06	13.5	100
2	4.60E-06	2.1	100	4.23E-06	2.8	100	4.88E-06	11.9	100	4.45E-06	13.5	100
3	4.18E-06	2.1	100	3.86E-06	2.8	100	4.44E-06	11.9	100	3.90E-06	13.5	100
4	3.49E-06	2.1	100	3.20E-06	2.8	100	3.68E-06	11.9	100	3.20E-06	13.5	100
5	2.55E-06	2.1	100	2.30E-06	2.8	100	2.72E-06	11.9	100	2.39E-06	13.5	100
6	3.59E-07	2.1	100	2.95E-07	2.8	100	8.25E-07	11.9	100	4.06E-07	13.5	100
7	2.21E-07	2.1	100	1.66E-07	2.8	100	6.47E-07	11.9	100	2.55E-07	13.5	100
8	*1 4.58E-07	2.1	100	3.89E-07	2.8	100	*1 7.24E-07	12.3	100	5.44E-07	13.5	100
9	8.29E-07	2.2	100	*1 8.63E-07	2.7	100	9.16E-07	12.6	100	8.65E-07	13.5	100
10	2.43E-06	2.2	100	2.45E-06	2.6	100	2.45E-06	12.6	100	2.33E-06	13.5	100
11	5.21E-06	2.2	100	5.02E-06	2.6	100	4.89E-06	12.6	100	4.67E-06	13.5	100
12	3.47E-06	2.2	100	3.40E-06	2.6	100	3.59E-06	12.6	100	3.37E-06	13.5	100
13	1.17E-06	2.2	100	1.19E-06	2.6	100	1.26E-06	12.6	100	1.23E-06	13.5	100
14	3.75E-07	2.2	100	4.78E-07	2.6	100	4.53E-07	12.6	100	4.90E-07	13.5	100
15	1.76E-06	2.2	100	1.75E-06	2.6	100	1.84E-06	12.6	100	1.78E-06	13.5	100
16	5.46E-06	2.2	100	5.24E-06	2.6	100	5.85E-06	12.6	100	5.57E-06	13.5	100
17	7.61E-06	2.2	100	7.09E-06	2.6	100	7.95E-06	12.6	100	7.44E-06	13.5	100
18	6.99E-06	2.2	100	6.69E-06	2.6	100	7.68E-06	12.6	100	7.10E-06	13.5	100
19	8.58E-06	2.2	100	8.15E-06	2.6	100	8.09E-06	12.6	100	7.57E-06	13.5	100
20	5.66E-06	2.2	100	5.41E-06	2.6	100	5.56E-06	12.6	100	5.20E-06	13.5	100
21	6.54E-06	2.2	100	6.34E-06	2.6	100	7.41E-06	12.6	100	7.02E-06	13.5	100
22	2.78E-06	2.2	100	2.78E-06	2.6	100	3.02E-06	12.6	100	2.85E-06	13.5	100
23	1.14E-06	2.2	100	1.22E-06	2.6	100	1.34E-06	12.6	100	1.23E-06	13.5	100
24	2.15E-06	2.2	100	2.15E-06	2.6	100	1.86E-06	12.6	100	1.75E-06	13.5	100
25	4.30E-06	2.2	100	4.18E-06	2.6	100	4.41E-06	12.6	100	4.19E-06	13.5	100
26	4.85E-06	2.2	100	4.70E-06	2.6	100	5.10E-06	12.6	100	4.71E-06	13.5	100
27	3.64E-06	2.2	100	3.66E-06	2.6	100	4.27E-06	12.6	100	*1 3.99E-06	13.4	100
28	2.92E-06	2.9	100	3.13E-06	2.6	100	3.85E-06	12.6	100	3.48E-06	13.4	100
29	6.03E-06	3.4	100	6.88E-06	2.6	100	8.36E-06	12.6	100	7.60E-06	13.4	100
30	2.52E-06	3.4	100	2.88E-06	2.6	100	3.19E-06	12.6	100	2.91E-06	13.4	100
31												
1ヶ月値	3.50E-06	2.3	100	3.42E-06	2.7	100	3.81E-06	12.4	100	3.50E-06	13.5	100
最大値	2.15E-05	3.4	102	2.12E-05	2.8	102	2.30E-05	12.6	102	2.06E-05	13.5	101
最大値日時	06/08 12:15	06/28 11:21	06/01 04:52	06/19 03:09	06/01 00:01	06/01 02:36	06/19 03:23	06/08 10:37	06/04 02:44	06/21 04:35	06/01 00:01	06/01 00:03
最小値	0.00E+00	2.1	98	0.00E+00	2.6	98	0.00E+00	11.9	98	0.00E+00	13.4	99
最小値日時	06/06 09:59	06/01 00:01	06/14 06:53	06/06 09:04	06/09 10:16	06/05 08:54	06/06 08:39	06/01 00:01	06/01 00:46	06/05 11:17	06/27 10:32	06/01 00:04

*1:ろ紙交換

測定月報

測定日：2022/06

(7/8)

日	モニタ											
	A027			A028			A029			A030		
	1号機海側2、5m盤			1号機海側2、5m盤			3号機海側2、5m盤			3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.12E-06	2.5	100	2.16E-06	4.3	100	2.16E-06	2.4	100	2.27E-06	2.3	100
2	3.98E-06	2.5	100	4.09E-06	4.3	100	3.88E-06	2.4	100	4.17E-06	2.3	100
3	3.41E-06	2.5	100	3.46E-06	4.3	100	3.41E-06	2.4	100	3.63E-06	2.3	100
4	2.82E-06	2.5	100	2.84E-06	4.3	100	2.72E-06	2.4	100	2.87E-06	2.3	100
5	1.87E-06	2.5	100	1.89E-06	4.3	100	1.80E-06	2.4	100	1.93E-06	2.3	100
6	2.72E-07	2.5	100	2.92E-07	4.3	100	3.34E-07	2.4	100	3.53E-07	2.3	100
7	1.48E-07	2.5	100	1.53E-07	4.3	100	2.15E-07	2.4	100	2.42E-07	2.3	100
8	3.05E-07	2.5	100	3.26E-07	4.3	100	*1 4.24E-07	2.3	100	3.81E-07	2.3	100
9	6.63E-07	2.5	100	6.68E-07	4.3	100	7.44E-07	2.2	100	7.43E-07	2.3	100
10	1.89E-06	2.5	100	1.88E-06	4.3	100	1.88E-06	2.2	100	1.99E-06	2.3	100
11	3.67E-06	2.5	100	3.63E-06	4.3	100	3.45E-06	2.2	100	3.79E-06	2.3	100
12	2.93E-06	2.5	100	2.94E-06	4.3	100	2.94E-06	2.2	100	3.09E-06	2.3	100
13	9.75E-07	2.5	100	9.86E-07	4.3	100	1.07E-06	2.2	100	*1 1.10E-06	2.2	100
14	1.82E-07	2.5	100	2.05E-07	4.3	100	3.30E-07	2.2	100	2.60E-07	2.2	100
15	1.50E-06	2.5	100	1.47E-06	4.3	100	1.56E-06	2.2	100	1.54E-06	2.2	100
16	4.86E-06	2.5	100	4.90E-06	4.3	100	4.92E-06	2.2	100	4.89E-06	2.2	100
17	6.78E-06	2.5	100	6.65E-06	4.3	100	6.60E-06	2.2	100	6.91E-06	2.2	100
18	6.63E-06	2.5	100	6.53E-06	4.3	100	6.61E-06	2.2	100	6.74E-06	2.2	100
19	6.34E-06	2.5	100	6.40E-06	4.3	100	6.42E-06	2.2	100	6.51E-06	2.2	100
20	4.19E-06	2.5	100	4.12E-06	4.3	100	4.01E-06	2.1	100	4.24E-06	2.2	100
21	*1 6.47E-06	2.4	100	*1 6.36E-06	4.0	100	6.14E-06	2.0	100	6.29E-06	2.2	100
22	2.29E-06	2.4	100	2.40E-06	3.8	100	2.31E-06	2.0	100	2.37E-06	2.2	100
23	9.75E-07	2.4	100	1.13E-06	3.8	100	9.77E-07	2.0	100	1.03E-06	2.2	100
24	1.14E-06	2.4	100	1.28E-06	3.8	100	1.11E-06	2.0	100	1.19E-06	2.2	100
25	3.27E-06	2.4	100	3.46E-06	3.8	100	3.28E-06	2.0	100	3.46E-06	2.2	100
26	3.92E-06	2.4	100	3.98E-06	3.8	100	3.89E-06	2.0	100	4.04E-06	2.2	100
27	3.92E-06	2.4	100	3.94E-06	3.8	100	3.93E-06	2.0	100	4.11E-06	2.2	100
28	2.93E-06	2.4	100	3.01E-06	3.8	100	2.89E-06	2.0	100	3.04E-06	2.2	100
29	7.17E-06	2.4	100	7.11E-06	3.8	100	6.83E-06	2.0	100	7.22E-06	2.2	100
30	2.49E-06	2.4	100	2.52E-06	3.8	100	2.35E-06	2.0	100	2.51E-06	2.2	100
31												
1ヶ月値	3.00E-06	2.5	100	3.02E-06	4.1	100	2.97E-06	2.2	100	3.10E-06	2.2	100
最大値	1.93E-05	2.5	103	1.91E-05	4.3	102	3.08E-05	2.4	103	1.90E-05	2.3	102
最大値日時	06/19 03:23	06/01 00:01	06/02 01:23	06/19 03:48	06/01 00:01	06/10 03:08	06/08 11:07	06/01 00:01	06/09 21:01	06/19 03:53	06/01 00:01	06/01 03:24
最小値	0.00E+00	2.4	97	0.00E+00	3.8	98	0.00E+00	2.0	96	0.00E+00	2.2	98
最小値日時	06/06 06:13	06/21 09:06	06/01 14:02	06/06 01:15	06/21 09:21	06/05 08:38	06/06 09:14	06/20 10:37	06/06 13:51	06/06 08:29	06/13 09:01	06/02 21:34

*1: ろ紙交換

測定月報

測定日：2022/06

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.34E-06	8.9	100	2.42E-06	6.9	100						
2	4.11E-06	8.9	100	4.25E-06	6.9	100						
3	3.69E-06	8.9	100	3.87E-06	6.9	100						
4	2.97E-06	8.9	100	3.20E-06	6.9	100						
5	2.14E-06	8.9	100	2.26E-06	6.9	100						
6	2.89E-07	8.9	100	2.57E-07	6.9	100						
7	1.19E-07	8.9	100	1.03E-07	6.9	100						
8	4.11E-07	8.9	100	4.47E-07	6.9	100						
9	6.90E-07	8.9	100	7.24E-07	6.9	100						
10	2.14E-06	8.9	100	2.18E-06	6.9	100						
11	4.30E-06	8.9	100	4.56E-06	6.9	100						
12	3.09E-06	8.9	100	3.18E-06	6.9	100						
13	1.09E-06	8.9	100	1.17E-06	6.9	100						
14	3.34E-07	8.9	100	3.91E-07	6.9	100						
15	1.53E-06	8.9	100	1.66E-06	6.9	100						
16	4.94E-06	8.9	100	5.27E-06	6.9	100						
17	7.00E-06	8.9	100	7.51E-06	6.9	100						
18	6.72E-06	8.9	100	7.09E-06	6.9	100						
19	7.16E-06	8.9	100	7.57E-06	6.9	100						
20	4.50E-06	8.9	100	4.80E-06	6.9	100						
21	*1 6.10E-06	8.8	100	6.30E-06	6.9	100						
22	2.43E-06	8.8	100	2.58E-06	6.9	100						
23	1.09E-06	8.8	100	1.14E-06	6.9	100						
24	1.53E-06	8.8	100	1.63E-06	6.9	100						
25	3.63E-06	8.8	100	3.83E-06	6.9	100						
26	4.05E-06	8.8	100	4.28E-06	6.9	100						
27	3.58E-06	8.8	100	*1 3.90E-06	6.9	100						
28	3.11E-06	8.8	100	3.17E-06	6.9	100						
29	7.12E-06	8.8	100	7.33E-06	6.9	100						
30	2.70E-06	8.8	100	2.85E-06	6.9	100						
31												
1ヶ月値	3.16E-06	8.9	100	3.33E-06	6.9	100						
最大値	2.08E-05	8.9	103	2.12E-05	6.9	101						
最大値日時	06/19 03:55	06/01 00:01	06/04 07:21	06/19 04:11	06/01 00:01	06/01 00:14						
最小値	0.00E+00	8.8	97	0.00E+00	6.9	99						
最小値日時	06/05 11:20	06/21 08:41	06/04 01:09	06/06 06:50	06/01 00:01	06/01 00:04						

*1: ろ紙交換