

構内連続ダストモニタ測定記録(2024 年 11 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2024/11

(1/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A001 正門警備所 | | | A002 正門警備所 | | | A003 免震重要棟 | | | A004 免震重要棟 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.60E-06 | 0.9 | 100 | 4.01E-06 | 0.8 | 100 | 3.69E-06 | 1.6 | 100 | 3.73E-06 | 1.7 | 100 |
| 2 | 5.31E-06 | 0.9 | 100 | 6.26E-06 | 0.8 | 100 | 5.71E-06 | 1.6 | 100 | 5.85E-06 | 1.7 | 100 |
| 3 | 4.37E-06 | 0.9 | 100 | 4.87E-06 | 0.8 | 100 | 4.57E-06 | 1.6 | 100 | 4.82E-06 | 1.7 | 100 |
| 4 | 4.76E-06 | 0.9 | 100 | 5.23E-06 | 0.8 | 100 | 4.73E-06 | 1.6 | 100 | 4.87E-06 | 1.7 | 100 |
| 5 | 3.89E-06 | 0.9 | 100 | 4.30E-06 | 0.8 | 100 | *1 4.26E-06 | 1.6 | 100 | 4.29E-06 | 1.7 | 100 |
| 6 | 3.41E-06 | 0.9 | 100 | 3.75E-06 | 0.8 | 100 | 3.54E-06 | 1.6 | 100 | 3.59E-06 | 1.7 | 100 |
| 7 | 1.78E-06 | 0.9 | 100 | 1.98E-06 | 0.8 | 100 | 1.92E-06 | 1.6 | 100 | 1.96E-06 | 1.7 | 100 |
| 8 | 2.80E-06 | 0.9 | 100 | 3.04E-06 | 0.8 | 100 | 2.91E-06 | 1.6 | 100 | 2.99E-06 | 1.7 | 100 |
| 9 | 3.71E-06 | 0.9 | 100 | 4.09E-06 | 0.8 | 100 | 3.79E-06 | 1.6 | 100 | 3.86E-06 | 1.7 | 100 |
| 10 | 6.06E-06 | 0.9 | 100 | 6.67E-06 | 0.8 | 100 | 5.96E-06 | 1.6 | 100 | 6.08E-06 | 1.7 | 100 |
| 11 | 4.88E-06 | 0.9 | 100 | 5.42E-06 | 0.8 | 100 | 5.07E-06 | 1.6 | 100 | 5.20E-06 | 1.7 | 100 |
| 12 | 4.95E-06 | 0.9 | 100 | 5.45E-06 | 0.8 | 100 | 4.92E-06 | 1.6 | 100 | 5.08E-06 | 1.7 | 100 |
| 13 | *1 4.83E-06 | 0.9 | 100 | 5.24E-06 | 0.8 | 100 | 5.00E-06 | 1.6 | 100 | *1 5.15E-06 | 1.8 | 100 |
| 14 | 5.44E-06 | 0.9 | 100 | 5.97E-06 | 0.8 | 100 | 5.43E-06 | 1.6 | 100 | 5.42E-06 | 1.8 | 100 |
| 15 | 4.59E-06 | 0.9 | 100 | 5.12E-06 | 0.8 | 100 | 4.84E-06 | 1.6 | 100 | 4.98E-06 | 1.8 | 100 |
| 16 | 4.03E-06 | 0.9 | 100 | 4.46E-06 | 0.8 | 100 | 3.99E-06 | 1.6 | 100 | 4.06E-06 | 1.8 | 100 |
| 17 | 3.36E-06 | 0.9 | 100 | 3.78E-06 | 0.8 | 100 | 3.17E-06 | 1.6 | 100 | 3.14E-06 | 1.8 | 100 |
| 18 | 2.05E-06 | 0.9 | 100 | 2.27E-06 | 0.8 | 100 | 2.09E-06 | 1.6 | 100 | 2.04E-06 | 1.8 | 100 |
| 19 | 1.64E-06 | 0.9 | 100 | *1 1.76E-06 | 0.9 | 100 | 1.65E-06 | 1.6 | 100 | 1.60E-06 | 1.8 | 100 |
| 20 | 3.31E-06 | 0.9 | 100 | 3.50E-06 | 0.9 | 100 | 3.17E-06 | 1.6 | 100 | 3.18E-06 | 1.8 | 100 |
| 21 | 4.90E-06 | 0.9 | 100 | 5.30E-06 | 0.9 | 100 | 5.07E-06 | 1.6 | 100 | 5.06E-06 | 1.8 | 100 |
| 22 | 2.64E-06 | 0.9 | 100 | 2.82E-06 | 0.9 | 100 | 2.77E-06 | 1.6 | 100 | 2.77E-06 | 1.8 | 100 |
| 23 | 2.68E-06 | 0.9 | 100 | 2.87E-06 | 0.9 | 100 | 2.84E-06 | 1.6 | 100 | 2.87E-06 | 1.8 | 100 |
| 24 | 3.95E-06 | 0.9 | 100 | 4.24E-06 | 0.9 | 100 | 4.08E-06 | 1.6 | 100 | 4.07E-06 | 1.8 | 100 |
| 25 | 2.92E-06 | 0.9 | 100 | 3.12E-06 | 0.9 | 100 | 2.89E-06 | 1.6 | 100 | 2.83E-06 | 1.8 | 100 |
| 26 | 2.67E-06 | 0.9 | 100 | 2.85E-06 | 0.9 | 100 | 2.63E-06 | 1.6 | 100 | 2.59E-06 | 1.8 | 100 |
| 27 | 2.08E-06 | 0.9 | 100 | 2.22E-06 | 0.9 | 100 | 2.32E-06 | 1.6 | 100 | 2.34E-06 | 1.8 | 100 |
| 28 | 1.57E-06 | 0.9 | 100 | 1.66E-06 | 0.9 | 100 | 1.69E-06 | 1.6 | 100 | 1.67E-06 | 1.8 | 100 |
| 29 | 3.20E-06 | 0.9 | 100 | 3.42E-06 | 0.9 | 100 | 3.40E-06 | 1.6 | 100 | 3.41E-06 | 1.8 | 100 |
| 30 | 2.29E-06 | 0.9 | 100 | 2.42E-06 | 0.9 | 100 | 2.32E-06 | 1.6 | 100 | 2.35E-06 | 1.8 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.59E-06 | 0.9 | 100 | 3.94E-06 | 0.8 | 100 | 3.68E-06 | 1.6 | 100 | 3.73E-06 | 1.8 | 100 |
| 最大値 | 1.31E-05 | 0.9 | 102 | 1.43E-05 | 0.9 | 102 | 1.16E-05 | 1.6 | 102 | 1.18E-05 | 1.8 | 102 |
| 最大値日時 | 11/21 00:11 | 11/01 00:01 | 11/01 01:06 | 11/02 05:49 | 11/19 11:08 | 11/06 20:29 | 11/02 06:25 | 11/01 00:01 | 11/02 23:23 | 11/02 06:12 | 11/13 10:10 | 11/14 23:58 |
| 最小値 | 0.00E+00 | 0.9 | 97 | 0.00E+00 | 0.8 | 17 | 0.00E+00 | 1.6 | 98 | 0.00E+00 | 1.7 | 98 |
| 最小値日時 | 11/25 10:12 | 11/01 00:01 | 11/03 17:23 | 11/03 01:03 | 11/01 00:01 | 11/03 01:02 | 11/25 13:45 | 11/01 00:01 | 11/01 15:46 | 11/13 10:10 | 11/01 00:01 | 11/01 05:56 |

*1: ろ紙交換

測定月報

測定日：2024/11

(2/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A005 5/6号警備所前 | | | A006 5/6号警備所前 | | | A007 1号北側法面上(旧厚生棟) | | | A008 1号北側法面上(旧厚生棟) | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.40E-06 | 1.1 | 100 | 3.44E-06 | 1.1 | 100 | 3.65E-06 | 5.9 | 100 | 3.61E-06 | 6.2 | 100 |
| 2 | 5.32E-06 | 1.1 | 100 | 5.43E-06 | 1.1 | 100 | 5.53E-06 | 5.9 | 100 | 5.53E-06 | 6.2 | 100 |
| 3 | 4.45E-06 | 1.1 | 100 | 4.47E-06 | 1.1 | 100 | 4.56E-06 | 5.9 | 100 | 4.55E-06 | 6.2 | 100 |
| 4 | 4.56E-06 | 1.1 | 100 | 4.63E-06 | 1.1 | 100 | 4.80E-06 | 5.9 | 100 | 4.80E-06 | 6.2 | 100 |
| 5 | *1 3.93E-06 | 1.2 | 100 | 3.97E-06 | 1.1 | 100 | 4.05E-06 | 5.9 | 100 | 4.05E-06 | 6.2 | 100 |
| 6 | 3.38E-06 | 1.2 | 100 | 3.53E-06 | 1.1 | 100 | 3.52E-06 | 5.9 | 100 | 3.50E-06 | 6.2 | 100 |
| 7 | 1.78E-06 | 1.2 | 100 | 1.82E-06 | 1.1 | 100 | 1.88E-06 | 5.9 | 100 | 1.83E-06 | 6.2 | 100 |
| 8 | 2.52E-06 | 1.2 | 100 | 2.59E-06 | 1.1 | 100 | 2.85E-06 | 5.9 | 100 | 2.77E-06 | 6.2 | 100 |
| 9 | 3.40E-06 | 1.2 | 100 | 3.50E-06 | 1.1 | 100 | 3.64E-06 | 5.9 | 100 | 3.64E-06 | 6.2 | 100 |
| 10 | 5.19E-06 | 1.2 | 100 | 5.34E-06 | 1.1 | 100 | 5.71E-06 | 5.9 | 100 | 5.72E-06 | 6.2 | 100 |
| 11 | 4.48E-06 | 1.2 | 100 | 4.65E-06 | 1.1 | 100 | 4.90E-06 | 5.9 | 100 | 4.84E-06 | 6.2 | 100 |
| 12 | 4.41E-06 | 1.2 | 100 | 4.60E-06 | 1.1 | 100 | 4.84E-06 | 5.9 | 100 | 4.81E-06 | 6.2 | 100 |
| 13 | 4.64E-06 | 1.2 | 100 | 4.80E-06 | 1.1 | 100 | 4.86E-06 | 5.9 | 100 | *1 4.88E-06 | 6.1 | 100 |
| 14 | 4.88E-06 | 1.2 | 100 | 5.08E-06 | 1.1 | 100 | 5.27E-06 | 5.9 | 100 | 5.28E-06 | 6.1 | 100 |
| 15 | 4.47E-06 | 1.2 | 100 | 4.62E-06 | 1.1 | 100 | 4.70E-06 | 5.9 | 100 | 4.68E-06 | 6.1 | 100 |
| 16 | 3.46E-06 | 1.2 | 100 | 3.60E-06 | 1.1 | 100 | 3.94E-06 | 5.9 | 100 | 3.95E-06 | 6.1 | 100 |
| 17 | 2.71E-06 | 1.2 | 100 | 2.80E-06 | 1.1 | 100 | 3.12E-06 | 5.9 | 100 | 3.11E-06 | 6.1 | 100 |
| 18 | 2.02E-06 | 1.2 | 100 | 2.03E-06 | 1.1 | 100 | 2.07E-06 | 5.9 | 100 | 2.07E-06 | 6.1 | 100 |
| 19 | 1.49E-06 | 1.2 | 100 | *1 1.53E-06 | 1.1 | 100 | 1.59E-06 | 5.9 | 100 | 1.58E-06 | 6.1 | 100 |
| 20 | 3.04E-06 | 1.2 | 100 | 3.10E-06 | 1.1 | 100 | 3.03E-06 | 5.9 | 100 | 3.03E-06 | 6.1 | 100 |
| 21 | 4.66E-06 | 1.2 | 100 | 4.78E-06 | 1.1 | 100 | 4.87E-06 | 5.9 | 100 | 4.98E-06 | 6.1 | 100 |
| 22 | 2.63E-06 | 1.2 | 100 | 2.66E-06 | 1.1 | 100 | 2.72E-06 | 5.9 | 100 | 2.72E-06 | 6.1 | 100 |
| 23 | 2.75E-06 | 1.2 | 100 | 2.77E-06 | 1.1 | 100 | 2.83E-06 | 5.9 | 100 | 2.80E-06 | 6.1 | 100 |
| 24 | 3.76E-06 | 1.2 | 100 | 3.86E-06 | 1.1 | 100 | 4.09E-06 | 5.9 | 100 | 4.10E-06 | 6.1 | 100 |
| 25 | 2.56E-06 | 1.2 | 100 | 2.61E-06 | 1.1 | 100 | *1 2.75E-06 | 5.9 | 100 | 2.80E-06 | 6.1 | 100 |
| 26 | 2.29E-06 | 1.2 | 100 | 2.31E-06 | 1.1 | 100 | 2.42E-06 | 5.9 | 100 | 2.55E-06 | 6.1 | 100 |
| 27 | 2.09E-06 | 1.2 | 100 | 2.13E-06 | 1.1 | 100 | 2.18E-06 | 5.9 | 100 | 2.26E-06 | 6.1 | 100 |
| 28 | 1.73E-06 | 1.2 | 100 | 1.73E-06 | 1.1 | 100 | 1.58E-06 | 5.9 | 100 | 1.66E-06 | 6.1 | 100 |
| 29 | 3.26E-06 | 1.2 | 100 | 3.30E-06 | 1.1 | 100 | 3.25E-06 | 5.9 | 100 | 3.40E-06 | 6.1 | 100 |
| 30 | 2.23E-06 | 1.2 | 100 | 2.29E-06 | 1.1 | 100 | 2.21E-06 | 5.9 | 100 | 2.29E-06 | 6.1 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.38E-06 | 1.2 | 100 | 3.47E-06 | 1.1 | 100 | 3.58E-06 | 5.9 | 100 | 3.59E-06 | 6.1 | 100 |
| 最大値 | 1.70E-05 | 1.2 | 102 | 1.15E-05 | 1.1 | 102 | 1.16E-05 | 5.9 | 102 | 1.22E-05 | 6.2 | 102 |
| 最大値日時 | 11/05 11:13 | 11/05 11:13 | 11/01 09:00 | 11/02 06:44 | 11/01 00:01 | 11/01 06:36 | 11/21 00:15 | 11/01 00:01 | 11/01 18:27 | 11/02 06:16 | 11/01 00:01 | 11/06 14:16 |
| 最小値 | 0.00E+00 | 1.1 | 97 | 0.00E+00 | 1.1 | 98 | 0.00E+00 | 5.9 | 98 | 0.00E+00 | 6.1 | 98 |
| 最小値日時 | 11/25 14:59 | 11/01 00:01 | 11/02 18:34 | 11/19 10:16 | 11/01 00:01 | 11/01 00:42 | 11/03 05:48 | 11/01 00:01 | 11/01 14:21 | 11/13 11:36 | 11/13 11:36 | 11/03 03:09 |

*1: ろ紙交換

測定月報

測定日：2024/11

(3/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A009 | | | A010 | | | A011 | | | A012 | | |
| | 1/2号西側法面上 | | | 1/2号西側法面上 | | | 3/4号西側法面上 | | | 3/4号西側法面上 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.47E-06 | 3.7 | 100 | 3.41E-06 | 5.2 | 100 | 3.59E-06 | 2.1 | 100 | 3.46E-06 | 3.7 | 100 |
| 2 | 5.63E-06 | 3.7 | 100 | 5.48E-06 | 5.2 | 100 | 5.74E-06 | 2.1 | 100 | 5.62E-06 | 3.7 | 100 |
| 3 | 4.61E-06 | 3.7 | 100 | 4.59E-06 | 5.2 | 100 | 4.77E-06 | 2.1 | 100 | 4.55E-06 | 3.7 | 100 |
| 4 | 4.79E-06 | 3.7 | 100 | 4.79E-06 | 5.2 | 100 | 4.98E-06 | 2.1 | 100 | 4.78E-06 | 3.7 | 100 |
| 5 | 4.11E-06 | 3.7 | 100 | *1 4.09E-06 | 5.3 | 100 | 4.22E-06 | 2.1 | 100 | 4.08E-06 | 3.7 | 100 |
| 6 | 3.55E-06 | 3.7 | 100 | 3.41E-06 | 5.3 | 100 | 3.64E-06 | 2.1 | 100 | 3.43E-06 | 3.7 | 100 |
| 7 | 1.89E-06 | 3.7 | 100 | 1.83E-06 | 5.3 | 100 | 1.82E-06 | 2.1 | 100 | 1.77E-06 | 3.7 | 100 |
| 8 | 2.84E-06 | 3.7 | 100 | 2.74E-06 | 5.3 | 100 | 2.83E-06 | 2.1 | 100 | 2.73E-06 | 3.7 | 100 |
| 9 | 3.67E-06 | 3.7 | 100 | 3.54E-06 | 5.3 | 100 | 3.77E-06 | 2.1 | 100 | 3.62E-06 | 3.7 | 100 |
| 10 | 5.57E-06 | 3.7 | 100 | 5.45E-06 | 5.3 | 100 | 6.03E-06 | 2.1 | 100 | 5.74E-06 | 3.7 | 100 |
| 11 | 4.78E-06 | 3.7 | 100 | 4.63E-06 | 5.3 | 100 | 5.00E-06 | 2.1 | 100 | 4.79E-06 | 3.7 | 100 |
| 12 | 4.95E-06 | 3.7 | 100 | 4.73E-06 | 5.3 | 100 | 5.28E-06 | 2.5 | 100 | 4.92E-06 | 3.7 | 100 |
| 13 | *1 4.97E-06 | 3.7 | 100 | 4.79E-06 | 5.3 | 100 | 5.18E-06 | 2.8 | 100 | 4.87E-06 | 3.7 | 100 |
| 14 | 5.07E-06 | 3.7 | 100 | 5.10E-06 | 5.3 | 100 | 5.56E-06 | 2.8 | 100 | 5.18E-06 | 3.7 | 100 |
| 15 | 4.45E-06 | 3.7 | 100 | 4.49E-06 | 5.3 | 100 | 4.95E-06 | 2.8 | 100 | 4.55E-06 | 3.7 | 100 |
| 16 | 3.86E-06 | 3.7 | 100 | 3.88E-06 | 5.3 | 100 | 4.16E-06 | 2.8 | 100 | 3.88E-06 | 3.7 | 100 |
| 17 | 2.90E-06 | 3.7 | 100 | 2.90E-06 | 5.3 | 100 | 3.39E-06 | 2.8 | 100 | 3.13E-06 | 3.7 | 100 |
| 18 | 2.02E-06 | 3.7 | 100 | 2.07E-06 | 5.3 | 100 | 2.14E-06 | 2.8 | 100 | 1.97E-06 | 3.7 | 100 |
| 19 | 1.61E-06 | 3.7 | 100 | 1.57E-06 | 5.3 | 100 | 1.63E-06 | 2.8 | 100 | 1.48E-06 | 3.7 | 100 |
| 20 | 2.99E-06 | 3.7 | 100 | 3.00E-06 | 5.3 | 100 | 3.23E-06 | 2.8 | 100 | 2.90E-06 | 3.7 | 100 |
| 21 | 4.78E-06 | 3.7 | 100 | 4.90E-06 | 5.3 | 100 | 5.26E-06 | 2.8 | 100 | 4.73E-06 | 3.7 | 100 |
| 22 | 2.68E-06 | 3.7 | 100 | 2.67E-06 | 5.3 | 100 | 2.87E-06 | 2.8 | 100 | 2.55E-06 | 3.7 | 100 |
| 23 | 2.80E-06 | 3.7 | 100 | 2.80E-06 | 5.3 | 100 | 3.00E-06 | 2.8 | 100 | 2.68E-06 | 3.7 | 100 |
| 24 | 3.94E-06 | 3.7 | 100 | 3.99E-06 | 5.3 | 100 | 4.25E-06 | 2.8 | 100 | 3.82E-06 | 3.7 | 100 |
| 25 | 2.77E-06 | 3.7 | 100 | 2.76E-06 | 5.3 | 100 | 2.95E-06 | 2.8 | 100 | *1 2.64E-06 | 3.7 | 100 |
| 26 | 2.47E-06 | 3.7 | 100 | 2.49E-06 | 5.3 | 100 | 2.72E-06 | 2.8 | 100 | 2.33E-06 | 3.7 | 100 |
| 27 | 2.22E-06 | 3.7 | 100 | 2.21E-06 | 5.3 | 100 | 2.27E-06 | 2.8 | 100 | 2.05E-06 | 3.7 | 100 |
| 28 | 1.65E-06 | 3.7 | 100 | 1.65E-06 | 5.3 | 100 | 1.70E-06 | 2.8 | 100 | 1.49E-06 | 3.7 | 100 |
| 29 | 3.34E-06 | 3.7 | 100 | 3.37E-06 | 5.3 | 100 | 3.54E-06 | 2.8 | 100 | 3.11E-06 | 3.7 | 100 |
| 30 | 2.26E-06 | 3.7 | 100 | 2.30E-06 | 5.3 | 100 | 2.43E-06 | 2.8 | 100 | 2.16E-06 | 3.7 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.55E-06 | 3.7 | 100 | 3.52E-06 | 5.3 | 100 | 3.76E-06 | 2.5 | 100 | 3.50E-06 | 3.7 | 100 |
| 最大値 | 1.19E-05 | 3.7 | 102 | 1.80E-05 | 5.3 | 102 | 1.31E-05 | 2.8 | 102 | 1.19E-05 | 3.7 | 102 |
| 最大値日時 | 11/02 06:19 | 11/01 00:01 | 11/01 04:12 | 11/05 11:32 | 11/05 11:32 | 11/07 05:11 | 11/21 00:14 | 11/12 10:46 | 11/01 08:43 | 11/02 05:59 | 11/01 00:01 | 11/19 01:40 |
| 最小値 | 0.00E+00 | 3.7 | 97 | 0.00E+00 | 5.2 | 98 | 0.00E+00 | 2.1 | 98 | 0.00E+00 | 3.7 | 98 |
| 最小値日時 | 11/25 11:20 | 11/01 00:01 | 11/18 02:56 | 11/25 11:38 | 11/01 00:01 | 11/04 07:28 | 11/12 10:46 | 11/01 00:01 | 11/01 00:49 | 11/25 10:24 | 11/01 00:01 | 11/08 09:05 |

*1: ろ紙交換

測定月報

測定日：2024/11

(4/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A013 4号南側法面上[3号南側] | | | A014 4号南側法面上[3号南側] | | | A015 登録C休憩所 | | | A016 登録C休憩所 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.29E-06 | 0.9 | 100 | 3.61E-06 | 5.5 | 100 | 3.55E-06 | 2.2 | 100 | 3.96E-06 | 1.3 | 100 |
| 2 | 5.48E-06 | 0.9 | 100 | 5.89E-06 | 5.5 | 100 | 5.48E-06 | 2.2 | 100 | 6.04E-06 | 1.3 | 100 |
| 3 | 4.41E-06 | 0.9 | 100 | 4.75E-06 | 5.5 | 100 | 4.21E-06 | 2.2 | 100 | 4.67E-06 | 1.3 | 100 |
| 4 | 4.60E-06 | 0.9 | 100 | 4.97E-06 | 5.5 | 100 | 4.54E-06 | 2.2 | 100 | 4.96E-06 | 1.3 | 100 |
| 5 | *1 3.97E-06 | 0.8 | 100 | 4.29E-06 | 5.5 | 100 | 3.76E-06 | 2.2 | 100 | 4.17E-06 | 1.3 | 100 |
| 6 | 3.30E-06 | 0.8 | 100 | 3.61E-06 | 5.5 | 100 | 3.31E-06 | 2.2 | 100 | 3.72E-06 | 1.3 | 100 |
| 7 | 1.74E-06 | 0.8 | 100 | 1.89E-06 | 5.5 | 100 | 1.71E-06 | 2.2 | 100 | 1.95E-06 | 1.3 | 100 |
| 8 | 2.58E-06 | 0.8 | 100 | 2.83E-06 | 5.5 | 100 | 2.78E-06 | 2.2 | 100 | 3.06E-06 | 1.3 | 100 |
| 9 | 3.44E-06 | 0.8 | 100 | 3.77E-06 | 5.5 | 100 | 3.61E-06 | 2.2 | 100 | 3.98E-06 | 1.3 | 100 |
| 10 | 5.30E-06 | 0.8 | 100 | 5.86E-06 | 5.5 | 100 | 5.74E-06 | 2.2 | 100 | 6.32E-06 | 1.3 | 100 |
| 11 | 4.54E-06 | 0.8 | 100 | 5.02E-06 | 5.5 | 100 | 4.77E-06 | 2.2 | 100 | 5.25E-06 | 1.3 | 100 |
| 12 | 4.65E-06 | 0.8 | 100 | 5.12E-06 | 5.5 | 100 | 4.74E-06 | 2.2 | 100 | 5.22E-06 | 1.3 | 100 |
| 13 | 4.68E-06 | 0.8 | 100 | 5.15E-06 | 5.5 | 100 | 4.64E-06 | 2.2 | 100 | *1 5.08E-06 | 1.4 | 100 |
| 14 | 4.98E-06 | 0.8 | 100 | 5.47E-06 | 5.5 | 100 | 5.22E-06 | 2.2 | 100 | 5.67E-06 | 1.4 | 100 |
| 15 | 4.46E-06 | 0.8 | 100 | 4.84E-06 | 5.5 | 100 | 4.47E-06 | 2.2 | 100 | 4.83E-06 | 1.4 | 100 |
| 16 | 3.63E-06 | 0.8 | 100 | 4.01E-06 | 5.5 | 100 | 3.68E-06 | 2.2 | 100 | 4.02E-06 | 1.4 | 100 |
| 17 | 3.05E-06 | 0.8 | 100 | 3.34E-06 | 5.5 | 100 | 3.09E-06 | 2.2 | 100 | 3.39E-06 | 1.4 | 100 |
| 18 | 2.02E-06 | 0.8 | 100 | 2.18E-06 | 5.5 | 100 | 1.96E-06 | 2.2 | 100 | 2.13E-06 | 1.4 | 100 |
| 19 | 1.56E-06 | 0.8 | 100 | *1 1.65E-06 | 5.6 | 100 | *1 1.46E-06 | 2.3 | 100 | 1.63E-06 | 1.4 | 100 |
| 20 | 2.92E-06 | 0.8 | 100 | 3.15E-06 | 5.6 | 100 | 2.92E-06 | 2.3 | 100 | 3.32E-06 | 1.4 | 100 |
| 21 | 4.69E-06 | 0.8 | 100 | 5.08E-06 | 5.6 | 100 | 4.57E-06 | 2.3 | 100 | 5.15E-06 | 1.4 | 100 |
| 22 | 2.51E-06 | 0.8 | 100 | 2.69E-06 | 5.6 | 100 | 2.45E-06 | 2.3 | 100 | 2.73E-06 | 1.3 | 100 |
| 23 | 2.66E-06 | 0.8 | 100 | 2.91E-06 | 5.6 | 100 | 2.49E-06 | 2.3 | 100 | 2.64E-06 | 1.3 | 100 |
| 24 | 3.71E-06 | 0.8 | 100 | 4.18E-06 | 5.6 | 100 | 3.72E-06 | 2.3 | 100 | 3.87E-06 | 1.3 | 100 |
| 25 | 2.57E-06 | 0.8 | 100 | 2.85E-06 | 5.6 | 100 | 2.68E-06 | 2.3 | 100 | 2.81E-06 | 1.3 | 100 |
| 26 | 2.28E-06 | 0.8 | 100 | 2.48E-06 | 5.6 | 100 | 2.40E-06 | 2.3 | 100 | 2.51E-06 | 1.3 | 100 |
| 27 | 2.11E-06 | 0.8 | 100 | 2.29E-06 | 5.6 | 100 | 1.86E-06 | 2.3 | 100 | 2.01E-06 | 1.3 | 100 |
| 28 | 1.53E-06 | 0.8 | 100 | 1.64E-06 | 5.6 | 100 | 1.39E-06 | 2.3 | 100 | 1.53E-06 | 1.3 | 100 |
| 29 | 3.12E-06 | 0.8 | 100 | 3.50E-06 | 5.6 | 100 | 2.95E-06 | 2.3 | 100 | 3.17E-06 | 1.3 | 100 |
| 30 | 2.17E-06 | 0.8 | 100 | 2.37E-06 | 5.6 | 100 | 2.07E-06 | 2.3 | 100 | 2.24E-06 | 1.3 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.40E-06 | 0.8 | 100 | 3.71E-06 | 5.5 | 100 | 3.41E-06 | 2.2 | 100 | 3.73E-06 | 1.3 | 100 |
| 最大値 | 1.42E-05 | 0.9 | 102 | 1.27E-05 | 5.6 | 103 | 1.22E-05 | 2.3 | 103 | 1.33E-05 | 1.4 | 102 |
| 最大値日時 | 11/05 11:49 | 11/01 00:01 | 11/04 07:56 | 11/21 00:25 | 11/19 10:48 | 11/09 06:40 | 11/02 06:27 | 11/19 10:01 | 11/25 00:24 | 11/02 06:10 | 11/13 09:51 | 11/01 01:47 |
| 最小値 | 0.00E+00 | 0.8 | 97 | 0.00E+00 | 5.5 | 97 | 0.00E+00 | 2.2 | | 0.00E+00 | 1.3 | 98 |
| 最小値日時 | 11/21 11:29 | 11/05 11:49 | 11/30 16:51 | 11/19 10:48 | 11/01 00:01 | 11/04 08:10 | 11/19 10:01 | 11/01 00:01 | | 11/21 10:51 | 11/01 00:01 | 11/01 00:11 |

*1: ろ紙交換

測定月報

測定日：2024/11

(5/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A017 旧情報棟 | | | A018 旧情報棟 | | | A019 シーールド中央制御室 | | | A020 シーールド中央制御室 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.73E-06 | 4.6 | 100 | 3.68E-06 | 3.6 | 100 | 3.39E-06 | 1.6 | 100 | 3.50E-06 | 2.1 | 100 |
| 2 | 5.60E-06 | 4.6 | 100 | 5.52E-06 | 3.6 | 100 | 5.60E-06 | 1.6 | 100 | 5.72E-06 | 2.1 | 100 |
| 3 | 4.60E-06 | 4.6 | 100 | 4.54E-06 | 3.6 | 100 | 4.48E-06 | 1.6 | 100 | 4.59E-06 | 2.1 | 100 |
| 4 | 4.93E-06 | 4.6 | 100 | 4.92E-06 | 3.6 | 100 | 4.60E-06 | 1.6 | 100 | 4.64E-06 | 2.1 | 100 |
| 5 | 4.09E-06 | 4.6 | 100 | 4.02E-06 | 3.6 | 100 | *1 4.06E-06 | 1.6 | 100 | *1 4.11E-06 | 2.0 | 100 |
| 6 | 3.58E-06 | 4.6 | 100 | 3.56E-06 | 3.6 | 100 | 3.38E-06 | 1.6 | 100 | 3.53E-06 | 2.0 | 100 |
| 7 | 2.00E-06 | 4.6 | 100 | 1.98E-06 | 3.6 | 100 | 1.71E-06 | 1.6 | 100 | 1.73E-06 | 2.0 | 100 |
| 8 | 2.96E-06 | 4.6 | 100 | 2.97E-06 | 3.6 | 100 | 2.61E-06 | 1.6 | 100 | 2.66E-06 | 2.0 | 100 |
| 9 | 3.79E-06 | 4.6 | 100 | 3.78E-06 | 3.6 | 100 | 3.53E-06 | 1.6 | 100 | 3.68E-06 | 2.0 | 100 |
| 10 | 5.94E-06 | 4.6 | 100 | 5.79E-06 | 3.6 | 100 | 5.76E-06 | 1.6 | 100 | 5.80E-06 | 2.0 | 100 |
| 11 | 5.22E-06 | 4.6 | 100 | 5.11E-06 | 3.6 | 100 | 4.77E-06 | 1.6 | 100 | 4.80E-06 | 2.0 | 100 |
| 12 | 5.13E-06 | 4.6 | 100 | 5.02E-06 | 3.6 | 100 | 4.75E-06 | 1.6 | 100 | 4.89E-06 | 2.0 | 100 |
| 13 | 5.01E-06 | 4.6 | 100 | 4.88E-06 | 3.6 | 100 | 4.84E-06 | 1.6 | 100 | 4.92E-06 | 2.0 | 100 |
| 14 | 5.57E-06 | 4.6 | 100 | 5.42E-06 | 3.6 | 100 | 5.21E-06 | 1.6 | 100 | 5.33E-06 | 2.0 | 100 |
| 15 | 4.97E-06 | 4.6 | 100 | 4.80E-06 | 3.6 | 100 | 4.57E-06 | 1.6 | 100 | 4.72E-06 | 2.0 | 100 |
| 16 | 4.16E-06 | 4.6 | 100 | 4.02E-06 | 3.6 | 100 | 3.73E-06 | 1.6 | 100 | 3.83E-06 | 2.0 | 100 |
| 17 | 3.43E-06 | 4.6 | 100 | 3.34E-06 | 3.6 | 100 | 3.10E-06 | 1.6 | 100 | 3.08E-06 | 2.0 | 100 |
| 18 | 2.19E-06 | 4.6 | 100 | 2.14E-06 | 3.6 | 100 | 2.00E-06 | 1.6 | 100 | 2.04E-06 | 2.0 | 100 |
| 19 | 1.73E-06 | 4.6 | 100 | 1.72E-06 | 3.6 | 100 | 1.56E-06 | 1.6 | 100 | 1.60E-06 | 2.0 | 100 |
| 20 | 3.22E-06 | 4.6 | 100 | *1 3.12E-06 | 3.8 | 100 | 2.97E-06 | 1.6 | 100 | 3.06E-06 | 2.0 | 100 |
| 21 | 5.11E-06 | 4.6 | 100 | 4.87E-06 | 3.9 | 100 | 4.75E-06 | 1.6 | 100 | 4.96E-06 | 2.0 | 100 |
| 22 | 2.87E-06 | 4.6 | 100 | 2.75E-06 | 3.9 | 100 | 2.55E-06 | 1.6 | 100 | 2.67E-06 | 2.0 | 100 |
| 23 | 2.96E-06 | 4.6 | 100 | 2.78E-06 | 3.9 | 100 | 2.55E-06 | 1.6 | 100 | 2.76E-06 | 2.0 | 100 |
| 24 | 4.24E-06 | 4.6 | 100 | 4.04E-06 | 3.9 | 100 | 3.80E-06 | 1.6 | 100 | 3.95E-06 | 2.0 | 100 |
| 25 | *1 3.04E-06 | 4.7 | 100 | 2.89E-06 | 3.9 | 100 | 2.64E-06 | 1.6 | 100 | 2.74E-06 | 2.0 | 100 |
| 26 | 2.72E-06 | 4.8 | 100 | 2.65E-06 | 3.9 | 100 | 2.33E-06 | 1.6 | 100 | 2.47E-06 | 2.0 | 100 |
| 27 | 2.28E-06 | 4.8 | 100 | 2.19E-06 | 3.9 | 100 | 1.98E-06 | 1.6 | 100 | 2.10E-06 | 2.0 | 100 |
| 28 | 1.72E-06 | 4.8 | 100 | 1.67E-06 | 3.9 | 100 | 1.42E-06 | 1.6 | 100 | 1.50E-06 | 2.0 | 100 |
| 29 | 3.44E-06 | 4.8 | 100 | 3.36E-06 | 3.9 | 100 | 3.03E-06 | 1.6 | 100 | 3.18E-06 | 2.0 | 100 |
| 30 | 2.37E-06 | 4.8 | 100 | 2.29E-06 | 3.9 | 100 | 2.14E-06 | 1.6 | 100 | 2.23E-06 | 2.0 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.75E-06 | 4.6 | 100 | 3.66E-06 | 3.7 | 100 | 3.46E-06 | 1.6 | 100 | 3.56E-06 | 2.0 | 100 |
| 最大値 | 1.16E-05 | 4.8 | 103 | 1.19E-05 | 3.9 | 102 | 1.75E-05 | 1.6 | 102 | 1.23E-05 | 2.1 | 102 |
| 最大値日時 | 11/21 00:23 | 11/25 10:15 | 11/25 05:35 | 11/02 06:08 | 11/20 10:18 | 11/02 01:40 | 11/05 11:44 | 11/01 00:01 | 11/03 15:14 | 11/21 00:23 | 11/01 00:01 | 11/03 10:25 |
| 最小値 | 0.00E+00 | 4.6 | 98 | 0.00E+00 | 3.6 | 98 | 0.00E+00 | 1.6 | 98 | 0.00E+00 | 2.0 | 98 |
| 最小値日時 | 11/25 10:15 | 11/01 00:01 | 11/01 04:16 | 11/20 10:18 | 11/01 00:01 | 11/01 03:43 | 11/21 14:08 | 11/01 00:01 | 11/01 03:52 | 11/05 12:00 | 11/05 12:00 | 11/01 07:24 |

*1:ろ紙交換

測定月報

測定日：2024/11

(6/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A021 Hタンクエリア | | | A022 Hタンクエリア | | | A023 2u西側 | | | A024 2u西側 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.83E-06 | 2.5 | 100 | 3.56E-06 | 2.1 | 100 | 3.57E-06 | 6.1 | 100 | 3.40E-06 | 5.9 | 100 |
| 2 | 6.13E-06 | 2.5 | 100 | 5.72E-06 | 2.1 | 100 | 5.57E-06 | 6.1 | 100 | 5.18E-06 | 5.9 | 100 |
| 3 | 4.87E-06 | 2.5 | 100 | 4.47E-06 | 2.1 | 100 | 4.57E-06 | 6.1 | 100 | 4.28E-06 | 5.9 | 100 |
| 4 | 5.20E-06 | 2.5 | 100 | 4.76E-06 | 2.1 | 100 | 4.92E-06 | 6.1 | 100 | 4.57E-06 | 5.9 | 100 |
| 5 | 4.37E-06 | 2.5 | 100 | *1 4.04E-06 | 2.2 | 100 | 4.13E-06 | 6.1 | 100 | 3.87E-06 | 5.9 | 100 |
| 6 | 3.75E-06 | 2.5 | 100 | 3.44E-06 | 2.2 | 100 | 3.56E-06 | 6.1 | 100 | 3.33E-06 | 5.9 | 100 |
| 7 | 1.98E-06 | 2.5 | 100 | 1.75E-06 | 2.2 | 100 | 1.82E-06 | 6.1 | 100 | 1.76E-06 | 5.9 | 100 |
| 8 | 3.07E-06 | 2.5 | 100 | 2.75E-06 | 2.2 | 100 | 2.82E-06 | 6.1 | 100 | 2.68E-06 | 5.9 | 100 |
| 9 | 4.02E-06 | 2.5 | 100 | 3.64E-06 | 2.2 | 100 | 3.68E-06 | 6.1 | 100 | 3.50E-06 | 5.9 | 100 |
| 10 | 6.51E-06 | 2.5 | 100 | 5.88E-06 | 2.2 | 100 | 6.00E-06 | 6.1 | 100 | 5.64E-06 | 5.9 | 100 |
| 11 | 5.29E-06 | 2.5 | 100 | 4.80E-06 | 2.2 | 100 | 5.01E-06 | 6.1 | 100 | 4.76E-06 | 5.9 | 100 |
| 12 | 5.42E-06 | 2.5 | 100 | 4.93E-06 | 2.2 | 100 | 5.05E-06 | 6.1 | 100 | 4.71E-06 | 5.9 | 100 |
| 13 | *1 5.37E-06 | 2.6 | 100 | 4.77E-06 | 2.2 | 100 | 4.87E-06 | 6.1 | 100 | 4.59E-06 | 5.9 | 100 |
| 14 | 5.80E-06 | 2.6 | 100 | 5.30E-06 | 2.2 | 100 | 5.37E-06 | 6.1 | 100 | 4.98E-06 | 5.9 | 100 |
| 15 | 5.09E-06 | 2.6 | 100 | 4.63E-06 | 2.2 | 100 | 5.01E-06 | 6.1 | 100 | 4.71E-06 | 5.9 | 100 |
| 16 | 4.28E-06 | 2.6 | 100 | 3.89E-06 | 2.2 | 100 | 3.91E-06 | 6.1 | 100 | 3.70E-06 | 5.9 | 100 |
| 17 | 3.53E-06 | 2.6 | 100 | 3.15E-06 | 2.2 | 100 | 3.29E-06 | 6.1 | 100 | 3.15E-06 | 5.9 | 100 |
| 18 | 2.21E-06 | 2.6 | 100 | 1.99E-06 | 2.2 | 100 | 2.05E-06 | 6.1 | 100 | 1.94E-06 | 5.9 | 100 |
| 19 | 1.72E-06 | 2.6 | 100 | 1.57E-06 | 2.2 | 100 | 1.61E-06 | 6.1 | 100 | 1.53E-06 | 5.9 | 100 |
| 20 | 3.40E-06 | 2.6 | 100 | 3.12E-06 | 2.2 | 100 | 3.10E-06 | 6.1 | 100 | *1 3.01E-06 | 5.8 | 100 |
| 21 | 5.40E-06 | 2.6 | 100 | 4.86E-06 | 2.2 | 100 | 4.99E-06 | 6.1 | 100 | 4.73E-06 | 5.8 | 100 |
| 22 | 2.84E-06 | 2.6 | 100 | 2.62E-06 | 2.2 | 100 | 2.74E-06 | 6.1 | 100 | 2.65E-06 | 5.8 | 100 |
| 23 | 2.87E-06 | 2.6 | 100 | 2.69E-06 | 2.2 | 100 | 2.85E-06 | 6.1 | 100 | 2.77E-06 | 5.8 | 100 |
| 24 | 4.23E-06 | 2.6 | 100 | 3.88E-06 | 2.2 | 100 | 4.15E-06 | 6.1 | 100 | 3.88E-06 | 5.8 | 100 |
| 25 | 3.10E-06 | 2.6 | 100 | 2.83E-06 | 2.2 | 100 | *1 2.89E-06 | 6.2 | 100 | 2.86E-06 | 5.8 | 100 |
| 26 | 2.83E-06 | 2.6 | 100 | 2.60E-06 | 2.2 | 100 | 2.52E-06 | 6.3 | 100 | 2.81E-06 | 5.8 | 100 |
| 27 | 2.18E-06 | 2.6 | 100 | 2.01E-06 | 2.2 | 100 | 3.13E-06 | 6.3 | 100 | 3.10E-06 | 5.8 | 100 |
| 28 | 1.68E-06 | 2.6 | 100 | 1.53E-06 | 2.2 | 100 | 3.06E-06 | 6.3 | 100 | 3.06E-06 | 5.8 | 100 |
| 29 | 3.49E-06 | 2.6 | 100 | 3.22E-06 | 2.2 | 100 | 4.81E-06 | 6.3 | 100 | 4.86E-06 | 5.8 | 100 |
| 30 | 2.42E-06 | 2.6 | 100 | 2.21E-06 | 2.2 | 100 | 3.81E-06 | 6.3 | 100 | 4.12E-06 | 5.8 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.90E-06 | 2.6 | 100 | 3.55E-06 | 2.2 | 100 | 3.83E-06 | 6.1 | 100 | 3.67E-06 | 5.9 | 100 |
| 最大値 | 1.38E-05 | 2.6 | 102 | 1.26E-05 | 2.2 | 103 | 1.19E-05 | 6.3 | 102 | 3.72E-05 | 5.9 | 103 |
| 最大値日時 | 11/02 06:13 | 11/13 10:33 | 11/03 05:37 | 11/02 05:59 | 11/05 11:38 | 11/21 15:12 | 11/21 00:30 | 11/25 10:02 | 11/13 17:37 | 11/26 10:59 | 11/01 00:01 | 11/27 03:58 |
| 最小値 | 0.00E+00 | 2.5 | 98 | 0.00E+00 | 2.1 | 97 | 0.00E+00 | 6.1 | 98 | 0.00E+00 | 5.8 | |
| 最小値日時 | 11/13 10:33 | 11/01 00:01 | 11/03 19:37 | 11/05 11:38 | 11/01 00:01 | 11/15 17:29 | 11/25 10:02 | 11/01 00:01 | 11/01 07:09 | 11/26 10:55 | 11/20 10:12 | |

*1:ろ紙交換

測定月報

測定日：2024/11

(7/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A027 1号機海側2、5m盤 | | | A028 1号機海側2、5m盤 | | | A029 3号機海側2、5m盤 | | | A030 3号機海側2、5m盤 | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.58E-06 | 2.0 | 100 | 3.47E-06 | 2.5 | 100 | 3.55E-06 | 2.1 | 100 | 3.22E-06 | 2.3 | 100 |
| 2 | 5.52E-06 | 2.0 | 100 | 5.37E-06 | 2.5 | 100 | 5.65E-06 | 2.1 | 100 | 5.11E-06 | 2.3 | 100 |
| 3 | 4.81E-06 | 2.0 | 100 | 4.60E-06 | 2.5 | 100 | 4.76E-06 | 2.1 | 100 | 4.26E-06 | 2.3 | 100 |
| 4 | 4.97E-06 | 2.0 | 100 | 4.74E-06 | 2.5 | 100 | 4.98E-06 | 2.1 | 100 | 4.49E-06 | 2.3 | 100 |
| 5 | 4.22E-06 | 2.0 | 100 | 4.04E-06 | 2.5 | 100 | 4.18E-06 | 2.1 | 100 | 3.83E-06 | 2.3 | 100 |
| 6 | 3.59E-06 | 2.0 | 100 | 3.47E-06 | 2.5 | 100 | 3.61E-06 | 2.1 | 100 | 3.27E-06 | 2.3 | 100 |
| 7 | 1.94E-06 | 2.0 | 100 | 1.84E-06 | 2.5 | 100 | 1.99E-06 | 2.1 | 100 | 1.78E-06 | 2.3 | 100 |
| 8 | 2.78E-06 | 2.0 | 100 | 2.69E-06 | 2.5 | 100 | 2.90E-06 | 2.1 | 100 | 2.66E-06 | 2.3 | 100 |
| 9 | 3.69E-06 | 2.0 | 100 | 3.52E-06 | 2.5 | 100 | 3.81E-06 | 2.1 | 100 | 3.49E-06 | 2.3 | 100 |
| 10 | 5.62E-06 | 2.0 | 100 | 5.41E-06 | 2.5 | 100 | 5.59E-06 | 2.1 | 100 | 5.06E-06 | 2.3 | 100 |
| 11 | 5.08E-06 | 2.0 | 100 | 4.87E-06 | 2.5 | 100 | 4.98E-06 | 2.1 | 100 | 4.53E-06 | 2.3 | 100 |
| 12 | 4.78E-06 | 2.5 | 100 | 4.73E-06 | 2.5 | 100 | 4.98E-06 | 2.1 | 100 | 4.53E-06 | 2.3 | 100 |
| 13 | 4.63E-06 | 2.8 | 100 | 4.78E-06 | 2.5 | 100 | 5.04E-06 | 2.1 | 100 | *1 4.56E-06 | 2.2 | 100 |
| 14 | 4.76E-06 | 2.8 | 100 | 4.92E-06 | 2.5 | 100 | 5.13E-06 | 2.1 | 100 | 4.72E-06 | 2.2 | 100 |
| 15 | 4.38E-06 | 2.8 | 100 | 4.60E-06 | 2.5 | 100 | 4.68E-06 | 2.1 | 100 | 4.35E-06 | 2.2 | 100 |
| 16 | 3.50E-06 | 2.8 | 100 | 3.65E-06 | 2.5 | 100 | 3.91E-06 | 2.1 | 100 | 3.63E-06 | 2.2 | 100 |
| 17 | 2.84E-06 | 2.8 | 100 | 2.98E-06 | 2.5 | 100 | 3.05E-06 | 2.1 | 100 | 2.79E-06 | 2.2 | 100 |
| 18 | 1.98E-06 | 2.8 | 100 | 2.05E-06 | 2.5 | 100 | 2.11E-06 | 2.1 | 100 | 1.98E-06 | 2.2 | 100 |
| 19 | 1.48E-06 | 2.8 | 100 | 1.53E-06 | 2.5 | 100 | 1.64E-06 | 2.1 | 100 | 1.55E-06 | 2.2 | 100 |
| 20 | 2.93E-06 | 2.8 | 100 | *1 3.09E-06 | 2.5 | 100 | 3.08E-06 | 2.1 | 100 | 2.87E-06 | 2.2 | 100 |
| 21 | 4.63E-06 | 2.8 | 100 | 4.88E-06 | 2.5 | 100 | 5.06E-06 | 2.1 | 100 | 4.62E-06 | 2.2 | 100 |
| 22 | 2.62E-06 | 2.8 | 100 | 2.76E-06 | 2.5 | 100 | 2.87E-06 | 2.1 | 100 | 2.64E-06 | 2.2 | 100 |
| 23 | 2.76E-06 | 2.8 | 100 | 2.84E-06 | 2.5 | 100 | 2.95E-06 | 2.1 | 100 | 2.77E-06 | 2.2 | 100 |
| 24 | 3.86E-06 | 2.8 | 100 | 4.06E-06 | 2.5 | 100 | 4.20E-06 | 2.1 | 100 | 3.88E-06 | 2.2 | 100 |
| 25 | 2.58E-06 | 2.8 | 100 | 2.69E-06 | 2.5 | 100 | *1 2.95E-06 | 2.0 | 100 | 2.70E-06 | 2.2 | 100 |
| 26 | 2.26E-06 | 2.8 | 100 | 2.36E-06 | 2.5 | 100 | 2.67E-06 | 2.0 | 100 | 2.47E-06 | 2.2 | 100 |
| 27 | 2.11E-06 | 2.8 | 100 | 2.20E-06 | 2.5 | 100 | 2.35E-06 | 2.0 | 100 | 2.14E-06 | 2.2 | 100 |
| 28 | 1.63E-06 | 2.8 | 100 | 1.68E-06 | 2.5 | 100 | 1.78E-06 | 2.0 | 100 | 1.64E-06 | 2.2 | 100 |
| 29 | 3.28E-06 | 2.8 | 100 | 3.37E-06 | 2.5 | 100 | 3.55E-06 | 2.0 | 100 | 3.26E-06 | 2.2 | 100 |
| 30 | 2.24E-06 | 2.8 | 100 | 2.31E-06 | 2.5 | 100 | 2.47E-06 | 2.0 | 100 | 2.24E-06 | 2.2 | 100 |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.50E-06 | 2.5 | 100 | 3.52E-06 | 2.5 | 100 | 3.68E-06 | 2.1 | 100 | 3.37E-06 | 2.2 | 100 |
| 最大値 | 1.16E-05 | 2.8 | 104 | 1.11E-05 | 2.5 | 104 | 1.14E-05 | 2.1 | 102 | 1.04E-05 | 2.3 | 101 |
| 最大値日時 | 11/11 08:39 | 11/12 10:27 | 11/03 14:25 | 11/21 00:32 | 11/01 00:01 | 11/19 10:04 | 11/02 06:03 | 11/01 00:01 | 11/03 16:13 | 11/21 00:29 | 11/01 00:01 | 11/01 00:13 |
| 最小値 | 0.00E+00 | 2.0 | 96 | 0.00E+00 | 2.5 | 96 | 0.00E+00 | 2.0 | 98 | 0.00E+00 | 2.2 | 99 |
| 最小値日時 | 11/12 10:27 | 11/01 00:01 | 11/03 04:27 | 11/20 09:57 | 11/01 00:01 | 11/16 15:18 | 11/02 15:00 | 11/25 09:46 | 11/04 02:33 | 11/28 10:36 | 11/13 11:46 | 11/01 00:19 |

*1: ろ紙交換

測定月報

測定日：2024/11

(8/8)

| 日 | モニタ | | | | | | | | | | | |
|-------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|-----------------------------|--------------|---------------|
| | A031 HTI南側 | | | A032 HTI南側 | | | | | | | | |
| | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) | 濃度 (Bq/cm ³) | 計数率 (cps) | 流量 (L/min) |
| 1 | 3.56E-06 | 1.1 | 100 | 3.57E-06 | 1.5 | 100 | | | | | | |
| 2 | 5.52E-06 | 1.1 | 100 | 5.51E-06 | 1.5 | 100 | | | | | | |
| 3 | 4.54E-06 | 1.1 | 100 | 4.57E-06 | 1.5 | 100 | | | | | | |
| 4 | 4.64E-06 | 1.1 | 100 | 4.64E-06 | 1.5 | 100 | | | | | | |
| 5 | 4.02E-06 | 1.1 | 100 | *1 4.13E-06 | 1.6 | 100 | | | | | | |
| 6 | 3.39E-06 | 1.1 | 100 | 3.32E-06 | 1.6 | 100 | | | | | | |
| 7 | 1.76E-06 | 1.1 | 100 | 1.69E-06 | 1.6 | 100 | | | | | | |
| 8 | 2.57E-06 | 1.1 | 100 | 2.56E-06 | 1.6 | 100 | | | | | | |
| 9 | 3.49E-06 | 1.1 | 100 | 3.41E-06 | 1.6 | 100 | | | | | | |
| 10 | 5.50E-06 | 1.1 | 100 | 5.46E-06 | 1.6 | 100 | | | | | | |
| 11 | 4.96E-06 | 1.1 | 100 | 4.91E-06 | 1.6 | 100 | | | | | | |
| 12 | 4.72E-06 | 1.1 | 100 | 4.67E-06 | 1.6 | 100 | | | | | | |
| 13 | 4.82E-06 | 1.1 | 100 | 4.74E-06 | 1.6 | 100 | | | | | | |
| 14 | 5.02E-06 | 1.1 | 100 | 4.94E-06 | 1.6 | 100 | | | | | | |
| 15 | 4.71E-06 | 1.1 | 100 | 4.67E-06 | 1.6 | 100 | | | | | | |
| 16 | 3.77E-06 | 1.1 | 100 | 3.72E-06 | 1.6 | 100 | | | | | | |
| 17 | 3.48E-06 | 1.1 | 100 | 3.49E-06 | 1.6 | 100 | | | | | | |
| 18 | 2.08E-06 | 1.1 | 100 | 2.07E-06 | 1.6 | 100 | | | | | | |
| 19 | 1.55E-06 | 1.1 | 100 | 1.52E-06 | 1.6 | 100 | | | | | | |
| 20 | 2.91E-06 | 1.1 | 100 | 2.90E-06 | 1.6 | 100 | | | | | | |
| 21 | 4.82E-06 | 1.1 | 100 | 4.72E-06 | 1.6 | 100 | | | | | | |
| 22 | 2.57E-06 | 1.1 | 100 | 2.54E-06 | 1.6 | 100 | | | | | | |
| 23 | 2.67E-06 | 1.1 | 100 | 2.66E-06 | 1.6 | 100 | | | | | | |
| 24 | 3.86E-06 | 1.1 | 100 | 3.82E-06 | 1.6 | 100 | | | | | | |
| 25 | *1 2.83E-06 | 1.0 | 100 | 2.80E-06 | 1.6 | 100 | | | | | | |
| 26 | 2.36E-06 | 1.0 | 100 | 2.39E-06 | 1.6 | 100 | | | | | | |
| 27 | 2.30E-06 | 1.0 | 100 | 2.32E-06 | 1.6 | 100 | | | | | | |
| 28 | 1.51E-06 | 1.0 | 100 | 1.47E-06 | 1.6 | 100 | | | | | | |
| 29 | 3.16E-06 | 1.0 | 100 | 3.16E-06 | 1.6 | 100 | | | | | | |
| 30 | 2.16E-06 | 1.0 | 100 | 2.13E-06 | 1.6 | 100 | | | | | | |
| 31 | | | | | | | | | | | | |
| 1ヶ月値 | 3.51E-06 | 1.1 | 100 | 3.48E-06 | 1.6 | 100 | | | | | | |
| 最大値 | 1.10E-05 | 1.1 | 102 | 1.17E-05 | 1.6 | 102 | | | | | | |
| 最大値日時 | 11/21 00:14 | 11/01 00:01 | 11/07 11:57 | 11/02 06:26 | 11/05 10:03 | 11/01 02:29 | | | | | | |
| 最小値 | 0.00E+00 | 1.0 | 98 | 0.00E+00 | 1.5 | 98 | | | | | | |
| 最小値日時 | 11/27 11:16 | 11/25 09:56 | 11/01 12:14 | 11/05 10:03 | 11/01 00:01 | 11/01 00:33 | | | | | | |

*1: ろ紙交換