Reference

## Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations (Data summarized on January 3)

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation (Bq/cm3) (Density limit in the air to which radiation workers
Time of Sampling	January 2, 2012 7:00am ~ 12:00pm		January 2, 2012 9:12am ~ 9:22am				
Detected Nuclides (Half-life)	density of sample ( Bq/cm3)	Scaling Factor ( / )	density of sample ( Bq/cm3)	Scaling Factor ( / )	density of sample ( Bq/cm3)	Scaling Factor ( / )	breathe in the section 4 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	3.6E-07	0.00	ND	-			3E-03

<sup>\*</sup> The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10-O

Data of other nuclides are under examination.

Detection limits of 3 nuclides on the West Gate of Fukushima Daiichi are as follows:

Volatile: I-131: approx. 1E-7Bq/cm3, Cs-134: approx. 3E-7Bq/cm3 Particulate: I-131: approx. 7E-8Bq/cm3, Cs-134: approx. 2E-7Bq/cm3 Particulate: I-131: approx. 7E-8Bq/cm3, Cs-134: approx. 2E-7Bq/cm3


Detection limits of 3 nuclides on MP-1 of Fukushima Daini are as follows:

Volatile: I-131: approx. 2E-6Bq/cm3, Cs-134: approx. 3E-6Bq/cm3, Cs-137: approx. 3E-6Bq/cm3 Particulate: I-131: approx. 7E-7Bq/cm3, Cs-134: approx. 2E-6Bq/cm3, Cs-137: approx. 2E-6Bq/cm3

<sup>\*</sup> In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

<sup>\* &</sup>quot;ND" means the sampled data is below measurable limit.

## West Gate of Fukushima Daiichi Nuclear Power Station Results of Dust Nuclide Analysis (Bq/cm3)



## (Reference) Fukushima Daini MP-1 Results of Dust Nuclide Analysis (Bq/cm3)

