Reference

## Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

# (Data summarized on March 29)

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation (Bq/cm3) (Density limit in the air to which radiation workers
Time of Sampling	Mar 28, 2012 7:00 am - 12:00 pm		Mar 28, 2012 9:35 am - 9:45 am				
Detected Nuclides (Half-life)	density of sample ( Bq/cm3)	Scaling Factor ( / )	density of sample ( Bq/cm3)	Scaling Factor ( / )	density of sample ( Bq/cm3)	Scaling Factor ( / )	breathe in the section 4 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	1			1E-03
Cs-134 (about 2 years)	ND	-	ND				2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03

<sup>\*</sup> The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10-O

Data of other nuclides are under examination.

Detection limits at the West Gate of Fukushima Daiichi are as follows:

Volatile: I-131: approx. 1E-7Bq/cm3, Cs-134: approx. 3E-7Bq/cm3, Cs-137: approx. 4E-7Bq/cm3 approx. 2E-7Bq/cm3, Cs-137: approx. 2E-7Bq/cm3

Detection limits at MP-1 of Fukushima Daini are as follows:

Volatile: I-131: approx. 2E-6Bq/cm3, Cs-134: approx. 3E-6Bq/cm3, Cs-137: approx. 3E-6Bq/cm3 134: approx. 2E-6Bq/cm3, Cs-137: approx. 2E-6Bq/cm3

Particulate: I-131: approx. 6E-8Bq/cm3, Cs-134:

Particulate: I-131: approx. 1E-6Bq/cm3, Cs-

<sup>\*</sup> In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

<sup>\* &</sup>quot;ND" means the sampled data is below measurable limit.

#### Fukushima Daiichi Nuclear Power Station Results of Pu Analysis in the Air

1. Sampling Point: West Gate of Fukushima Daiichi Nuclear Power Station

2. Analytical Body: Japan Chemical Analysis Center

3. Results of Analysis:

(Unit: Bq/cm<sup>3</sup>)

Sample	Date of Sampling	Pu-238	Pu-239+Pu-240
Volatile	3/12	N.D. [<6.3×10 <sup>-10</sup> ]	N.D. [<6.9×10 <sup>-10</sup> ]
Particle	3/12	N.D. [<9.5×10 <sup>-10</sup> ]	N.D. [<9.5×10 <sup>-10</sup> ]

Values in [ ] indicate detection limits.

#### 4. Valuation:

None of Pu-238 or Pu-239+Pu-240 were detected the samples collected this time.

End

# West Gate of Fukushima Daiichi Nuclear Power Station Results of Dust Nuclide Analysis (Bq/cm3)



