Reference

Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

(Data summarized on May 24)

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation (Bq/cm³) (Density limit in the air to which radiation workers
Time of Sampling	May 23, 2012 7:00 ~ 12:00		May 23, 2012 9:38 ~ 9:48				
Detected Nuclides (Half-life)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling	breathe in the section 4 of the appendix 2)
I-131 (approx. 8 days)	ND	1	ND	-			1E-03
Cs-134 (approx. 2 years)	ND	-	ND				2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-			3E-03

^{*} The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10-O

Data of other nuclides are under examination.

Detection limits at the West Gate of Fukushima Daiichi are as follows:

Volatile: I-131: approx. 1E-7Bq/cm3, Cs-134: approx. 3E-7Bq/cm3, Cs-137: approx. 4E-7Bq/cm3 approx. 2E-7Bq/cm3, Cs-137: approx. 2E-7Bq/cm3

Detection limits at MP-1 of Fukushima Daini are as follows:

Volatile: I-131: approx. 2E-6Bq/cm3, Cs-134: approx. 3E-6Bq/cm3, Cs-137: approx. 3E-6Bq/cm3 134: approx. 1E-6Bq/cm3, Cs-137: approx. 1E-6Bq/cm3


Particulate: I-131: approx. 6E-8Bq/cm3, Cs-134:

Particulate: I-131: approx. 9E-7Bq/cm3, Cs-

^{*} In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

^{* &}quot;ND" means the sampled data is below measurable limit.

West Gate of Fukushima Daiichi Nuclear Power Station Results of Dust Nuclide Analysis (Bq/cm3)



(Reference) Fukushima Daini MP-1 Results of Dust Nuclide Analysis (Bq/cm3)

