Reference

Nuclide Analysis Results of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations < 1/2 > (Data summarized on September 19)

Place of Sampling	The West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini NPS (Reference)				Density Limit Specified by
Time of Sampling	Sep 18, 2012 7:00 AM - 12:00 PM		Sep 18, 2012 9:29 AM - 9:39 AM				the Reactor Regulation (Bq/cm³) (Density limit in the air which radiation workers
Detected Nuclides (Half-life)	Density of Sample (Bq/cm³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm³)	Scaling Factor (/)	breathe in is specified in section 4 of Appendix 2)
I-131 (Approx. 8 days)	ND	-	ND	-			1E-03
Cs-134 (Approx. 2 years)	ND	ı	ND	ı			2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-			3E-03

^{*} The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10^{-O}

Data of other nuclides is under examination.

The detection limits at the west gate of Fukushima Daiichi NPS are as follows: Volatile: I-131: Approx. 9E-8Bq/cm3, Cs-134: Approx.2E-7Bq/cm3, Cs-137: Approx.3E-7Bq/cm3 Particulate: I-131: Approx. 6E-8Bq/cm3, Cs-134: Approx.1E-7Bq/cm3, Cs-137: Approx.2E-7Bq/cm3 The detection limits at MP-1 of Fukushima Daini MPS are as follows: Volatile: I-131: Approx. 1E-6Bq/cm3, Cs-134: Approx.2E-6Bq/cm3, Cs-137: Approx.2E-6Bq/cm3

Particulate: I-131: Approx. 8E-7Bq/cm3, Cs-134: Approx.1E-6Bq/cm3, Cs-137: Approx.7E-7Bq/cm3

^{*} In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

 $^{^{\}ast}$ "ND" indicates that the measurement result is below the detection limit.

Reference

Nuclide Analysis Results of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations < 2/2 > (Data summarized on September 19)

Place of Sampling	MP-1 at Fukushima Daiichi NPS		MP-3 at Fukushima Daiichi NPS		MP-8 at Fukushima Daiichi NPS		Density Limit Specified by the Reactor Regulation (Bq/cm³) (Density limit in the air which radiation workers
Time of Sampling	Sep 18, 2012 9:46 AM - 2:46 PM		Sep 18, 2012 9:15 AM - 2:15 PM		Sep 18, 2012 9:26 AM - 2:26 PM		
Detected Nuclides (Half-life)	Density of Sample (Bq/cm³)	Scaling Factor (/)	Density of Sample (Bq/cm³)	Scaling Factor (/)	Density of Sample (Bq/cm³)	Scaling Factor (/)	breathe in is specified in section 4 of Appendix 2)
I-131 (Approx. 8 days)	ND	-	ND	1	ND	1	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	3E-03

^{*} The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.


O.OE - O is the same as O.O x 10^{-O}

Data of other nuclides is under examination.


The detection limits are as follows. Volatile: I-131: Approx. 1E-7Bq/cm3, Cs-134: Approx.2E-7Bq/cm3, Cs-137: Approx.3E-7Bq/cm3
Particulate: I-131: Approx. 5E-8Bq/cm3, Cs-134: Approx.1E-7Bq/cm3, Cs-137: Approx.1E-7Bq/cm3
As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.


^{*} In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.


^{* &}quot;ND" indicates that the measurement result is below the detection limit.



(Reference) Dust Nuclides Analysis Results of MP-1 at Fukushima Daini NPS (Bq/cm³)







Dust Nuclides Analysis Result: MP-8 at Fukushima Daiichi NPS (Bq/cm³)

