Reference

## Nuclides Analysis Result of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations

## (Data summarized on October 14)

Place of Sampling	The West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini NPS (Reference)				Density Limit Specified by the Reactor Regulation (Bq/cm³) (Density limit in the air which radiation workers breathe in
Time of Sampling	October 13, 2012 7:00 AM - 12:00 PM		October 13, 2012 9:46 AM - 9:56 AM				
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm³)	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	is specified in section 4 of Appendix 2)
I-131 (Approx. 8 days)	ND	1	ND	-			1E-03
Cs-134 (Approx. 2 years)	ND		ND	-			2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-			3E-03

<sup>\*</sup> The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10<sup>-O</sup>

Data of other nuclides is under examination.


The detection limits at the west gate of Fukushima Daiichi NPS are as follows: Volatile: I-131: Approx. 9E-8Bq/cm3, Cs-134: Approx.2E-7Bq/cm3, Cs-137: Approx.3E-7Bq/cm3 Particulate: I-131: Approx. 5E-8Bq/cm3, Cs-134: Approx.1E-7Bq/cm3, Cs-137: Approx.2E-7Bq/cm3 The detection limits at MP-1 of Fukushima Daini MPS are as follows: Volatile: I-131: Approx. 1E-6Bq/cm3, Cs-134: Approx.2E-6Bq/cm3, Cs-137: Approx.2E-6Bq/cm3

Particulate: I-131: Approx. 7E-7Bq/cm3, Cs-134: Approx.9E-7Bq/cm3, Cs-137: Approx.8E-7Bq/cm3

<sup>\*</sup> In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

 $<sup>^{\</sup>star}$  "ND" indicates that the measurement result is below the detection limit.

## Dust Nuclides Analysis Result: The West Gate of Fukushima Daiichi Nuclear Power Station (Bq/cm3)



## (Reference) Dust Nuclides Analysis Results of MP-1 at Fukushima Daini NPS (Bq/cm3)

