

Reference
-----------

### Nuclide Analysis Results of Radioactive Fallout at and around the Site of Fukushima Daiichi NPS

	Sampling Point	Sampling Period		Radioactivity Density of Samples (Bq/m <sup>2</sup> ) (Half-life)		
		From	To	I-131 (approx. 8 days)	Cs-134 (approx. 2 years)	Cs-137 (approx. 30 years)
Fukushima Daiichi NPS	Environment Management Building	2012/9/3 11:00 AM	2012/10/1 10:30 AM	ND	12000	20000
Fukushima Daini NPS	Administrative Office Building	2012/9/3 2:10 PM	2012/10/1 10:10 AM	ND	ND	ND

\* Bq/m<sup>2</sup> = MBq/km<sup>2</sup>

\* When the measurement value is below the detection limit, "ND" is marked. (I-131: approx. 490Bq/m<sup>2</sup>, Cs-134: approx. 66Bq/m<sup>2</sup>, Cs-137: approx. 82Bq/m<sup>2</sup>)  
 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.