

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 15, 2012 7:00 - 12:00		Feb 15, 2012 9:35 - 9:45				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected at west gate of Fukushima Daiichi NPP are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

 Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 9E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 2E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <1/2>

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 16, 2012 7:00 - 12:00		Feb 16, 2012 9:15 - 9:25				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected at west gate of Fukushima Daiichi NPP are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

 Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 2E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <2/2>

Place of Sampling	North Side Slope of Fukushima Daiichi Unit 1		West Side Slope of Fukushima Daiichi Unit 1 & 2		West Side Slope of Fukushima Daiichi Unit 3 & 4		②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Time of Sampling		Time of Sampling		Time of Sampling		
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
	I-131 (about 8 days)	ND	-	ND	-	ND	
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21 hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 5E-6Bq/cm³

Particulate: I-131: approx. 1E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the seaside of the sites of Fukushima Nuclear Power Stations

Place of Sampling	Fukushima Daiichi Unit 1 -4 Sea Side						②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 16, 2012 9:31 - 14:31						
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-					1E-03
Cs-134 (about 2 years)	ND	-					2E-03
Cs-137 (about 30 years)	2.8E-07	0.00					3E-03
Nb-95 (approx.35days)	ND	-					2E-02
Tc-99m (approx.6hrs)	ND	-					7E-01
Ag-110m (approx.250days)	ND	-					3E-03
Sb-125 (approx.3yrs)	ND	-					6E-03
Te-129 (approx.70mins)	ND	-					4E-01
Te-129m (approx.34days)	ND	-					4E-03
I-132 (approx.2hrs)	ND	-					7E-02
Te-132 (approx.78hrs)	ND	-					4E-03
I-133 (approx.21 hrs)	ND	-					5E-03
Cs-136 (approx.13days)	ND	-					1E-02
Ba-140 (approx.13days)	ND	-					1E-02
La-140 (approx.40hrs)	ND	-					1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 4E-7Bq/cm³, Cs-137: approx. 5E-7Bq/cm³

 Particulate: I-131: approx. 8E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Feb 17, 2012 7:00 - 12:00		Feb 17, 2012 9:23 - 9:33				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected at west gate of Fukushima Daiichi NPP are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

 Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 1E-6Bq/cm³, Cs-137: approx. 2E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)		/		②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Time of Sampling		Time of Sampling		/		
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	/	/	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	/	/	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	/	/	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	/	/	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	/	/	7E-01
Ag-110m (approx.250days)	ND	-	ND	-	/	/	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	/	/	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	/	/	4E-01
Te-129m (approx.34days)	ND	-	ND	-	/	/	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	/	/	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	/	/	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	/	/	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	/	/	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	/	/	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	/	/	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected at west gate of Fukushima Daiichi NPP are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

 Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 9E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 19, 2012 7:00 - 12:00		Feb 19, 2012 9:14 - 9:24				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 1E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 20, 2012 7:00 - 12:00		Feb 20, 2012 9:20 - 9:30				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <1/2>

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 21, 2012 7:00 - 12:00		Feb 21, 2012 9:25 - 9:35				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 9E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <2/2>

Place of Sampling	Fukushima Daiichi MP-1		Fukushima Daiichi MP-3		Fukushima Daiichi MP-8		②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 21, 2012 9:29 - 14:29		Feb 21, 2012 9:02 - 14:02		Feb 21, 2012 9:13 - 14:13		
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 2E-7Bq/cm³, Cs-134: approx. 4E-7Bq/cm³, Cs-137: approx. 5E-7Bq/cm³

Particulate: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <1/2>

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Time of Sampling		Time of Sampling				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 5E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <2/2>

Place of Sampling	North Side Slope of Fukushima Daiichi Unit 1		West Side Slope of Fukushima Daiichi Unit 1 & 2		West Side Slope of Fukushima Daiichi Unit 3 & 4		②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Time of Sampling		Time of Sampling		Time of Sampling		
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 5E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the seaside of the sites of Fukushima Nuclear Power Stations

Place of Sampling	Fukushima Daiichi Unit 1 -4 Sea Side						②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 22, 2012 8:34 - 13:34						
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-					1E-03
Cs-134 (about 2 years)	ND	-					2E-03
Cs-137 (about 30 years)	ND	-					3E-03
Nb-95 (approx.35days)	ND	-					2E-02
Tc-99m (approx.6hrs)	ND	-					7E-01
Ag-110m (approx.250days)	ND	-					3E-03
Sb-125 (approx.3yrs)	ND	-					6E-03
Te-129 (approx.70mins)	ND	-					4E-01
Te-129m (approx.34days)	ND	-					4E-03
I-132 (approx.2hrs)	ND	-					7E-02
Te-132 (approx.78hrs)	ND	-					4E-03
I-133 (approx.21hrs)	ND	-					5E-03
Cs-136 (approx.13days)	ND	-					1E-02
Ba-140 (approx.13days)	ND	-					1E-02
La-140 (approx.40hrs)	ND	-					1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 2E-7Bq/cm³, Cs-134: approx. 4E-7Bq/cm³, Cs-137: approx. 5E-7Bq/cm³

Particulate: I-131: approx. 9E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Feb 23, 2012 7:00 - 12:00		Feb 23, 2012 9:11 - 9:21				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 9E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Feb 24, 2012 7:00 - 12:00		Feb 24, 2012 9:35 - 9:45				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

 Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 25, 2012 7:00 - 12:00		Feb 25, 2012 9:23 - 9:33				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 1E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 26, 2012 7:00 - 12:00		Feb 26, 2012 9:19 - 9:29				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Particulate: I-131: approx. 6E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 27, 2012 7:00 - 12:00		Feb 27, 2012 9:18 - 9:28				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as fc

Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 1E-6Bq/cm³, Cs-137: approx. 2E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <1/2>

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
	Time of Sampling		Time of Sampling				
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132 (approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

West Gate of Fukushima Daiichi NPSにおけるThe detection limits of major three nuclide that are not detected are as follows:

 Volatile: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

 Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

The detection limits of three major nuclide that are not detected at MP-1 of Fukushima Daini NPP are as follows:

 Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, Cs-137: approx. 3E-6Bq/cm³

 Particulate: I-131: approx. 9E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 1E-6Bq/cm³

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the Sites of Fukushima Nuclear Power Stations <2/2>

Place of Sampling	Fukushima Daiichi MP-1		Fukushima Daiichi MP-3		Fukushima Daiichi MP-8		②Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation in section 4 of appendix 2)
Time of Sampling	Feb 28, 2012 9:16 - 14:16		Feb 28, 2012 8:47 - 13:47		Feb 28, 2012 8:59 - 13:59		
Detected Nuclides (Half-life)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	①density of sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	5.2E-07	0.00	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* When the radioactivity density is below the detection limit, it shows "ND" which means "Not Detectable".

The detection limits of major three nuclide that are not detected are as follows:

Volatile: I-131: approx. 2E-7Bq/cm³, Cs-134: approx. 4E-7Bq/cm³, Cs-137: approx. 5E-7Bq/cm³

Particulate: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 3E-7Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 15, 2012 8:35 AM		Feb 15, 2012 8:20 AM		Feb 15, 2012 8:35 AM		Feb 15, 2012 8:10 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.4	0.02	1.2	0.02	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	1.5	0.02	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.76Bq/L, Cs-134: approx. 0.93Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 1/3>

Place of Sampling	3 km offshore of Haramachi Ward Upper Layer		3 km offshore of Haramachi Ward Lower Layer		3 km offshore of Odaka Ward Upper Layer		3 km offshore of Odaka Ward Lower Layer		3 km offshore of Iwasawa shore Upper Layer		3 km offshore of Iwasawa shore Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 14, 2012 10:25 AM		Feb 14, 2012 10:25 AM		Feb 14, 2012 10:10 AM		Feb 14, 2012 10:10 AM		Feb 14, 2012 8:20 AM		Feb 14, 2012 8:20 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.63Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 2/3>

Place of Sampling	8 km offshore of Odaka Ward Upper Layer		8 km offshore of Odaka Ward Lower Layer		8 km offshore of Iwasawa shore Upper Layer		8 km offshore of Iwasawa shore Lower Layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 14, 2012 9:50 AM		Feb 14, 2012 9:50 AM		Feb 14, 2012 8:45 AM		Feb 14, 2012 8:45 AM						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-					300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-					200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.64Bq/L, Cs-134: approx. 0.88Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 3/3>

Place of Sampling	3 km offshore of Souma City Upper Layer		3 km offshore of Souma City Lower Layer		5 km offshore of Souma City Upper Layer		5 km offshore of Souma City Lower Layer		5 km offshore of Kashima Upper Layer		5 km offshore of Kashima Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 14, 2012 6:30 AM		Feb 14, 2012 6:30 AM		Feb 14, 2012 6:50 AM		Feb 14, 2012 6:50 AM		Feb 14, 2012 7:10 AM		Feb 14, 2012 7:10 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.63Bq/L, Cs-134: approx. 0.95Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 16, 2012 8:40 AM		Feb 16, 2012 8:20 AM		Feb 16, 2012 8:30 AM		Feb 16, 2012 8:05 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	1.8	0.03	ND	-	ND	-	60
Cs-137 (about 30 years)	1.1	0.01	2.5	0.03	ND	-	1.1	0.01	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.71Bq/L, Cs-134: approx. 0.90Bq/L, Cs-137: approx. 0.98Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 1/4 >

Place of Sampling	15 km offshore of Minami-Souma City Upper Layer		15 km offshore of Minami-Souma City Lower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 15, 2012 (Not sampled)		Feb 15, 2012 (Not sampled)		Feb 15, 2012 10:15 AM		Feb 15, 2012 10:15 AM		Feb 15, 2012 9:45 AM		Feb 15, 2012 9:45 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.66Bq/L, Cs-134: approx. 0.84Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 2/4 >

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 15, 2012 9:05 AM		Feb 15, 2012 9:05 AM		Feb 15, 2012 8:20 AM		Feb 15, 2012 8:20 AM		Feb 15, 2012 8:15 AM		Feb 15, 2012 8:15 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.69Bq/L, Cs-134: approx. 0.92Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 3/4 >

Place of Sampling	3 km offshore of North of Iwaki Upper Layer		3 km offshore of North of Iwaki Lower Layer		3 km offshore of Natsui river Upper Layer		3 km offshore of Natsui river Lower Layer		3 km offshore of Onahama port Upper Layer		3 km offshore of Onahama port Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	N/A		N/A		N/A		N/A		Feb 15, 2012 6:40 AM		Feb 15, 2012 6:40 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.73Bq/L, Cs-134: approx. 0.85Bq/L, Cs-137: approx. 0.97Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 4/4 >

Place of Sampling	3 km offshore of Ena Upper Layer		3 km offshore of Ena Lower Layer		3 km offshore of Numanouchi Upper Layer		3 km offshore of Numanouchi Lower Layer		3 km offshore of Toyoma Upper Layer		3 km offshore of Toyoma Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 15, 2012 7:00 AM		Feb 15, 2012 7:00 AM		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.68Bq/L, Cs-134: approx. 0.95Bq/L, Cs-137: approx. 1.0Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 17, 2012 8:50 AM		Feb 17, 2012 8:35 AM		Feb 17, 2012 8:40 AM		Feb 17, 2012 8:10 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	15	0.25	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	21	0.23	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.0Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 1/4 >

Place of Sampling	15 km offshore of Minami-Souma CityUpper Layer		15 km offshore of Minami-Souma CityLower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 16, 2012 (Not sampled)		Feb 16, 2012 (Not sampled)		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129(approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140(approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 2/4 >

Place of Sampling	3 km offshore of Haramachi Ward Upper Layer		3 km offshore of Haramachi Ward Lower Layer		3 km offshore of Odaka Ward Upper Layer		3 km offshore of Odaka Ward Lower Layer		3 km offshore of Iwasawa shore Upper Layer		3 km offshore of Iwasawa shore Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Feb 16, 2012 (Not sampled)		Feb 16, 2012 (Not sampled)		Feb 16, 2012 (Not sampled)		Feb 16, 2012 (Not sampled)		Feb 16, 2012 8:40 AM		Feb 16, 2012 8:40 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.56Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 3/4 >

Place of Sampling	8 km offshore of Odaka Ward Upper Layer		8 km offshore of Odaka Ward Lower Layer		8 km offshore of Iwasawa shore Upper Layer		8 km offshore of Iwasawa shore Lower Layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 16, 2012 (Not sampled)		Feb 16, 2012 (Not sampled)		Feb 16, 2012 9:05 AM		Feb 16, 2012 9:05 AM						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	ND	-					40
Cs-134 (about 2 years)	-	-	-	-	ND	-	ND	-					60
Cs-137 (about 30 years)	-	-	-	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	-	-	-	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	-	-	-	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	-	-	-	-	ND	-	ND	-					300
Te-129 (approx.70mins)	-	-	-	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	-	-	-	-	ND	-	ND	-					200
I-132 (approx.2hrs)	-	-	-	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	-	-	-	-	ND	-	ND	-					300
Ba-140 (approx.13days)	-	-	-	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	-	-	-	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.66Bq/L, Cs-134: approx. 0.85Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 4/4 >

Place of Sampling	5km Offshore of Numanouchi Upper Layer		5km Offshore of Numanouchi Lower Layer										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 16, 2012 7:15 AM		Feb 16, 2012 7:15 AM										
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-									40
Cs-134 (about 2 years)	ND	-	ND	-									60
Cs-137 (about 30 years)	ND	-	ND	-									90
Mo-99 (approx. 66hrs)	ND	-	ND	-									1,000
Tc-99m (approx.6hrs)	ND	-	ND	-									40,000
Te-129m (approx.34days)	ND	-	ND	-									300
Te-129 (approx.70mins)	ND	-	ND	-									10,000
Te-132 (approx.78hrs)	ND	-	ND	-									200
I-132 (approx.2hrs)	ND	-	ND	-									3,000
Cs-136 (approx.13days)	ND	-	ND	-									300
Ba-140 (approx.13days)	ND	-	ND	-									300
La-140 (approx. 40hrs)	ND	-	ND	-									400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.73Bq/L, Cs-134: approx. 0.86Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 18, 2012 8:40 AM		Feb 18, 2012 8:20 AM		Feb 18, 2012 8:15 AM		Feb 18, 2012 7:55 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	0.83	0.01	2.0	0.03	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	3.5	0.04	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.68Bq/L, Cs-134: approx. 0.80Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 1/2>

Place of Sampling	15 km offshore of Minami-Souma City Upper Layer		15 km offshore of Minami-Souma City Lower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 2/2>

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 17, 2012 (Not sampled)		Feb 17, 2012 (Not sampled)		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 19, 2012 8:45 AM		Feb 19, 2012 8:20 AM		Feb 19, 2012 8:20 AM		Feb 19, 2012 8:00 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.2	0.02	1.2	0.02	ND	-	ND	-	60
Cs-137 (about 30 years)	1.9	0.02	1.5	0.02	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.71Bq/L, Cs-134: approx. 0.82Bq/L, Cs-137: approx. 0.96Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 1/2>

Place of Sampling	3 km offshore of Haramachi Ward Upper Layer		3 km offshore of Haramachi Ward Lower Layer		3 km offshore of Odaka Ward Upper Layer		3 km offshore of Odaka Ward Lower Layer		3 km offshore of Iwasawa shore Upper Layer		3 km offshore of Iwasawa shore Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 18, 2012 10:05 AM		Feb 18, 2012 10:05 AM		Feb 18, 2012 9:45 AM		Feb 18, 2012 9:45 AM		Feb 18, 2012 8:00 AM		Feb 18, 2012 8:00 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.69Bq/L, Cs-134: approx. 0.90Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 2/2>

Place of Sampling	8 km offshore of Odaka Ward Upper Layer		8 km offshore of Odaka Ward Lower Layer		8 km offshore of Iwasawa shore Upper Layer		8 km offshore of Iwasawa shore Lower Layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 18, 2012 10:25 AM		Feb 18, 2012 10:25 AM		Feb 18, 2012 8:20 AM		Feb 18, 2012 8:20 AM						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-					300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-					200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.69Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.0Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 20, 2012 8:40 AM		Feb 20, 2012 8:20 AM		Feb 20, 2012 8:20 AM		Feb 20, 2012 8:00 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	1.0	0.02	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	2.2	0.02	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.73Bq/L, Cs-134: approx. 0.91Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 1/2>

Place of Sampling	15 km offshore of Minami-Souma City Upper Layer		15 km offshore of Minami-Souma City Lower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 19, 2012 11:55 AM		Feb 19, 2012 11:55 AM		Feb 19, 2012 9:05 AM		Feb 19, 2012 9:05 AM		Feb 19, 2012 8:45 AM		Feb 19, 2012 8:45 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.71Bq/L, Cs-134: approx. 0.91Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 2/2>

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 19, 2012 8:10 AM		Feb 19, 2012 8:10 AM		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.73Bq/L, Cs-134: approx. 0.86Bq/L, Cs-137: approx. 1.0Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore remeasurement >

Place of Sampling	15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daini Upper Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 13, 2012 8:50 AM		Feb 15, 2012 9:05 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	90
Mn-54 (approx.310days)	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	200
Ce-144 (approx. 280 days)	ND	-	ND	-	200
Mo-99 (approx. 66hrs)	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of three major nuclide, Mn-54, Co-60 and Ce-144 that are not detected are as follows: I-131: approx. 0.18Bq/L, Cs-134: approx. 0.25Bq/L, Cs-137: approx. 0.30Bq/L, Mn-54: approx. 0.12Bq/L, Co-60: approx. 0.13Bq/L, Ce-144: approx. 1.0Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 21, 2012 8:40 AM		Feb 21, 2012 8:20 AM		Feb 21, 2012 8:30 AM		Feb 21, 2012 8:05 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.1	0.02	2.7	0.05	ND	-	ND	-	60
Cs-137 (about 30 years)	2.4	0.03	2.5	0.03	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.71Bq/L, Cs-134: approx. 0.88Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 1/4 >

Place of Sampling	3 km offshore of Haramachi Ward Upper Layer		3 km offshore of Haramachi Ward Lower Layer		3 km offshore of Odaka Ward Upper Layer		3 km offshore of Odaka Ward Lower Layer		3 km offshore of Iwasawa shore Upper Layer		3 km offshore of Iwasawa shore Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 20, 2012 10:05 AM		Feb 20, 2012 10:05 AM		Feb 20, 2012 9:45 AM		Feb 20, 2012 9:45 AM		Feb 20, 2012 7:45 AM		Feb 20, 2012 7:45 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.64Bq/L, Cs-134: approx. 0.91Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 2/4 >

Place of Sampling	8 km offshore of Odaka Ward Upper Layer		8 km offshore of Odaka Ward Lower Layer		8 km offshore of Iwasawa shore Upper Layer		8 km offshore of Iwasawa shore Lower Layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 20, 2012 9:25 AM		Feb 20, 2012 9:25 AM		Feb 20, 2012 8:10 AM		Feb 20, 2012 8:10 AM						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-					300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-					200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.64Bq/L, Cs-134: approx. 0.95Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 3/4 >

Place of Sampling	3 km offshore of North of Iwaki Upper Layer		3 km offshore of North of Iwaki Lower Layer		3 km offshore of Natsui river Upper Layer		3 km offshore of Natsui river Lower Layer		3 km offshore of Onahama port Upper Layer		3 km offshore of Onahama port Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 20, 2012 6:35 AM		Feb 20, 2012 6:35 AM		Feb 20, 2012 7:00 AM		Feb 20, 2012 7:00 AM		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.66Bq/L, Cs-134: approx. 0.92Bq/L, Cs-137: approx. 0.99Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 4/4 >

Place of Sampling	3 km offshore of Ena Upper Layer		3 km offshore of Ena Lower Layer		3 km offshore of Numanouchi Upper Layer		3 km offshore of Numanouchi Lower Layer		3 km offshore of Toyoma Upper Layer		3 km offshore of Toyoma Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	N/A		N/A		Feb 20, 2012 7:10 AM		Feb 20, 2012 7:10 AM		Feb 20, 2012 7:20 AM		Feb 20, 2012 7:20 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.1Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore Unmanned Survey Ship >

Place of Sampling	50 m from the center of the north side seawall, Fukushima Daiichi		50 m from the center of the south side seawall, Fukushima Daiichi										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling		Time of Sampling										
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
	I-131 (about 8 days)	ND	-	ND	-								
Cs-134 (about 2 years)	1.1	0.02	0.85	0.01									60
Cs-137 (about 30 years)	2.0	0.02	1.2	0.01									90
Mo-99 (approx. 66hrs)	ND	-	ND	-									1,000
Tc-99m (approx.6hrs)	ND	-	ND	-									40,000
Te-129m (approx.34days)	ND	-	ND	-									300
Te-129 (approx.70mins)	ND	-	ND	-									10,000
Te-132 (approx.78hrs)	ND	-	ND	-									200
I-132 (approx.2hrs)	ND	-	ND	-									3,000
Cs-136 (approx.13days)	ND	-	ND	-									300
Ba-140 (approx.13days)	ND	-	ND	-									300
La-140 (approx. 40hrs)	ND	-	ND	-									400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.64Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 22, 2012 8:45 AM	Feb 22, 2012 8:30 AM	Feb 22, 2012 8:30 AM	Feb 22, 2012 8:05 AM				
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.2	0.02	1.2	0.02	ND	-	ND	-	60
Cs-137 (about 30 years)	1.4	0.02	2.5	0.03	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.66Bq/L, Cs-134: approx. 0.89Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 1/3>

Place of Sampling	15 km offshore of Minami-Souma City Upper Layer		15 km offshore of Minami-Souma City Lower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	N/A		N/A		Feb 21, 2012 9:05 AM		Feb 21, 2012 9:05 AM		Feb 21, 2012 8:35 AM		Feb 21, 2012 8:35 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.61Bq/L, Cs-134: approx. 0.93Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 2/3>

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 21, 2012 8:05 AM		Feb 21, 2012 8:05 AM		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.61Bq/L, Cs-134: approx. 0.85Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore 3/3>

Place of Sampling	3 km offshore of Souma City Upper Layer		3 km offshore of Souma City Lower Layer		5 km offshore of Souma City Upper Layer		5 km offshore of Souma City Lower Layer		5 km offshore of Kashima Upper Layer		5 km offshore of Kashima Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 21, 2012 6:40 AM		Feb 21, 2012 6:40 AM		Feb 21, 2012 6:55 AM		Feb 21, 2012 6:55 AM		Feb 21, 2012 7:10 AM		Feb 21, 2012 7:10 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.70Bq/L, Cs-134: approx. 0.96Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 23, 2012 8:30 AM		Feb 23, 2012 8:10 AM		Feb 23, 2012 8:30 AM		Feb 23, 2012 8:05 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.5	0.03	1.6	0.03	ND	-	ND	-	60
Cs-137 (about 30 years)	3.4	0.04	2.4	0.03	ND	-	1.6	0.02	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.74Bq/L, Cs-134: approx. 0.92Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 1/4 >

Place of Sampling	15 km offshore of Minami-Souma City Upper Layer		15 km offshore of Minami-Souma City Lower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
Time of Sampling	Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)													
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 2/4 >

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	N/A		N/A		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		
Time of Sampling	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 3/4 >

Place of Sampling	3 km offshore of Haramachi Ward Upper Layer		3 km offshore of Haramachi Ward Lower Layer		3 km offshore of Odaka Ward Upper Layer		3 km offshore of Odaka Ward Lower Layer		3 km offshore of Iwasawa shore Upper Layer		3 km offshore of Iwasawa shore Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 4/4 >

Place of Sampling	8 km offshore of Odaka Ward Upper Layer		8 km offshore of Odaka Ward Lower Layer		8 km offshore of Iwasawa shore Upper Layer		8 km offshore of Iwasawa shore Lower Layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)		Feb 22, 2012 (Not sampled)						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-					40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-					60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-					90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-					1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-					40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-					300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-					10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-					200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-					3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-					300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-					300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 24, 2012 8:25 AM		Feb 24, 2012 8:05 AM		Feb 24, 2012 8:25 AM		Feb 24, 2012 8:00 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	7.3	0.12	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	12	0.13	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.86Bq/L, Cs-134: approx. 0.92Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 1/4 >

Place of Sampling	15 km offshore of Minami-Souma CityUpper Layer		15 km offshore of Minami-Souma CityLower Layer		15 km offshore of Ukedo-gawa Upper Layer		15 km offshore of Ukedo-gawa Lower Layer		15 km offshore of Fukushima Daiichi Upper Layer		15 km offshore of Fukushima Daiichi Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129(approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140(approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 2/4 >

Place of Sampling	approx. 15 km offshore of Fukushima Daini Upper Layer		approx. 15 km offshore of Fukushima Daini Lower Layer		15 km offshore of Iwasawa Shore Upper Layer		15 km offshore of Iwasawa Shore Lower Layer		15 km offshore of Hirono-town Upper Layer		15 km offshore of Hirono-town Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		Feb 23, 2012 (Not sampled)		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 3/4 >

Place of Sampling	3 km offshore of North of Iwaki Upper Layer		3 km offshore of North of Iwaki Lower Layer		3 km offshore of Natsui river Upper Layer		3 km offshore of Natsui river Lower Layer		3 km offshore of Onahama port Upper Layer		3 km offshore of Onahama port Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	N/A		N/A		N/A		N/A		Feb 23, 2012 6:30 AM		Feb 23, 2012 6:30 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Te-129 (approx.70mins)	-	-	-	-	-	-	-	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	200
I-132 (approx.2hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
Ba-140 (approx.13days)	-	-	-	-	-	-	-	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	-	-	-	-	-	-	-	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.62Bq/L, Cs-134: approx. 0.96Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【 Definite Report 】 Nuclide Analysis Results of Radioactive Materials in Seawater < offshore 4/4 >

Place of Sampling	3 km offshore of Ena Upper Layer		3 km offshore of Ena Lower Layer		3 km offshore of Numanouchi Upper Layer		3 km offshore of Numanouchi Lower Layer		3 km offshore of Toyoma Upper Layer		3 km offshore of Toyoma Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
Time of Sampling	Feb 23, 2012 6:45 AM		Feb 23, 2012 6:45 AM		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)													
I-131 (about 8 days)	ND	-	ND	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	ND	-	ND	-	-	-	-	-	-	-	-	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	-	-	-	-	-	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	-	-	-	-	-	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	-	-	-	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.75Bq/L, Cs-134: approx. 0.92Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 25, 2012 8:40 AM		Feb 25, 2012 8:20 AM		Feb 25, 2012 (Not sampled)		Feb 25, 2012 8:00 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	ND	-	40
Cs-134 (about 2 years)	1.9	0.03	1.4	0.02	-	-	ND	-	60
Cs-137 (about 30 years)	1.5	0.02	1.4	0.02	-	-	1.1	0.01	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.72Bq/L, Cs-134: approx. 0.86Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 26, 2012 8:40 AM		Feb 26, 2012 8:20 AM		Feb 26, 2012 (Not sampled)		Feb 26, 2012 7:55 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	ND	-	40
Cs-134 (about 2 years)	1.0	0.02	1.1	0.02	-	-	1.0	0.02	60
Cs-137 (about 30 years)	1.4	0.02	1.7	0.02	-	-	1.3	0.01	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.69Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 27, 2012 8:40 AM		Feb 27, 2012 8:20 AM		Feb 27, 2012 (Not sampled)		Feb 27, 2012 8:00 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	-	-	ND	-	40
Cs-134 (about 2 years)	0.89	0.01	0.88	0.01	-	-	1.2	0.02	60
Cs-137 (about 30 years)	1.2	0.01	ND	-	-	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	-	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	-	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	-	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	-	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	-	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	-	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	-	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.70Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Coast>

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 28, 2012 8:40 AM		Feb 28, 2012 8:20 AM		Feb 28, 2012 8:20 AM		Feb 28, 2012 8:00 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	1.5	0.03	0.90	0.02	ND	-	ND	-	60
Cs-137 (about 30 years)	2.3	0.03	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.68Bq/L, Cs-134: approx. 0.84Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 15, 2012 6:51 AM		Feb 15, 2012 6:54 AM		Feb 15, 2012 6:56 AM		Feb 15, 2012 6:58 AM		Feb 15, 2012 7:00 AM		Feb 15, 2012 7:03 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	21	0.35	22	0.37	43	0.72	28	0.47	83	1.4	60
Cs-137 (about 30 years)	ND	-	ND	-	35	0.39	50	0.56	30	0.33	130	1.4	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 18Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 15, 2012 7:06 AM	Feb 15, 2012 7:10 AM	Feb 15, 2012 7:06 AM	Feb 15, 2012 7:10 AM	Feb 15, 2012 7:12 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	67	1.1	260	4.3	36	0.60	67	1.1	ND	-	-	-	60
Cs-137 (about 30 years)	84	0.93	330	3.7	38	0.42	110	1.2	54	0.60	-	-	90
Mn-54 (approx.310 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 15Bq/L, Cs-134: approx. 20Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 16, 2012 6:52 AM		Feb 16, 2012 6:55 AM		Feb 16, 2012 6:58 AM		Feb 16, 2012 7:00 AM		Feb 16, 2012 7:04 AM		Feb 16, 2012 7:06 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	31	0.52	100	1.7	60
Cs-137 (about 30 years)	ND	-	26	0.29	48	0.53	32	0.36	44	0.49	100	1.1	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 24Bq/L, Cs-137: approx. 24Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 16, 2012 7:09 AM	Feb 16, 2012 7:11 AM	Feb 16, 2012 7:13 AM	Feb 16, 2012 7:15 AM	Feb 16, 2012 7:18 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	62	1.0	160	2.7	60	1.0	64	1.1	41	0.68	-	-	60
Cs-137 (about 30 years)	100	1.1	220	2.4	79	0.88	81	0.90	48	0.53	-	-	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 17, 2012 6:54 AM		Feb 17, 2012 7:00 AM		Feb 17, 2012 7:03 AM		Feb 17, 2012 7:06 AM		Feb 17, 2012 7:10 AM		Feb 17, 2012 7:12 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	34	0.57	41	0.68	36	0.60	57	0.95	60
Cs-137 (about 30 years)	ND	-	30	0.33	37	0.41	60	0.67	48	0.53	110	1.2	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 27Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 17, 2012 7:16 AM	Feb 17, 2012 7:18 AM	Feb 17, 2012 7:21 AM	Feb 17, 2012 7:23 AM	Feb 17, 2012 7:27 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	42	0.70	130	2.2	75	1.3	84	1.4	27	0.45	-	-	60
Cs-137 (about 30 years)	51	0.57	180	2.0	92	1.0	120	1.3	47	0.52	-	-	90
Mn-54 (approx.310 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 16Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 18, 2012 7:37 AM		Feb 18, 2012 7:43 AM		Feb 18, 2012 7:46 AM		Feb 18, 2012 7:48 AM		Feb 18, 2012 7:51 AM		Feb 18, 2012 7:53 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	21	0.35	31	0.52	24	0.40	68	1.1	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	64	0.71	39	0.43	84	0.93	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 12Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 28Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 18, 2012 7:56 AM	Feb 18, 2012 7:58 AM	Feb 18, 2012 8:00 AM	Feb 18, 2012 8:02 AM	Feb 18, 2012 8:05 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	71	1.2	120	2.0	41	0.68	52	0.87	41	0.68	-	-	60
Cs-137 (about 30 years)	73	0.81	180	2.0	77	0.86	100	1.1	68	0.76	-	-	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 14Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 19, 2012 7:20 AM		Feb 19, 2012 7:24 AM		Feb 19, 2012 7:28 AM		Feb 19, 2012 7:32 AM		Feb 19, 2012 7:34 AM		Feb 19, 2012 7:37 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	37	0.62	67	1.1	120	2.0	60
Cs-137 (about 30 years)	ND	-	32	0.36	33	0.37	45	0.50	89	0.99	110	1.2	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 19, 2012 7:41 AM	Feb 19, 2012 7:46 AM	Feb 19, 2012 7:41 AM	Feb 19, 2012 7:46 AM	Feb 19, 2012 7:50 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	63	1.1	170	2.8	67	1.1	110	1.8	30	0.50	-	-	60
Cs-137 (about 30 years)	92	1.0	230	2.6	98	1.1	150	1.7	70	0.78	-	-	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 15Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 20, 2012 7:06 AM		Feb 20, 2012 7:15 AM		Feb 20, 2012 7:20 AM		Feb 20, 2012 7:23 AM		Feb 20, 2012 7:27 AM		Feb 20, 2012 7:30 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	43	0.72	46	0.77	36	0.60	62	1.0	110	1.8	60
Cs-137 (about 30 years)	ND	-	40	0.44	52	0.58	43	0.48	76	0.84	170	1.9	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 20Bq/L, Cs-137: approx. 24Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 20, 2012 7:37 AM	Feb 20, 2012 7:40 AM	Feb 20, 2012 12:53 PM	Feb 20, 2012 7:45 AM	Feb 20, 2012 7:49 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	77	1.3	210	3.5	53	0.88	120	2.0	75	1.3	-	-	60
Cs-137 (about 30 years)	94	1.0	270	3.0	63	0.70	160	1.8	99	1.1	-	-	90
Mn-54 (approx.310 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 14Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 21, 2012 7:39 AM		Feb 21, 2012 7:47 AM		Feb 21, 2012 7:52 AM		Feb 21, 2012 7:55 AM		Feb 21, 2012 8:00 AM		Feb 21, 2012 8:03 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	30	0.50	27	0.45	74	1.2	94	1.6	60
Cs-137 (about 30 years)	ND	-	29	0.32	35	0.39	27	0.30	72	0.80	140	1.6	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 28Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 21, 2012 8:10 AM	Feb 21, 2012 8:13 AM	Feb 21, 2012 8:16 AM	Feb 21, 2012 8:19 AM	Feb 21, 2012 8:24 AM	Feb 21, 2012 8:50 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	43	0.72	220	3.7	90	1.5	86	1.4	30	0.50	ND	-	60
Cs-137 (about 30 years)	71	0.79	320	3.6	110	1.2	130	1.4	44	0.49	ND	-	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Feb 22, 2012 6:31 AM		Feb 22, 2012 10:00 AM		Feb 22, 2012 6:40 AM		Feb 22, 2012 1:45 PM		Feb 22, 2012 6:46 AM		Feb 22, 2012 6:50 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	23	0.38	ND	-	21	0.35	37	0.62	60
Cs-137 (about 30 years)	ND	-	ND	-	34	0.38	33	0.37	44	0.49	44	0.49	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 10Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 22, 2012 6:56 AM	Feb 22, 2012 6:59 AM	Feb 22, 2012 7:05 AM	Feb 22, 2012 7:08 AM	Feb 22, 2012 7:13 AM	Feb 22, 2012 7:17 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	43	0.72	110	1.8	49	0.82	200	3.3	50	0.83	73	1.2	60
Cs-137 (about 30 years)	45	0.50	160	1.8	84	0.93	270	3.0	50	0.56	85	0.94	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 16Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 22, 2012 7:22 AM		Feb 22, 2012 7:20 AM		N/A								
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	-	-							40
Cs-134 (about 2 years)	54	0.90	19	0.32	-	-							60
Cs-137 (about 30 years)	58	0.64	24	0.27	-	-							90
Mn-54 (approx.310d ays)	ND	-	ND	-	-	-							1,000
Co-60 (approx.5yrs)	ND	-	ND	-	-	-							200
Tc-99m (approx.6hrs)	ND	-	ND	-	-	-							40,000
Te-129m (approx.34day s)	ND	-	ND	-	-	-							300
Te- 129(approx.7 0mins)	ND	-	ND	-	-	-							10,000
Cs-136 (approx.13day s)	ND	-	ND	-	-	-							300
Ba-140 (approx.13day s)	ND	-	ND	-	-	-							300
La-140 (approx.40hrs)	ND	-	ND	-	-	-							400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 10Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Feb 23, 2012 6:22 AM		Feb 23, 2012 10:50 AM		Feb 23, 2012 6:27 AM		Feb 23, 2012 3:30 PM		Feb 23, 2012 6:31 AM		Feb 23, 2012 6:34 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	24	0.40	33	0.55	24	0.40	28	0.47	60
Cs-137 (about 30 years)	ND	-	ND	-	46	0.51	29	0.32	39	0.43	52	0.58	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 23, 2012 6:36 AM	Feb 23, 2012 6:39 AM	Feb 23, 2012 6:42 AM	Feb 23, 2012 6:45 AM	Feb 23, 2012 6:48 AM	Feb 23, 2012 6:50 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	27	0.45	140	2.3	ND	-	110	1.8	38	0.63	130	2.2	60
Cs-137 (about 30 years)	45	0.50	190	2.1	30	0.33	180	2.0	69	0.77	170	1.9	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 23Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 23, 2012 6:54 AM		N/A		N/A							
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	-	-							40
Cs-134 (about 2 years)	35	0.58	-	-	-	-							60
Cs-137 (about 30 years)	47	0.52	-	-	-	-							90
Mn-54 (approx.310d ays)	ND	-	-	-	-	-							1,000
Co-60 (approx.5yrs)	ND	-	-	-	-	-							200
Tc-99m (approx.6hrs)	ND	-	-	-	-	-							40,000
Te-129m (approx.34day s)	ND	-	-	-	-	-							300
Te- 129(approx.7 0mins)	ND	-	-	-	-	-							10,000
Cs-136 (approx.13day s)	ND	-	-	-	-	-							300
Ba-140 (approx.13day s)	ND	-	-	-	-	-							300
La-140 (approx.40hrs)	ND	-	-	-	-	-							400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 24, 2012 6:24 AM		Feb 24, 2012 11:30 AM		Feb 24, 2012 6:27 AM		Feb 24, 2012 4:30 PM		Feb 24, 2012 6:34 AM		Feb 24, 2012 6:36 AM	
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	26	0.43	27	0.45	22	0.37	24	0.40	60
Cs-137 (about 30 years)	ND	-	ND	-	34	0.38	28	0.31	40	0.44	48	0.53	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 12Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 27Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 24, 2012 6:38 AM	Feb 24, 2012 6:40 AM	Feb 24, 2012 6:43 AM	Feb 24, 2012 6:45 AM	Feb 24, 2012 6:47 AM	Feb 24, 2012 6:49 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	28	0.47	76	1.3	ND	-	94	1.6	46	0.77	60	1.0	60
Cs-137 (about 30 years)	40	0.44	110	1.2	45	0.50	120	1.3	67	0.74	61	0.68	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L, Cs-134: approx. 22Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
Time of Sampling	Feb 24, 2012 6:51 AM		N/A		N/A								
Detected Nuclides (Half-life)	ND	-	-	-	-	-							40
I-131 (about 8 days)	28	0.47	-	-	-	-							60
Cs-134 (about 2 years)	37	0.41	-	-	-	-							90
Cs-137 (about 30 years)	ND	-	-	-	-	-							1,000
Mn-54 (approx.310d ays)	ND	-	-	-	-	-							200
Co-60 (approx.5yrs)	ND	-	-	-	-	-							40,000
Tc-99m (approx.6hrs)	ND	-	-	-	-	-							300
Te-129m (approx.34day s)	ND	-	-	-	-	-							10,000
Te- 129(approx.7 0mins)	ND	-	-	-	-	-							300
Cs-136 (approx.13day s)	ND	-	-	-	-	-							300
Ba-140 (approx.13day s)	ND	-	-	-	-	-							400
La-140 (approx.40hrs)													

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 10Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 25, 2012 7:04 AM		N/A		Feb 25, 2012 7:08 AM		N/A		Feb 25, 2012 7:12 AM		Feb 25, 2012 7:13 AM	
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	-	-	ND	-	-	-	ND	-	44	0.73	60
Cs-137 (about 30 years)	ND	-	-	-	32	0.36	-	-	36	0.40	61	0.68	90
Mn-54 (approx.310days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 24Bq/L, Cs-137: approx. 24Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 25, 2012 7:16 AM	Feb 25, 2012 7:18 AM	Feb 25, 2012 7:21 AM	Feb 25, 2012 7:24 AM	Feb 25, 2012 7:22 AM	Feb 25, 2012 7:25 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	40	0.67	88	1.5	52	0.87	170	2.8	29	0.48	55	0.92	60
Cs-137 (about 30 years)	47	0.52	130	1.4	61	0.68	190	2.1	46	0.51	72	0.80	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 12Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 25, 2012 7:28 AM		N/A		N/A								
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	-	-							40
Cs-134 (about 2 years)	ND	-	-	-	-	-							60
Cs-137 (about 30 years)	36	0.40	-	-	-	-							90
Mn-54 (approx.310d ays)	ND	-	-	-	-	-							1,000
Co-60 (approx.5yrs)	ND	-	-	-	-	-							200
Tc-99m (approx.6hrs)	ND	-	-	-	-	-							40,000
Te-129m (approx.34day s)	ND	-	-	-	-	-							300
Te- 129(approx.7 0mins)	ND	-	-	-	-	-							10,000
Cs-136 (approx.13day s)	ND	-	-	-	-	-							300
Ba-140 (approx.13day s)	ND	-	-	-	-	-							300
La-140 (approx.40hrs)	ND	-	-	-	-	-							400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 23Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 26, 2012 7:08 AM		N/A		Feb 26, 2012 7:15 AM		N/A		Feb 26, 2012 7:18 AM		Feb 26, 2012 7:20 AM	
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	-	-	27	0.45	-	-	45	0.75	44	0.73	60
Cs-137 (about 30 years)	32	0.36	-	-	59	0.66	-	-	52	0.58	63	0.70	90
Mn-54 (approx.310days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	-	-	ND	-	-	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 20Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 26, 2012 7:22 AM	Feb 26, 2012 7:26 AM	Feb 26, 2012 7:27 AM	Feb 26, 2012 7:29 AM	Feb 26, 2012 7:28 AM	Feb 26, 2012 7:32 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	32	0.53	77	1.3	34	0.57	180	3.0	74	1.2	87	1.5	60
Cs-137 (about 30 years)	40	0.44	100	1.1	43	0.48	210	2.3	96	1.1	100	1.1	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 13Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 26, 2012 7:42 AM		N/A		N/A							
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	-	-							40
Cs-134 (about 2 years)	ND	-	-	-	-	-							60
Cs-137 (about 30 years)	ND	-	-	-	-	-							90
Mn-54 (approx.310d ays)	ND	-	-	-	-	-							1,000
Co-60 (approx.5yrs)	ND	-	-	-	-	-							200
Tc-99m (approx.6hrs)	ND	-	-	-	-	-							40,000
Te-129m (approx.34day s)	ND	-	-	-	-	-							300
Te- 129(approx.7 0mins)	ND	-	-	-	-	-							10,000
Cs-136 (approx.13day s)	ND	-	-	-	-	-							300
Ba-140 (approx.13day s)	ND	-	-	-	-	-							300
La-140 (approx.40hrs)	ND	-	-	-	-	-							400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 24Bq/L, Cs-137: approx. 27Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/2>

Place of Sampling	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 27, 2012 7:04 AM		Feb 27, 2012 7:11 AM		Feb 27, 2012 7:18 AM		Feb 27, 2012 7:21 AM		Feb 27, 2012 7:25 AM		Feb 27, 2012 7:32 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	32	0.53	25	0.42	ND	-	60	1.0	60
Cs-137 (about 30 years)	ND	-	ND	-	34	0.38	45	0.50	29	0.32	81	0.90	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 12Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 24Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/2>

Place of Sampling	Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		In front of the water intake canal of 1F's Unit 6		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 27, 2012 7:38 AM	Feb 27, 2012 7:41 AM	Feb 27, 2012 7:44 AM	Feb 27, 2012 7:47 AM	Feb 27, 2012 7:51 AM	N/A						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40
Cs-134 (about 2 years)	ND	-	120	2.0	ND	-	53	0.88	ND	-	-	-	60
Cs-137 (about 30 years)	29	0.32	160	1.8	51	0.57	74	0.82	42	0.47	-	-	90
Mn-54 (approx.310 days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	-	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 23Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<1/3>

Place of Sampling	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4				Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 28, 2012 7:15 AM	N/A		Feb 28, 2012 7:20 AM	Feb 28, 2012 3:05 PM		Feb 28, 2012 7:22 AM		Feb 28, 2012 7:25 AM			
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	-	-	25	0.42	ND	-	ND	-	65	1.1	60
Cs-137 (about 30 years)	ND	-	-	-	ND	-	28	0.31	ND	-	64	0.71	90
Mn-54 (approx.310days)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	-	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 12Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 28Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<2/3>

Place of Sampling	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 28, 2012 7:27 AM	Feb 28, 2012 7:30 AM	Feb 28, 2012 7:33 AM	Feb 28, 2012 7:35 AM	Feb 28, 2012 7:38 AM	Feb 28, 2012 7:40 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	44	0.73	26	0.43	95	1.6	ND	-	30	0.50	60
Cs-137 (about 30 years)	ND	-	83	0.92	33	0.37	120	1.3	34	0.38	44	0.49	90
Mn-54 (approx.310days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Co-60 (approx.5yrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 23Bq/L, Cs-137: approx. 27Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Radioactivity Density of Seawater in the port of Fukushima Daiichi NPS<3/3>

Place of Sampling	Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi NPS		In front of the water intake canal of 1F's Unit 6								②Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	Feb 28, 2012 7:42 AM		N/A		Feb 28, 2012 8:50 AM							
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	-	-	ND	-							40
Cs-134 (about 2 years)	30	0.50	-	-	ND	-							60
Cs-137 (about 30 years)	ND	-	-	-	ND	-							90
Mn-54 (approx.310d ays)	ND	-	-	-	ND	-							1,000
Co-60 (approx.5yrs)	ND	-	-	-	ND	-							200
Tc-99m (approx.6hrs)	ND	-	-	-	ND	-							40,000
Te-129m (approx.34day s)	ND	-	-	-	ND	-							300
Te- 129(approx.7 0mins)	ND	-	-	-	ND	-							10,000
Cs-136 (approx.13day s)	ND	-	-	-	ND	-							300
Ba-140 (approx.13day s)	ND	-	-	-	ND	-							300
La-140 (approx.40hrs)	ND	-	-	-	ND	-							400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 11Bq/L, Cs-134: approx. 19Bq/L, Cs-137: approx. 27Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 15, 2012 9:30 AM	Feb 15, 2012 9:40 AM	Feb 15, 2012 11:26 AM	Feb 15, 2012 9:17 AM	Feb 15, 2012 10:18 AM	Feb 15, 2012 9:20 AM	Feb 15, 2012 8:55 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	2.2E-01	4.3E-01	2.4E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	3.6E-01	6.4E-01	3.8E-02	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 17, 2012 9:35 AM	Feb 17, 2012 9:40 AM	Feb 17, 2012 10:43 AM	Feb 17, 2012 10:00 AM	Feb 17, 2012 10:55 AM	Feb 17, 2012 9:30 AM	Feb 17, 2012 9:15 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	2.2E-01	4.7E-01	2.6E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	3.8E-01	6.9E-01	4.5E-02	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 20, 2012 10:57 AM	Feb 20, 2012 10:49 AM	Feb 20, 2012 10:10 AM	Feb 20, 2012 9:17 AM	Feb 20, 2012 10:12 AM	Feb 20, 2012 9:50 AM	Feb 20, 2012 9:30 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	3.0E-01	5.9E-01	2.5E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	4.4E-01	8.3E-01	4.6E-02	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 22, 2012 10:50 AM	Feb 22, 2012 10:55 AM	Feb 22, 2012 9:38 AM	Feb 22, 2012 9:46 AM	Feb 22, 2012 11:25 AM	Feb 22, 2012 9:21 AM	Feb 22, 2012 9:05 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	2.8E-01	5.7E-01	ND	ND	ND	ND	ND
Cs-137 (about 30 years)	4.0E-01	8.1E-01	3.0E-02	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 24, 2012 10:06 AM	Feb 24, 2012 9:30 AM	Feb 24, 2012 9:40 AM	Feb 24, 2012 9:16 AM	Feb 24, 2012 10:37 AM	Feb 24, 2012 9:05 AM	Feb 24, 2012 8:45 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	2.5E-01	5.1E-01	ND	ND	ND	ND	ND
Cs-137 (about 30 years)	4.0E-01	7.1E-01	2.8E-02	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Feb 27, 2012 9:57 AM	Feb 27, 2012 10:26 AM	Feb 27, 2012 10:45 AM	Feb 27, 2012 9:21 AM	Feb 27, 2012 10:36 AM	Feb 27, 2012 10:48 AM	Feb 27, 2012 9:00 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	2.4E-01	4.4E-01	ND	ND	ND	ND	ND
Cs-137 (about 30 years)	4.0E-01	6.5E-01	ND	ND	ND	ND	ND
Nb-95 (approx.35days)	ND	ND	ND	ND	ND	ND	ND
Ru-106 (approx.370days)	ND	ND	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND	ND	ND
Ba-140(approx.13days)	ND	ND	ND	ND	ND	ND	ND
La-140 (approx. 40hrs)	ND	ND	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/15 9:17	2012/2/15 9:22	2012/2/15 9:31	2012/2/15 9:42	N/A	2012/2/15 9:39	2012/2/15 9:46	2012/2/15 9:35
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	5.5E-02	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	6.2E-02	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*O.OE—O means O.O x 10-O

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 2E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/16 9:17	2012/2/16 9:20	2012/2/16 9:23	2012/2/16 9:33	N/A	2012/2/16 9:31	2012/2/16 9:37	2012/2/16 9:27
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.0E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.4E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/17 10:00	2012/2/17 10:05	2012/2/17 10:08	2012/2/17 10:21	N/A	2012/2/17 10:17	2012/2/17 10:26	2012/2/17 10:13
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.0E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.3E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 2E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/18 9:22	2012/2/18 9:26	2012/2/18 9:29	2012/2/18 9:39	N/A	2012/2/18 9:36	2012/2/18 9:43	2012/2/18 9:33
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.6E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/19 9:06	2012/2/19 9:10	2012/2/19 9:13	2012/2/19 9:26	N/A	2012/2/19 9:23	2012/2/19 9:31	2012/2/19 9:18
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	4.1E-02	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	6.1E-02	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/20 9:17	2012/2/20 9:22	2012/2/20 9:26	2012/2/20 9:41	2012/2/20 9:35	2012/2/20 9:38	2012/2/20 9:45	2012/2/20 9:30
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	ND	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	ND	1.0E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	ND	1.4E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	ND	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	ND	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	ND	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	ND	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/21 9:24	2012/2/21 9:29	2012/2/21 9:33	2012/2/21 9:44	N/A	2012/2/21 9:41	2012/2/21 9:49	2012/2/21 9:37
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	8.7E-02	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.2E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/22 9:46	2012/2/22 9:50	2012/2/22 9:54	2012/2/22 10:06	N/A	2012/2/22 10:02	2012/2/22 10:12	2012/2/22 9:58
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.5E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/23 9:57	2012/2/23 10:00	2012/2/23 10:04	2012/2/23 10:16	N/A	2012/2/23 10:13	2012/2/23 10:21	2012/2/23 10:09
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.4E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/24 9:16	2012/2/24 9:20	2012/2/24 9:32	2012/2/24 9:45	N/A	2012/2/24 9:42	2012/2/24 9:50	2012/2/24 9:36
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.2E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.7E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 2E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/25 9:32	2012/2/25 9:35	2012/2/25 9:39	2012/2/25 9:49	N/A	2012/2/25 9:46	2012/2/25 9:52	2012/2/25 9:43
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/26 9:33	2012/2/26 9:37	2012/2/26 9:41	2012/2/26 9:54	N/A	2012/2/26 9:51	2012/2/26 9:59	2012/2/26 9:46
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	3.6E-02	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	4.9E-02	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclides that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/27 9:21	2012/2/27 9:25	2012/2/27 9:28	2012/2/27 9:44	2012/2/27 9:38	2012/2/27 9:42	2012/2/27 9:48	2012/2/27 9:32
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	ND	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	ND	1.1E-01	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	ND	1.3E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	ND	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	ND	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	ND	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	ND	ND	ND	ND

*0.0E-0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite report】 Nuclide Analysis Results of Sub-drain Water in the Surroundings of Centralized Radiation Waste Treatment Facility

Place of sampling	Fukushima Daiichi Unit 4: Turbine building Southeast	Fukushima Daiichi Process main building Northeast	Fukushima Daiichi Process main building Southeast	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building South	Fukushima Daiichi On-site Bunker Building Southwest	Fukushima Daiichi Incineration Workshop Building West	Fukushima Daiichi Miscellaneous Solid Waste Volume Reduction Treatment Building North	Fukushima Daiichi On-site Bunker Building Southeast
Time of sampling	2012/2/28 9:15	2012/2/28 9:20	2012/2/28 9:23	2012/2/28 9:37	対象外 0:00	2012/2/28 9:32	2012/2/28 9:42	2012/2/28 9:28
Detected nuclides (half-life)	Density of sample (Bq/cm ³)							
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-134 (Approx. 2 years)	ND	ND	ND	ND	-	9.7E-02	ND	ND
Cs-137 (Approx. 30 years)	ND	ND	ND	ND	-	1.1E-01	ND	ND
Te-129 (Approx. 70 minutes)	ND	ND	ND	ND	-	ND	ND	ND
Te-129m (Approx. 34 days)	ND	ND	ND	ND	-	ND	ND	ND
Cs-136 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND
Ba-140 (Approx. 13 days)	ND	ND	ND	ND	-	ND	ND	ND

*0.0E - 0 means 0.0 x 10⁻⁰

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows:

I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Ibaraki Prefecture 1/2>

Place of Sampling	3 km offshore of Takadokobama shore Upper Layer		3 km offshore of Takadokobama shore Lower Layer		3 km offshore of Kujihama shore Upper Layer		3 km offshore of Kujihama shore Lower Layer		3 km offshore of Oarai shore Upper Layer		3 km offshore of Oarai shore Lower Layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 15, 2012 6:50 AM		Feb 15, 2012 6:48 AM		Feb 15, 2012 8:31 AM		Feb 15, 2012 8:29 AM		Feb 15, 2012 1:34 PM		Feb 15, 2012 1:32 PM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit of radioactive material in seawater. The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 0.92Bq/L, Cs-134: approx. 1.5Bq/L, Cs-137: approx. 1.4Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Ibaraki Prefecture 2/2 >

Place of Sampling	3 km offshore of Hirai shore Upper Layer		3 km offshore of Hirai shore Lower Layer		3 km offshore of Hasaki shore Upper Layer		3 km offshore of Hasaki shore Lower Layer						② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 13, 2012 2:09 PM		Feb 13, 2012 2:08 PM		Feb 13, 2012 2:20 PM		Feb 13, 2012 2:18 PM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-					300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-					200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit of radioactive material in seawater. The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.2Bq/L, Cs-134: approx. 1.3Bq/L, Cs-137: approx. 1.3Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Ibaraki Prefecture 1/2>

Place of Sampling	3 km offshore of Takadokobama shore Upper Layer		3 km offshore of Takadokobama shore Lower Layer		3 km offshore of Kujihama shore Upper Layer		3 km offshore of Kujihama shore Lower Layer		3 km offshore of Oarai shore Upper Layer		3 km offshore of Oarai shore Lower Layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 22, 2012 7:59 AM		Feb 22, 2012 7:57 AM		Feb 22, 2012 8:28 AM		Feb 22, 2012 8:26 AM		Feb 22, 2012 1:16 PM		Feb 22, 2012 1:13 PM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit of radioactive material in seawater. The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.0Bq/L, Cs-134: approx. 1.5Bq/L, Cs-137: approx. 1.3Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Ibaraki Prefecture 2/2 >

Place of Sampling	3 km offshore of Hirai shore Upper Layer		3 km offshore of Hirai shore Lower Layer		3 km offshore of Hasaki shore Upper Layer		3 km offshore of Hasaki shore Lower Layer						② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 21, 2012 2:46 PM		Feb 21, 2012 2:45 PM		Feb 21, 2012 1:42 PM		Feb 21, 2012 1:40 PM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-					1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-					40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-					300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-					10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-					200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-					3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-					300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-					400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit of radioactive material in seawater. The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.1Bq/L, Cs-134: approx. 1.4Bq/L, Cs-137: approx. 1.4Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Miyagi Prefecture 1/3>

Place of Sampling	Ishinomaki bayUpper Layer		Ishinomaki bayMiddle Layer		Ishinomaki bayLower Layer		Offshore of East side of Kinkasan Upper Layer		Offshore of East side of Kinkasan Middle Layer		Offshore of East side of Kinkasan Lower Layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling		Time of Sampling		Time of Sampling		Time of Sampling		Time of Sampling		Time of Sampling		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.0Bq/L, Cs-134: approx. 1.1Bq/L, Cs-137: approx. 1.3Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Miyagi Prefecture 2/3 >

Place of Sampling	Offshore of South side of Kinkasan Upper Layer		Offshore of South side of Kinkasan Middle Layer		Offshore of South side of Kinkasan Lower Layer		Offshore of Shichigahama Upper Layer		Offshore of Shichigahama Middle Layer		Offshore of Shichigahama Lower Layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 14, 2012 8:45 AM		Feb 14, 2012 8:58 AM		Feb 14, 2012 8:49 AM		Feb 14, 2012 9:19 AM		Feb 14, 2012 9:25 AM		Feb 14, 2012 9:22 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.0Bq/L, Cs-134: approx. 1.1Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in Seawater <Offshore of Miyagi Prefecture 3/3>

Place of Sampling	Central area of Sendai bay Upper Layer		Central area of Sendai bay Middle Layer		Central area of Sendai bay Lower Layer		Offshore of Abukumagawa Upper Layer		Offshore of Abukumagawa Middle Layer		Offshore of Abukumagawa Lower Layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Feb 14, 2012 7:15 AM		Feb 14, 2012 7:24 AM		Feb 14, 2012 7:20 AM		Feb 14, 2012 8:21 AM		Feb 14, 2012 8:26 AM		Feb 14, 2012 8:24 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90
Mo-99 (approx. 66hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	1,000
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40,000
Te-129m (approx.34days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	10,000
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	200
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	3,000
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	300
La-140 (approx. 40hrs)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	400

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 1.1Bq/L, Cs-134: approx. 1.1Bq/L, Cs-137: approx. 1.3Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide analysis results of ocean soil

Place of Sampling	3km offshore of Soma city	5km offshore of Soma city	5km offshore of Kashima		
Time of Sampling	Feb 14, 2012 8:50 AM	Feb 14, 2012 7:29 AM	Feb 14, 2012 8:04 AM		
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg · moist soil)				
I-131 (about 8 days)	ND	ND	ND		
Cs-134 (about 2 years)	10	13	53		
Cs-137 (about 30 years)	12	21	66		
Mn-54 (approx.310days)	ND	ND	ND		
Co-60 (approx.5yrs)	ND	ND	ND		
Tc-99m (approx.6hrs)	ND	ND	ND		
Ag-110m (approx.250days)	ND	ND	ND		
Sb-125 (approx.3yrs)	ND	ND	ND		
Te-129 (approx.70mins)	ND	ND	ND		
Te-129m (approx.34days)	ND	ND	ND		
Cs-136 (approx.13days)	ND	ND	ND		
Ba-140 (approx.13days)	ND	ND	ND		
La-140 (approx.40hrs)	ND	ND	ND		

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 3Bq/kg· moist soil,
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide analysis results of ocean soil

Place of Sampling	15km offshore of Minami Soma city	Iwasawa Seashoreoffshore 15km	15 km offshore of Hirono-town		
Time of Sampling	Feb 15, 2012 (Not sampled)	Feb 15, 2012 (Not sampled)	Feb 15, 2012 (Not sampled)		
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg · moist soil)				
I-131 (about 8 days)	-	-	-		
Cs-134 (about 2 years)	-	-	-		
Cs-137 (about 30 years)	-	-	-		
Mn-54 (approx.310days)	-	-	-		
Co-60 (approx.5yrs)	-	-	-		
Tc-99m (approx.6hrs)	-	-	-		
Ag-110m (approx.250days)	-	-	-		
Sb-125 (approx.3yrs)	-	-	-		
Te-129 (approx.70mins)	-	-	-		
Te-129m (approx.34days)	-	-	-		
Cs-136 (approx.13days)	-	-	-		
Ba-140 (approx.13days)	-	-	-		
La-140 (approx.40hrs)	-	-	-		

【Definite Report】 Nuclide analysis results of ocean soil < 1/2 >

Place of Sampling	15km offshore of Minami Soma city	15 km offshore of Ukedogawa	15 km offshore of Fukushima Daiichi	15 km offshore of Fukushima Daini	Iwasawa Seashoreoffshore 15km
Time of Sampling	Feb 16, 2012 (Not sampled)	Feb 16, 2012 (Not sampled)	Feb 16, 2012 (Not sampled)	Feb 16, 2012 (Not sampled)	Feb 16, 2012 (Not sampled)
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg · moist soil)				
I-131 (about 8 days)	-	-	-	-	-
Cs-134 (about 2 years)	-	-	-	-	-
Cs-137 (about 30 years)	-	-	-	-	-
Mn-54 (approx.310days)	-	-	-	-	-
Co-60 (approx.5yrs)	-	-	-	-	-
Tc-99m (approx.6hrs)	-	-	-	-	-
Ag-110m (approx.250days)	-	-	-	-	-
Sb-125 (approx.3yrs)	-	-	-	-	-
Te-129 (approx.70mins)	-	-	-	-	-
Te-129m (approx.34days)	-	-	-	-	-
Cs-136 (approx.13days)	-	-	-	-	-
Ba-140 (approx.13days)	-	-	-	-	-
La-140 (approx.40hrs)	-	-	-	-	-

【Definite Report】 Nuclide analysis results of ocean soil < 2/2 >

Place of Sampling	15 km offshore of Hirono-town				
Time of Sampling	Feb 16, 2012 (Not sampled)				
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg· moist soil)				
I-131 (about 8 days)	-				
Cs-134 (about 2 years)	-				
Cs-137 (about 30 years)	-				
Mn-54 (approx.310days)	-				
Co-60 (approx.5yrs)	-				
Tc-99m (approx.6hrs)	-				
Ag-110m (approx.250days)	-				
Sb-125 (approx.3yrs)	-				
Te-129 (approx.70mins)	-				
Te-129m (approx.34days)	-				
Cs-136 (approx.13days)	-				
Ba-140 (approx.13days)	-				
La-140 (approx.40hrs)	-				

【Definite Report】 Nuclide analysis results of ocean soil < 1/2 >

Place of Sampling	15km offshore of Minami Soma city	15 km offshore of Ukedogawa	15 km offshore of Fukushima Daiichi	15 km offshore of Fukushima Daini	Iwasawa Seashoreoffshore 15km
Time of Sampling	Feb 17, 2012 (Not sampled)	Feb 17, 2012 (Not sampled)	Feb 17, 2012 (Not sampled)	Feb 17, 2012 (Not sampled)	Feb 17, 2012 (Not sampled)
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg · moist soil)				
I-131 (about 8 days)	-	-	-	-	-
Cs-134 (about 2 years)	-	-	-	-	-
Cs-137 (about 30 years)	-	-	-	-	-
Mn-54 (approx.310days)	-	-	-	-	-
Co-60 (approx.5yrs)	-	-	-	-	-
Tc-99m (approx.6hrs)	-	-	-	-	-
Ag-110m (approx.250days)	-	-	-	-	-
Sb-125 (approx.3yrs)	-	-	-	-	-
Te-129 (approx.70mins)	-	-	-	-	-
Te-129m (approx.34days)	-	-	-	-	-
Cs-136 (approx.13days)	-	-	-	-	-
Ba-140 (approx.13days)	-	-	-	-	-
La-140 (approx.40hrs)	-	-	-	-	-

【Definite Report】 Nuclide analysis results of ocean soil < 2/2 >

Place of Sampling	15 km offshore of Hirono-town				
Time of Sampling	Feb 17, 2012 (Not sampled)				
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg· moist soil)				
I-131 (about 8 days)	-				
Cs-134 (about 2 years)	-				
Cs-137 (about 30 years)	-				
Mn-54 (approx.310days)	-				
Co-60 (approx.5yrs)	-				
Tc-99m (approx.6hrs)	-				
Ag-110m (approx.250days)	-				
Sb-125 (approx.3yrs)	-				
Te-129 (approx.70mins)	-				
Te-129m (approx.34days)	-				
Cs-136 (approx.13days)	-				
Ba-140 (approx.13days)	-				
La-140 (approx.40hrs)	-				

【Definite Report】 Nuclide analysis results of ocean soil < 1/2 >

Place of Sampling	15km offshore of Minami Soma city	15 km offshore of Ukedogawa	15 km offshore of Fukushima Daiichi	15 km offshore of Fukushima Daini	Iwasawa Seashoreoffshore 15km
Time of Sampling	Feb 19, 2012 12:15 PM	Feb 19, 2012 12:40 PM	Feb 19, 2012 11:10 AM	Feb 19, 2012 9:45 AM	Feb 19, 2012 8:25 AM
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg · moist soil)				
I-131 (about 8 days)	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	13	30	16	42	170
Cs-137 (about 30 years)	18	38	21	56	230
Mn-54 (approx.310days)	ND	ND	ND	ND	ND
Co-60 (approx.5yrs)	ND	ND	ND	ND	ND
Tc-99m (approx.6hrs)	ND	ND	ND	ND	ND
Ag-110m (approx.250days)	ND	ND	ND	ND	ND
Sb-125 (approx.3yrs)	ND	ND	ND	ND	ND
Te-129 (approx.70mins)	ND	ND	ND	ND	ND
Te-129m (approx.34days)	ND	ND	ND	ND	ND
Cs-136 (approx.13days)	ND	ND	ND	ND	ND
Ba-140 (approx.13days)	ND	ND	ND	ND	ND
La-140 (approx.40hrs)	ND	ND	ND	ND	ND

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 5Bq/kg· moist soil,
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide analysis results of ocean soil < 2/2 >

Place of Sampling	15 km offshore of Hirono-town				
Time of Sampling	Feb 19, 2012 7:30 AM				
Detected Nuclides (Half-life)	Radioactivity density (Bq/kg· moist soil)				
I-131 (about 8 days)	ND				
Cs-134 (about 2 years)	140				
Cs-137 (about 30 years)	200				
Mn-54 (approx.310days)	ND				
Co-60 (approx.5yrs)	ND				
Tc-99m (approx.6hrs)	ND				
Ag-110m (approx.250days)	ND				
Sb-125 (approx.3yrs)	ND				
Te-129 (approx.70mins)	ND				
Te-129m (approx.34days)	ND				
Cs-136 (approx.13days)	ND				
Ba-140 (approx.13days)	ND				
La-140 (approx.40hrs)	ND				

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: I-131: approx. 5Bq/kg· moist soil,
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the opening parts of the buildings of Fukushima Daiichi NPS <1/5>

Place of Sampling	process main building open hatch (east side open hatch)		burning building hatch (south-east open hatch)		Open part of On-site Bunker Building (truck bay door of On-site Bunker Building)		②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
Time of Sampling	21-Feb-12 9 : 00 ~ 10 : 00		21-Feb-12 9 : 00 ~ 10 : 00		21-Feb-12 9 : 00 ~ 10 : 00		
Detected Nuclides (Half-life)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	9.7E-06	0.00	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (approx.370days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132(approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 6E-6Bq/cm3, Cs-134: approx. 2E-5Bq/cm3, Cs-137: approx. 2E-5Bq/cm3 Particulate: I-131: approx. 3E-6Bq/cm3, Cs-134: approx. 8E-6Bq/cm3, Cs-137: approx. 1E-5Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the opening parts of the buildings of Fukushima Daiichi NPS <2/5>

Place of Sampling	Miscellaneous Solid Waste Volume Reduction Treatment Building open hatch (north-east side open hatch)		process main building open hatch (inside the decontamination device room)		Ventilation of Granulated Solidification Matter Storage Tank (ventilation outlet)		②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
	21-Feb-12 15 : 00 ~ 16 : 00		21-Feb-12 8 : 55 ~ 9 : 55		21-Feb-12 9 : 05 ~ 9 : 15		
Detected Nuclides (Half-life)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	3.9E-05	0.02	2.5E-04	0.13	ND	-	2E-03
Cs-137 (about 30 years)	4.0E-05	0.01	3.4E-04	0.11	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (approx.370days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132 (approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* 0.0E-0 means 0.0 x 10-0

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 6E-6Bq/cm3, Cs-134: approx. 2E-5Bq/cm3, Cs-137: approx. 2E-5Bq/cm3 Particulate: I-131: approx. 5E-6Bq/cm3, Cs-134: approx. 5E-6Bq/cm3, Cs-137: approx. 6E-6Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the opening parts of the buildings of Fukushima Daiichi NPS <3/5>

Place of Sampling	Waste treatment facility of Unit 1 (western open part)		Waste treatment facility of Unit 2 (western open part)		Waste treatment facility of Unit 4 (northeastern open part)		②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
Time of Sampling	22-Feb-12 8 : 50 ~9 : 50		22-Feb-12 8 : 50 ~9 : 50		23-Feb-12 14 : 40 ~15 : 40		
Detected Nuclides (Half-life)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	1.3E-05	0.00	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (approx.370days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132(approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* 0.0E-0 means 0.0 x 10-0

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 6E-6Bq/cm3, Cs-134: approx. 1E-5Bq/cm3, Cs-137: approx. 2E-5Bq/cm3 Particulate: I-131: approx. 4E-6Bq/cm3, Cs-134: approx. 9E-6Bq/cm3, Cs-137: approx. 9E-6Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the opening parts of the buildings of Fukushima Daiichi NPS <4/5>

Place of Sampling	Open part of reactor building of Unit 4 (truck bay door of reactor building)		Open part of turbine building of Unit 1 (truck bay door of turbine building)		Open part of turbine building of Unit 2 (truck bay door of turbine building)		②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
Time of Sampling	23-Feb-12 14 : 40 ~ 15 : 40		23-Feb-12 7 : 56 ~ 8 : 56		23-Feb-12 7 : 56 ~ 8 : 56		
Detected Nuclides (Half-life)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	3E-03
Nb-95 (approx.35days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (approx.370days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (approx.250days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (approx.70mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (approx.34days)	ND	-	ND	-	ND	-	4E-03
I-132(approx.2hrs)	ND	-	ND	-	ND	-	7E-02
Te-132 (approx.78hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (approx.21hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (approx.13days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (approx.13days)	ND	-	ND	-	ND	-	1E-02
La-140 (approx.40hrs)	ND	-	ND	-	ND	-	1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 5E-6Bq/cm3, Cs-134: approx. 1E-5Bq/cm3, Cs-137: approx. 2E-5Bq/cm3 Particulate: I-131: approx. 3E-6Bq/cm3, Cs-134: approx. 9E-6Bq/cm3, Cs-137: approx. 1E-5Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis Results of Radioactive Materials in the Air at the opening parts of the buildings of Fukushima Daiichi NPS <5/5>

Place of Sampling	Open part of turbine building of Unit 3 (truck bay door of turbine building)		Open part of turbine building of Unit 4 (truck bay door of turbine building)				②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)			
Time of Sampling	23-Feb-12 15 : 20 ~ 16 : 20		23-Feb-12 15 : 20 ~ 16 : 20				
Detected Nuclides (Half-life)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	①density of sample (Bq/cm3)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-			1E-03
Cs-134 (about 2 years)	ND	-	ND	-			2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03
Nb-95 (approx.35days)	ND	-	ND	-			2E-02
Tc-99m (approx.6hrs)	ND	-	ND	-			7E-01
Ru-106 (approx.370days)	ND	-	ND	-			6E-04
Ag-110m (approx.250days)	ND	-	ND	-			3E-03
Sb-125 (approx.3yrs)	ND	-	ND	-			6E-03
Te-129 (approx.70mins)	ND	-	ND	-			4E-01
Te-129m (approx.34days)	ND	-	ND	-			4E-03
I-132(approx.2hrs)	ND	-	ND	-			7E-02
Te-132 (approx.78hrs)	ND	-	ND	-			4E-03
I-133 (approx.21hrs)	ND	-	ND	-			5E-03
Cs-136 (approx.13days)	ND	-	ND	-			1E-02
Ba-140 (approx.13days)	ND	-	ND	-			1E-02
La-140 (approx.40hrs)	ND	-	ND	-			1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE—O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 5E-6Bq/cm3, Cs-134: approx. 1E-5Bq/cm3, Cs-137: approx. 2E-5Bq/cm3 Particulate: I-131: approx. 4E-6Bq/cm3, Cs-134: approx. 9E-6Bq/cm3, Cs-137: approx. 1E-5Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

【Definite Report】 Nuclide Analysis results of Radioactive Materials in the Air at the Sites of Fukushima Daiichi Nuclear Power Stations measured by unmanned robots

Place of Sampling	Unit 2 of Fukushima Daiichi R/B5F Operating Floor						Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) *
Time of Sampling	Feb 27, 2012 11:35 - 12:35						
Detected Nuclides (Half-life)	density of sample (Bq/cm3)	Scaling Factor (/)	density of sample (Bq/cm3)	Scaling Factor (/)	density of sample (Bq/cm3)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-					1E-03
Cs-134 (about 2 years)	3.0E-03	1.5					2E-03
Cs-137 (about 30 years)	3.9E-03	1.3					3E-03
Nb-95 (approx.35days)	ND	-					2E-02
Tc-99m (approx.6hrs)	ND	-					7E-01
Ru-106 (approx. 370days)	3.2E-04	0.53					6E-04
Ag-110m (approx.250days)	1.2E-03	0.40					3E-03
Sb-125 (approx.3yrs)	9.3E-04	0.16					6E-03
Te-129 (approx.70mins)	ND	-					4E-01
Te-129m (approx.34days)	ND	-					4E-03
I-132 (approx.2hrs)	ND	-					7E-02
Te-132 (approx.78hrs)	ND	-					4E-03
I-133 (approx.21hrs)	ND	-					5E-03
Cs-136 (approx.13days)	ND	-					1E-02
Ba-140 (approx.13days)	ND	-					1E-02
La-140 (approx.40hrs)	ND	-					1E-02
Ce-144 (approx. 280days)	8.2E-05	0.12					7E-04
Sn-113 (approx. 120days)	9.3E-05	0.01					1E-02

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

* O.OE - O means O.O x 10-O

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with

* "ND" means the sampled data is below measurable limit.

The detection limits of major three nuclide that are not detected are as follows: Volatile: I-131: approx. 1E-5Bq/cm3

Particulate: I-131: approx. 2E-5Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.