Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/3) Underground Water Obtained at Bank Protection

Unit: Bg/L

												Unit: Bq/L
		Underground water observation hole No.0-1	Underground water observation hole No.0-2	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-5	Underground water observation hole No.1-8	Groundwater pumped up from the well point	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3
	Date of sampling	/	/	/	/	/	/	/	/	Sep 1, 2013	Sep 1, 2013	/
	Time of sampling									10:00 AM	9:30 AM	
Cs	s-134 (Approx. 2 years)									ND(0.41)	0.66	
Cs	s-137 (Approx.30 years)									ND(0.55)	1.1	
The other y												
	ΑΙΙ β									230	ND(19)	
H	H-3 (Approx. 12 years)									670	270	
Sr	-90 (Approx. 29 years)	/	/	/	/		/	/		-	-	/

^{*} Data announced this time is provided in a thick-frame. The other data was announced on September 2.

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/3) Underground Water Obtained at Bank Protection

		Underground water observation hole No.0-1	Underground water observation hole No.0-2*1	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3*1	Underground water observation hole No.1-5	Underground water observation hole No.1-8		Groundwater pumped up from the well point	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3
	Date of sampling	/	/	/	/	/	/	/		/	Sep 4, 2013	Sep 4, 2013	/
	Time of sampling			/						/	10:10 AM	9:40 AM	
	Cs-134 (Approx. 2 years)										ND(0.44)	ND(0.40)	
(Cs-137 (Approx.30 years)										0.53	0.82	
The other v													
	ΑΙΙ β										300	29	
	H-3 (Approx. 12 years)	1/									Under analysis	Under analysis	
;	Sr-90 (Approx. 29 years)	/	/	/		/	/	/	/		-	-	/

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/3) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Date of Sampling			/						/		
Time of sampling											
Cs-134(Approx. 2 years)							/				
Cs-137(Approx.30 years)				/			/				
ΑΙΙ β					/			/		/	
H-3 (Approx. 12 years)							/				
Sr-90 (Approx. 29 years)				/			/		/		

	1F, Between the water intake channel of Unit 3 and Unit 4	Screen	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater*	East side of the port entrance*	South side of the south breakwater*
Date of Sampling									Sep 3, 2013	Sep 3, 2013	Sep 3, 2013
Time of sampling									8:39 AM	8:25 AM	8:31 AM
Cs-134(Approx. 2 years)									ND(0.88)	ND(0.63)	ND(0.43)
Cs-137(Approx.30 years)						/	/		ND(0.58)	ND(0.69)	ND(0.66)
ΑΙΙ β									ND(16)	ND(16)	ND(16)
H-3 (Approx. 12 years)						/	/	/	Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)	/	/			/	/	/	/	=	-	-

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

			observa	dwater tion hole .0-1	observa	ndwater ation hole o.0-2	observa	dwater tion hole p.1	Ground observat No.	ion hole	observa	dwater tion hole .1-2	Ground observat No.	ion hole	Ground observat No.	tion hole	observa	dwater tion hole .1-5	observa	dwater tion hole .1-8		dwater tion hole 1-9	Ground pumped the wel (notch	up from Il point
	Cs	s-134 (Approx. 2 years)	1.4	[8/29]	ND		13	[8/29]	1.9	[7/8]	11,000	[7/9]	10	[9/2]	1.5	[7/8]	310	[8/5]	30	[9/2]	170	[9/3]	1.5	[8/19]
	Cs	-137 (Approx.30 years)	3.0	[8/29]	0.75	[9/2]	31	[8/29]	3.6	[7/8]	22,000	[7/9]	24	[9/2]	3.6	[7/8]	650	[8/5]	63	[9/2]	380	[9/3]	3.4	[8/19]
		Ru-106 (Approx. 370 days)	ND		ND		26	[5/24]	7.9	[7/8]	160	(8/15)	17	(7/22) (8/8)	3.1	[8/8]	ND		ND		ND		25	[9/2]
	The	Mn-54 (Approx. 310 days)	ND		ND		ND		1.0	[7/5]	62	[7/5]	ND		ND		ND		0.52	[8/26]	ND		ND	
C	ther y	Co-60 (Approx. 5 years)	ND		ND		0.50	[7/19]	ND		3.1	[7/8]	ND		ND		ND		ND		ND		ND	
		Sb-125 (Approx. 3 years)	ND		ND		1.7	[7/11]	ND		250	(7/15)	1.4	(7/12) (8/26)	ND		12	(8/8)	ND		ND		ND	
		ΑΙΙ β	300	[8/22]	ND		1,900	[5/24]	4,400	[7/8]	900,000	(7/5) (7/9)	160,000	(8/12) (8/15)	380	[8/19]	56,000	(8/5)	1,200	[8/26]	470	[9/3]	360,000	[9/2]
	F	I-3 (Approx. 12 years)	45,000	[8/29]	ND		500,000	(5/24) (6/7)	630,000	[7/8]	400,000	[8/22]	290,000	[7/12]	98,000	[7/11]	72,000	(8/15)	950	[8/20]	Under analysis		460,000	(8/19)
	Sı	r-90(Approx. 29 years)	Under analysis		Under analysis	i	1,200	[6/7]	Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		ı	

		observa	dwater tion hole 5.2	Ground observat No.	tion hole	observa	ndwater ation hole o.3	Ground observat No.	ion hole
Cs	s-134 (Approx. 2 years)	0.50	[7/9]	0.66	[9/1]	3.5	[7/25]	1.2	(7/25) (8/8)
Cs	s-137 (Approx.30 years)	1.2	(7/11) (8/1)	1.1	(8/29) (9/1)	5.9	[8/8]	2.6	[8/1]
	Ru-106 (Approx. 370 days)	ND		ND		ND		ND	
The	Mn-54 (Approx. 310 days)	ND		ND		ND		ND	
other y	Co-60 (Approx. 5 years)	ND		ND		ND		ND	
	Sb-125 (Approx. 3 years)	ND		ND		ND		ND	
	All β	1,700	[7/8]	380	[7/29]	1,400	[7/11]	180	[8/1]
H	H-3 (Approx. 12 years)	850	[6/26]	440	[8/26]	3,200	[2012/12/ 12]	460	[8/1]
S	r-90(Approx. 29 years)	54	[5/31]	Under analysis		8.3	[2012/12/ 12]	Under analysis	

^{* &}quot;ND" indicates that the measurement result is below the detection limit.

^{*} Date of sampling is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement* (Seawater)

Unit: Bq/L

	Unit 5,6	th side of discharge annel	, .	ont of Unit 6 ake channel	,	front of draft quay	Unit 1-4 w	th side of rater intake nnel	Unit 1-4 v channel of East	th side of vater intake (north side t Seawall eak)	(Inside	1 Screen the Silt nce)	water inta of Unit 1		water inta of Unit 1	ween the ke channel and Unit 2 r layer)	(Inside	2 Screen the Silt nce)	water inta of Unit 2		water inta of Unit 2	tween the ake channel and Unit 3 er layer)	(Inside	3 Screen the Silt nce)
Cs-134(Approx. 2 years)	1.8	[6/21]	2.4	[8/19]	5.3	(8/5)	35	[8/29]	16	[8/12]	24	(8/12) (8/19)	27	[8/11]	13	(8/29)	26	[8/19]	21	[8/12]	3.5	[8/20]	350	(7/15)
Cs-137(Approx.30 years)	3.3	(6/26)	4.7	[8/19]	8.6	(8/5)	81	[8/13]	33	[8/12]	51	(8/12)	64	[8/27]	25	[8/29]	52	(8/19)	37	[8/12]	9.8	[8/20]	770	(7/15)
ΑΙΙ β	ND		46	[8/19]	40	[7/3]	1,100	(8/15)	320	[8/12]	700	[8/12]	740	[8/15]	450	[7/16]	490	[8/19]	410	[8/12]	85	[8/20]	1,000	(7/15)
H-3 (Approx. 12 years)	8.6	[6/26]	24	[8/19]	340	[6/26]	4,700	(8/15)	460	[7/15]	2,500	[8/12]	2,600	[8/15]	1,600	[9/1]	820	[8/19]	720	[8/12]	-		380	[8/12]
Sr-90 (Approx. 29 years)	5.8	[6/26]	-		7.4	[6/26]	Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		-		Under analysis	

	water inta of Unit 3		water inta of Unit 3	tween the ake channel and Unit 4 er layer)	(Inside	t 4 Screen e the Silt ence)	south o	ound the lischarge annel	1F, Por	t entrance	-	side in the ort	1F, West			side in the		n side in the port	North sid		East side of the port entrance	South side of the south breakwater
Cs-134(Approx. 2 years)	22	[8/12]	4.8	[8/20]	46	[7/8]	ND		1.6	[8/19]	2.9	[8/19]	2.6	[8/19]	ND		2.1	(8/19)	ND		ND	ND
Cs-137(Approx.30 years)	45	[8/12]	7.7	[8/20]	93.0	[7/8]	3.0	[7/15]	4.7	[8/19]	6.6	[8/19]	6.5	[8/19]	4.7	[8/19]	4.6	(8/19)	ND		ND	ND
ΑΙΙ β	390	[8/12]	57	[8/20]	310	[8/12]	ND		69	[8/19]	74	[8/19]	60	[7/4]	69	[8/19]	79	(8/19)	ND		ND	ND
H-3 (Approx. 12 years)	650	[8/12]	-		400	[8/12]	ND		68	[8/19]	67	(8/19)	59	[8/19]	52	(8/19)	60	[8/19]	4.7	[8/14]	ND	ND
Sr-90 (Approx. 29 years)	Under analysis		-		Under analysis		0.36	[6/26]	3.5	[6/20]	Under analysis		Under analysis		-		-		-		-	-

^{*} The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

^{* &}quot;ND" indicates that the measurement result is below the detection limit.

^{*} Date of sampling is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.