

Underground Reservoir Nuclide Analysis Results

<Reference>

April 9, 2013

Tokyo Electric Power Company

[Sampled place] Underground Reservoir i Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	12ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.4×10^{-2}	Approx. 8 days
Cs-134	N.D	5.4×10^{-2}	Approx. 2 years
Cs-137	N.D	7.0×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir i Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	6ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.7×10^{-2}	Approx. 8 days
Cs-134	N.D	5.3×10^{-2}	Approx. 2 years
Cs-137	N.D	6.7×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir ii Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	18ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.7×10^{-2}	Approx. 8 days
Cs-134	N.D	5.5×10^{-2}	Approx. 2 years
Cs-137	N.D	6.9×10^{-2}	Approx. 30 years
All	6.8×10^1	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir ii Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	9ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.5×10^{-2}	Approx. 8 days
Cs-134	N.D	5.0×10^{-2}	Approx. 2 years
Cs-137	N.D	6.8×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iii Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	5ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.3×10^{-2}	Approx. 8 days
Cs-134	N.D	5.1×10^{-2}	Approx. 2 years
Cs-137	N.D	6.5×10^{-2}	Approx. 30 years
All	3.5×10^{-2}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iii Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	5ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.7×10^{-2}	Approx. 8 days
Cs-134	N.D	5.2×10^{-2}	Approx. 2 years
Cs-137	N.D	6.9×10^{-2}	Approx. 30 years
All	1.2×10^{-1}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iv Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	10ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	3.1×10^{-2}	Approx. 8 days
Cs-134	N.D	4.9×10^{-2}	Approx. 2 years
Cs-137	N.D	6.7×10^{-2}	Approx. 30 years
All	3.3×10^{-2}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iv Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	7ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.6×10^{-2}	Approx. 8 days
Cs-134	N.D	5.1×10^{-2}	Approx. 2 years
Cs-137	N.D	6.5×10^{-2}	Approx. 30 years
All	3.2×10^{-2}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir v Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	12ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	3.1×10^{-2}	Approx. 8 days
Cs-134	N.D	5.0×10^{-2}	Approx. 2 years
Cs-137	N.D	7.1×10^{-2}	Approx. 30 years
All	2.6×10^{-1}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir v Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	8ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.7×10^{-2}	Approx. 8 days
Cs-134	N.D	5.4×10^{-2}	Approx. 2 years
Cs-137	N.D	6.7×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir vi Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	8ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.8×10^{-2}	Approx. 8 days
Cs-134	N.D	5.6×10^{-2}	Approx. 2 years
Cs-137	N.D	6.9×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir vi Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	5ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.4×10^{-2}	Approx. 8 days
Cs-134	N.D	5.0×10^{-2}	Approx. 2 years
Cs-137	N.D	6.8×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir vii Drain hole water, northeast side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	6ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.5×10^{-2}	Approx. 8 days
Cs-134	N.D	5.2×10^{-2}	Approx. 2 years
Cs-137	N.D	6.9×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir vii Drain hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	6ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.4×10^{-2}	Approx. 8 days
Cs-134	N.D	4.9×10^{-2}	Approx. 2 years
Cs-137	N.D	6.7×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir i Leakage detector hole water, northeast side

[Sampled date and time] At 10:10 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	4ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.2×10^{-2}	Approx. 8 days
Cs-134	N.D	5.1×10^{-2}	Approx. 2 years
Cs-137	N.D	6.6×10^{-2}	Approx. 30 years
All	N.D	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir i Leakage detector hole water, southwest side

[Sampled date and time] At 10:00 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	7ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.3×10^{-2}	Approx. 8 days
Cs-134	N.D	5.0×10^{-2}	Approx. 2 years
Cs-137	N.D	7.2×10^{-2}	Approx. 30 years
All	7.1×10^{-2}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir ii Leakage detector hole water, northeast side

[Sampled date and time] At 9:10 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	380ppm
------------------------	--------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	9.5×10^{-2}	Approx. 8 days
Cs-134	N.D	8.0×10^{-2}	Approx. 2 years
Cs-137	N.D	8.8×10^{-2}	Approx. 30 years
All	6.9×10^3	3.1×10^0	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir ii Leakage detector hole water, southwest side

[Sampled date and time] At 9:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	12ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	3.1×10^{-2}	Approx. 8 days
Cs-134	N.D	5.8×10^{-2}	Approx. 2 years
Cs-137	N.D	7.1×10^{-2}	Approx. 30 years
All	4.5×10^0	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iii Leakage detector hole water, northeast side

[Sampled date and time] At 10:20 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	3ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.4×10^{-2}	Approx. 8 days
Cs-134	N.D	5.3×10^{-2}	Approx. 2 years
Cs-137	N.D	6.5×10^{-2}	Approx. 30 years
All	1.2×10^{-1}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iii Leakage detector hole water, southwest side

[Sampled date and time] At 10:30 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	430ppm
------------------------	--------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	7.0×10^{-2}	Approx. 8 days
Cs-134	N.D	6.6×10^{-2}	Approx. 2 years
Cs-137	N.D	8.6×10^{-2}	Approx. 30 years
All	2.2×10^3	3.1×10^0	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iv Leakage detector hole water, northeast side

[Sampled date and time] At 10:40 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	12ppm
------------------------	-------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.0×10^{-2}	Approx. 8 days
Cs-134	N.D	5.1×10^{-2}	Approx. 2 years
Cs-137	N.D	6.6×10^{-2}	Approx. 30 years
All	3.1×10^{-1}	3.1×10^{-2}	-

All radioactive concentration: N.D

[Sampled place] Underground Reservoir iv Leakage detector hole water, southwest side

[Analysis results]

*Data is not obtained, since the amount of the water necessary for sampling was not obtained.

[Sampled place] Underground Reservoir vi Leakage detector hole water, northeast side

[Sampled date and time] At 11:40 AM on April 8 (Mon), 2013

[Analysis results]

Chloride concentration	8ppm
------------------------	------

Nuclide	Radioactive concentration (Bq/cm ³)	Detection limit (Bq/cm ³)	Half-life period
I-131	N.D	2.4×10^{-2}	Approx. 8 days
Cs-134	N.D	5.0×10^{-2}	Approx. 2 years
Cs-137	N.D	6.6×10^{-2}	Approx. 30 years
All	1.8×10^{-1}	3.1×10^{-2}	-

*Data is not obtained, since the amount of the water necessary for sampling was not obtained.

[Sampled place] Underground Reservoir vi Leakage detector hole water, southwest side

[Analysis results]

*Data is not obtained, since the amount of the water necessary for sampling was not obtained.