

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of November 4 and 5, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes								
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧	
	Nov 5, 2013								Nov 4, 2013							
Sampled time		9:42 AM	9:23 AM	9:30 AM	9:33 AM	9:35 AM	9:38 AM	8:59 AM	9:17 AM	9:03 AM	9:39 AM	9:59 AM	8:58 AM	10:24 AM	9:39 AM	
Chloride concentration (ppm)		9	11	56	62	80	9	9	5	7	10	5	10	23	9	
Tritium (Bq/cm ³)		2.4E-1	<5.3E-3	<5.9E-3	<5.9E-3	<5.9E-3	3.0E-2	7.0E-2	4.5E-2	1.2E+0	2.5E+0	8.1E-2	8.7E-2	5.0E-2	6.8E-2	
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on November 5 and 6.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.