

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of December 9 and 10, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Dec 10, 2013										Dec 9, 2013				
Sampled time		9:25 AM	9:05 AM	9:58 AM	10:00 AM	10:03 AM	10:07 AM	8:44 AM	9:12 AM	9:52 AM	9:37 AM	9:14 AM	8:59 AM	9:37 AM	9:19 AM
Chloride concentration (ppm)		10	10	55	66	50	10	10	5	8	12	7	10	16	10
Tritium (Bq/cm ³)		5.5E-1	<8.9E-3	2.1E-2	2.1E-2	5.0E-2	5.9E-2	6.0E-2	5.8E-2	9.0E-1	3.4E+0	6.5E-2	8.0E-2	3.9E-2	7.3E-2
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on December 10 and 11.

(Note 2) 0.0E±0 is the same as 0.0 x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.