

Analysis Results of Water inside Dike Obtained in H4-North Area Tank at Fukushima Daiichi NPS

Unit: Bq/L

	Water inside the dike at the H4-North area tank		
Date of Sampling	Oct 18, 2013	Oct 19, 2013	Oct 20, 2013
Time of sampling	9:20 AM	11:40 AM	9:30 AM
Cs-134(Approx. 2 years)	34	50	40
Cs-137(Approx.30 years)	90	79	120
Sb-125 (Approx. 3 years)	83	200	110
All β	360,000	450,000	510,000
H-3 (Approx. 12 years)	2,800	4,000	3,500

(Reference) All β concentration on September 15 (simplified measurement): 170,000 [Bq/L]