Reference

Nuclides Analysis Result of the Radioactive Materials in the Air at the Exhaust System of the Unit 2 Reactor Building

(Data summarized on May 15)

Place of Sampling	The Exhaust System of the Unit 2 Reactor Building (The entrance of cover exhaust system filter)		The Exhaust System of the Unit 2 Reactor Building (The exit of cover exhaust system filter)		Density Limit Specified by the Reactor Regulation
Time of Sampling	May 7, 2013 1:06 PM - 3:06 PM		May 7, 2013 12:12 PM - 2:12 PM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm³)	Scaling Factor (①/②)	Appendix 2)
I-131 (Approx. 8 days)	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	4.2E-07	0.00	ND	-	3E-03

^{*} The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE-O is the same as $O.O \times 10^{-O}$

Data of other nuclides is under examination.

The detection limits of the exhaust system at the Unit 2 Reactor Building (the entrance of cover exhaust system filter) are as follows.

Volatile; I-131: Approx. 2E-7Bq/cm³, Cs-134: Approx. 5E-7Bq/cm³, Cs-137: Approx. 6E-7Bq/cm³

Particulate; I-131: Approx. 1E-7Bq/cm³, Cs-134: Approx. 3E-7Bq/cm³

The detection limits of the exhaust system at the Unit 2 Reactor Building (the exit of cover exhaust system filter) are as follows.

Volatile; I-131: Approx. 2E-7Bq/cm³, Cs-134: Approx. 5E-7Bq/cm³, Cs-137: Approx. 6E-7Bq/cm³

Particulate; I-131: Approx. 1E-7Bq/cm³, Cs-134: Approx. 3E-7Bq/cm³, Cs-137: Approx. 4E-7Bq/cm³

^{*} In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

^{* &}quot;ND" indicates that the measurement result is below the detection limit.