

Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Seawater of the south water outlet ^{Note 1} (near the exit of the side ditch) (T-2)	Confluence of drainage channel B and C ^{Note 2} (C-1)	Sampling points in drainage channel B			
			Upper stream of B-1 (B-0)	Location where high radiation was detected on August 21 (B-1)	Downstream of B-1 (B-2)	In front of the confluence of drainage channel C (B-3)
Date of Sampling	Aug 22, 2013	Aug 22, 2013	Aug 22, 2013	Aug 22, 2013	Aug 22, 2013	Aug 22, 2013
Time of sampling	11:45 AM	12:10 PM	4:10 PM	3:55 PM	3:40 PM	3:25 PM
Cs-134(Approx. 2 years)	2.3	ND(18)	35	58	ND(20)	ND(19)
Cs-137(Approx.30 years)	3.8	ND(27)	49	150	ND(27)	39
All β	ND(21)	200	71	330	250	580

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Locations of each sampling point are provided as a reference. (August 23, 2013)

<Reference> Locations of each sampling point

