

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

		Groundwater around H4 area				
		E-1	E-2	E-3	E-4	E-5
Date of Sampling		Sep 8, 2013	Sep 8, 2013			
Time of sampling		9:20 AM	9:50 AM			
Cs-134 (Approx. 2 years)		2.5	0.64			
Cs-137 (Approx. 30 years)		5.1	0.74			
The other y						
All β		3200	67			
H-3 (Approx. 12 years)		4,200	290			

* Data announced this time is provided in a thick-frame. The other data was announced on September 9.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

