Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 13, 2013	Sep 13, 2013			
Time of sampling	10:00 AM	8:45 AM			
ΑΙΙ β	1,300	ND(15)			
H-3 (Approx. 12 years)	Under analysis	Under analysis			

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

