Sampling Results Regarding the Water Leak at the Tanks in the H4 area and the B area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

Unit: Bq/L

	Note 1 (near the drain		Side ditch next to the tank Note 4 (X-2)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	drainage channel C and the side ditch	Sampling points of the inside of drainage channel B					
		Junction of the drainage channels B and C Note 2 (C-1)				high dose equivalent		Point immediately short of the junction with the drainage channel C (B-3)	Point near Fureai Intersection in the drainage channel B Note 3 (B-0-1)	Point near the main gate in the drainage channel C Note 3 (C-0)	Drainage channel C
Date of Sampling	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013	Oct 13, 2013
Time of sampling	10:40 AM	11:35 AM	4:31 PM	11:10 AM	11:25 AM	*	*	*	11:50 AM	12:00 PM	10:20 AM
Cs-134(Approx. 2 years)	ND(1.4)	ND(18)	83	43	ND(19)	*	*	*	21	ND(18)	ND(19)
Cs-137(Approx.30 years)	ND(1.6)	ND(26)	220	88	ND(26)	*	*	*	50	ND(27)	ND(27)
Allβ	ND(18)	ND(13)	6,500	4,000	ND(13)	*	*	*	150	ND(13)	ND(13)

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

Note 3: Water inflow location of drainage channel to the tank area

Note 4: Since the analysis result of the sample obtained at 11:05 AM on October 13 was considered to be affected by sediment, the ampling was performed again.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* The sampling could not ber performed since there was no water left.

