# Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

## I-131(Bq/cm<sup>3</sup>)

Sampling	After tra	ınsfer																			
Location	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29	Dec 30	Dec 31	Jan 1	Jan 2	Jan 3	Jan 4	Jan 5	Jan 6	Jan 7	Jan 8	Jan 9	Jan 10	Jan 11	Jan 12
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

#### Cs-134(Bq/cm<sup>3</sup>)

Sampling																					
Location	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29	Dec 30	Dec 31	Jan 1	Jan 2	Jan 3	Jan 4	Jan 5	Jan 6	Jan 7	Jan 8	Jan 9	Jan 10	Jan 11	Jan 12
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-
	0.086	0.1	0.067	0.12	0.041	0.12	0.085	0.12	0.27	0.072	0.13	0.11	0.12	0.11	0.089	0.087	0.17	0.13	0.11	0.067	0.12
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								

## Cs-137(Bq/cm<sup>3</sup>)

Sampling																					
Location	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29	Dec 30	Dec 31	Jan 1	Jan 2	Jan 3	Jan 4	Jan 5	Jan 6	Jan 7	Jan 8	Jan 9	Jan 10	Jan 11	Jan 12
	ND	ND	ND	ND	ND	ND	ND	ND	0.029	ND	ND	ND	ND								
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-
	0.14	0.17	0.12	0.2	0.063	0.21	0.16	0.2	0.51	0.12	0.22	0.22	0.17	0.18	0.17	0.15	0.28	0.22	0.22	0.13	0.25
	ND	ND	0.026	ND	ND	0.025	ND	ND	ND	ND	0.022	ND	ND	ND							
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								

- \* Hyphen "-" indicates that neither sampling nor measurement was implemented.
- \* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at
- \* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.
- \* Samping at since May 30, 2011
- \* Sampling at has been done since August 2, 2011
- \* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm<sup>3</sup>, Cs-134: Approx.0.02Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (January 12, 2013)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

### <Place of Sampling>

Southeast of Unit 4 Turbine Building

Northeast of the Process Main Building

Southeast of the Process Main Building

Southwest of the Process Main Building

South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building

Southwest Part of the On-site Bunker Building

West Side of the Incineration Workshop Building

North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southeast Part of the On-site Bunker Building