


Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank

East seawall break



— : Location where ground improvement construction was completed, or being implemented (as of January 31, 2014)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16
Date of sampling					Feb 13, 2014		Feb 13, 2014	Feb 13, 2014			Feb 13, 2014	Feb 13, 2014	Feb 13, 2014	Feb 13, 2014
Time of sampling					12:00 PM		10:35 AM	10:50 AM			11:18 AM	9:35 AM	9:51 AM	9:57 AM
Chloride (unit: ppm)					-		-	-			-	-	-	-
Cs-134 (Approx. 2 years)					ND(0.41)		ND(0.62)	2400.00			0.50	9.4	1.1	ND(2.2)
Cs-137 (Approx.30 years)					ND(0.43)		0.69	5900.00			1.5	23	2.4	4.00
The other y					Mn-54 (Approx. 310 days)		0.39	ND	320		ND	ND	ND	ND
					Co-60 (Approx. 5 years)		ND	ND	770		ND	ND	ND	ND
Gross β						ND(19)	440	640000			ND(19)	140	440	3,000,000
H-3 (Approx. 12 years)						74,000	230,000	15,000			10,000	33,000	23,000 ^{*1}	8,700
Sr-90 (Approx. 29 years)						-	Under analysis	Under analysis			Under analysis	Under analysis	Under analysis	Under analysis

	Underground water observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-4	Underground water observation hole No.3-5
Date of sampling	Feb 13, 2014											
Time of sampling	10:54 AM											
Chloride (unit: ppm)	-											
Cs-134 (Approx. 2 years)	ND(0.43)											
Cs-137 (Approx.30 years)	ND(0.49)											
The other y	Mn-54 (Approx. 310 days)	ND										
	Co-60 (Approx. 5 years)	ND										
Gross β	ND(19)											
H-3 (Approx. 12 years)	15,000											
Sr-90 (Approx. 29 years)	Under analysis											

* Data announced this time is provided in a thick-frame. The other data was announced on February 14.

** "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

** "-" indicates that the measurement was out of range.

*1 The highest dose among the results previously announced in the "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection".

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16
Date of sampling					Feb 17, 2014		Feb 17, 2014	Feb 17, 2014	Feb 17, 2014		Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014
Time of sampling					12:00 PM		9:49 AM	10:29 AM	10:09 AM		9:08 AM	9:12 AM	9:26 AM	9:36 AM
Chloride (unit: ppm)					-		-	-	-		-	-	-	-
Cs-134 (Approx. 2 years)					ND(0.48)		ND(0.45)	2,900 ^{*1}	39		0.53	4.2	5.4 ^{*1}	ND(2.1)
Cs-137 (Approx.30 years)					ND(0.58)		ND(0.55)	7,300 ^{*1}	93		1.5	10	13 ^{*1}	4.7 ^{*1}
The other γ	Mn-54 (Approx. 310 days)				0.62		ND	320	8.3		ND	ND	ND	ND
	Co-60 (Approx. 5 years)				ND		ND	750	0.59		ND	ND	ND	ND
	Ru-106 (Approx. 370 days)				ND		4.5	ND	ND		ND	ND	ND	ND
Gross β					ND(19)		390	760,000 ^{*1}	56,000		19	420	730 ^{*1}	2,000,000
H-3 (Approx. 12 years)					Under analysis		Under analysis	Under analysis	Under analysis		Under analysis	Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)					-		-	-	Under analysis		-	-	-	-


	Underground water observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-4	Underground water observation hole No.3-5
Date of sampling	Feb 17, 2014	Feb 17, 2014										
Time of sampling	9:32 AM	10:00 AM										
Chloride (unit: ppm)	-	-										
Cs-134 (Approx. 2 years)	ND(0.49)	5.6										
Cs-137 (Approx.30 years)	ND(0.56)	12										
The other γ	Mn-54 (Approx. 310 days)	ND	1.9 ^{*1}									
	Co-60 (Approx. 5 years)	ND	ND									
	Ru-106 (Approx. 370 days)	ND	ND									
Gross β	ND(19)	650,000										
H-3 (Approx. 12 years)	Under analysis	Under analysis										
Sr-90 (Approx. 29 years)	-	-										

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

*¹ The highest dose among the results previously announced in the "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection".

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Seawater)



Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Time of sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/	/	90	10
Gross β	/	/	/	/	/	/	/	/	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	/	/	30	10

Unit: Bq/L

	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	Feb 14, 2014	Feb 14, 2014	Feb 14, 2014	Feb 14, 2014	Feb 14, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014		
Time of sampling	/	/	9:05 AM	9:10 AM	9:13 AM	9:16 AM	9:07 AM	10:31 AM	10:37 AM	10:43 AM	10:50 AM	10:57 AM		
Cs-134(Approx. 2 years)	/	/	ND(1.0)	1.8	1.6	ND(1.3)	2.5	ND(0.73)	ND(0.74)	ND(0.77)	ND(0.83)	ND(0.83)	60	10
Cs-137(Approx.30 years)	/	/	2.8	5.4	3.5	3.1	5.6	ND(0.59)	ND(0.65)	ND(0.59)	ND(0.81)	ND(0.76)	90	10
Gross β	/	/	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)		
H-3 (Approx. 12 years)	/	/	2.3	15	2.4	2.3	5.6	ND(1.6)	ND(1.6)	ND(1.6)	ND(1.6)	ND(1.6)	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	-	-	-	-	-	-	-	-	-	-	30	10

* Data announced this time is provided in a thick-frame. The other data was announced on February 13 and 15.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm³ to Bq/L]).

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (4/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014		Feb 17, 2014	Feb 17, 2014			Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014		
Time of sampling	7:05 AM	7:10 AM	6:47 AM		7:20 AM	6:53 AM			6:58 AM	7:00 AM	7:08 AM	7:13 AM		
Cs-134(Approx. 2 years)	N D(0.81)	N D(2.7)	N D(2.1)		9.0	24			28	21	30	19	60	10
Cs-137(Approx.30 years)	1.8	N D(2.5)	5.9		29	64			67	47	70	46	90	10
Gross β	8.4	25	21		79	250			290	210	160	200		
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis		Under analysis	Under analysis			Under analysis	Under analysis	Under analysis	Under analysis	60,000	10,000
Sr-90(Approx. 29 years)	-	-	-		Under analysis	Under analysis			Under analysis	Under analysis	Under analysis	Under analysis	30	10

Unit: Bq/L

	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014	Feb 17, 2014							
Time of sampling	7:11 AM	6:05 AM	9:27 AM	9:36 AM	9:40 AM	9:44 AM	9:31 AM							
Cs-134(Approx. 2 years)	13	N D(0.71)	N D(1.7)	N D(1.2)	1.5	N D(1.6)	1.6						60	10
Cs-137(Approx.30 years)	35	0.64	2.0	3.5	4.9	3.1	3.8						90	10
Gross β	110	11	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)							
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis						60,000	10,000
Sr-90(Approx. 29 years)	Under analysis	Under analysis	Under analysis	-	-	-	-						30	10

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm³ to Bq/L]).

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-1-1	Groundwater observation hole No.0-1-2	Groundwater observation hole No.0-2	Groundwater observation hole No.0-3-1	Groundwater observation hole No.0-3-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1*	Groundwater observation hole No.1-2*	Groundwater observation hole No.1-3*	Groundwater observation hole No.1-4*	Groundwater observation hole No.1-5*
Cs-134 (Approx. 2 years)	7.6 [12/15]	ND	ND	0.61 [10/13]	0.44 [11/24]	0.82 <1/14>	ND	13 [8/29]	1.9 [7/8]	11,000 [7/9]	10 [9/2]	1.5 [7/8]	310 [8/5]
Cs-137 (Approx.30 years)	19 ^{*2} <1/26>	0.58 [12/7]	0.51 [11/17]	2.2 <1/12>	0.86 [11/20]	2.1 <1/14>	1.4 <1/12>	31 [8/29]	3.6 [7/8]	22,000 [7/9]	24 [9/2]	3.6 [7/8]	650 [8/5]
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	0.62 <2/3>	ND	ND	1.0 [7/5]	62 [7/5]	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	ND	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12] [8/26]	ND	12 [8/8]
Gross β	300 [8/22]	21 [12/7]	21 [11/10]	87 [10/13]	ND	67 ^{*1} [12/11]	29 [12/29]	1,900 [5/24]	4,400 [7/8]	900,000 [7/5] [7/9]	160,000 [8/12] [8/15]	380 [8/19]	56,000 [8/5]
H-3 (Approx. 12 years)	45,000 [8/29]	18,000 [12/7]	74,000 [12/15] <1/19>	6,400 <1/26>	ND	76,000 <2/6>	48,000 <1/26> <2/3>	500,000 [5/24] [6/7]	630,000 [7/8]	430,000 [9/16]	290,000 [7/12]	98,000 [7/11]	72,000 [8/15]
Sr-90(Approx. 29 years)	140 [8/8]	Under analysis	Under analysis	0.73 [9/2]	Under analysis	Under analysis	Under analysis	1,300 [8/22]	2,300 [6/28]	5,000,000 [7/5]	130,000 [8/8]	200 [7/8]	5,100 [8/22]

Unit: Bq/L

	Groundwater observation hole No.1-6	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-10	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-13	Groundwater observation hole No.1-14	Groundwater observation hole No.1-16	Groundwater observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)
Cs-134 (Approx. 2 years)	2,400 <2/13>	47 [11/25]	170 [9/3]	-	1.1 <1/13>	74 [10/21]	37,000 <2/13>	1.2 ^{*1} [11/14]	3.1 ^{*1} [12/13]	1.2 [12/5]	110 [9/23]
Cs-137 (Approx.30 years)	5,900 <2/13>	110 [11/25]	380 [9/3]	-	2.8 <1/13>	170 [10/21]	93,000 <2/13>	2.4 <2/13>	4.0 <2/13>	0.66 [12/12]	250 [9/23]
The other y	Ru-106 (Approx. 370 days)	ND	ND	-	ND	5.4 [10/28]	ND	ND	9.2 [10/28]	4.1 [12/12]	25 [9/2]
	Mn-54 (Approx. 310 days)	320 <2/13>	12 <2/3>	ND	-	ND	ND	ND	ND	ND	1.1 <2/10>
	Co-60 (Approx. 5 years)	770 <2/13>	1.3 <2/3>	ND	-	0.51 [10/24]	ND	ND	0.9 [11/7]	0.61 [11/25]	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	-	61 [10/21]	ND	ND	11 [12/5]	2.1 [11/25]	ND
Gross β	640,000 <2/13>	59,000 <2/3>	2,100 ^{*3} [11/17]	78 ^{*3} <1/27>	2,300 [12/26]	730 [10/21]	260,000 <2/12> <2/13>	440 <1/30> <2/13>	3,100,000 <1/30> <2/3>	130 [12/2] [12/23]	700,000 [9/23]
H-3 (Approx. 12 years)	110,000 ^{*3} <2/6>	12,000 <1/6> <2/3>	860 ^{*3} [11/14]	270,000 ^{*3} <1/27>	85,000 [9/13]	440,000 [10/31]	88,000 <2/12>	19,000 <2/3> <2/6>	43,000 [9/26]	32,000 <1/20>	460,000 [8/19]
Sr-90(Approx. 29 years)	-	1,300 [9/16]	170 [9/3]	-	17 [9/13]	Under analysis	-				

Unit: Bq/L

	Groundwater observation hole No.2	Groundwater observation hole No.2-1*	Groundwater observation hole No.2-2	Groundwater observation hole No.2-3	Groundwater observation hole No.2-5	Groundwater observation hole No.2-6	Groundwater observation hole No.2-7	Groundwater observation hole No.2-9	Groundwater pumped up from the well point (between Unit 2 and 3)	Groundwater observation hole No.3	Groundwater observation hole No.3-1*	Groundwater observation hole No.3-4	Groundwater observation hole No.3-5
Cs-134 (Approx. 2 years)	0.50 [7/9]	0.66 [9/1]	15 <2/12>	0.84 <1/5>	25 <2/12>	0.56 [10/30]	1.5 <1/12>	-	1.1 [12/12]	3.5 [7/25]	1.2 [7/25] [8/8]	1.9 <1/8>	64 <1/15>
Cs-137 (Approx.30 years)	1.2 [7/11] [8/1]	1.1 [8/29] [9/1]	38 <2/12>	2.6 <1/5>	62 <2/12>	0.80 <2/13>	3.6 <1/12>	0.58 ^{*2} <2/11>	2.6 <2/16>	5.9 [8/8]	2.6 [8/1]	4.3 [11/27]	170 <1/15>
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND	6.5 ^{*2} <2/11>	ND	ND	ND	ND	-
	Mn-54 (Approx. 310 days)	ND	ND	ND	0.29 [12/6]	0.94 <1/8>	ND	-	ND	ND	ND	0.54 [10/30]	-
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	-	ND	ND	ND	ND	-
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	30 <2/12>	ND	ND	-	ND	1.6 <1/1>	ND	ND
Gross β	1,700 [7/8]	380 [7/29]	540 <1/29>	1,500 [12/6]	150,000 <2/12>	3,200 [12/5]	270 [12/20]	1,700 ^{*3} <2/7>	240,000 [12/12]	1,400 [7/11]	180 [8/1]	17 <2/12>	69 <1/29>
H-3 (Approx. 12 years)	870 [12/8] <2/12>	440 [8/26]	660 <1/8>	1,700 [12/6]	6,300 [12/4]	1,200 [11/24] [11/27]	1,100 <1/17>	13,000 ^{*3} <2/7>	5,100 [12/6]	3,200 [2012/12] [12]	460 [8/1]	170 [9/18]	170 <1/8>
Sr-90(Approx. 29 years)	54 [5/31]	5.9 [7/25]	Under analysis	-	-	8.3 [2012/12] [12]	4.4 [7/23]	ND	-				

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

*1 Analysis result of pumped water.

*2 The results are for a reference, since the water was highly turbid. (γ and Gross β were measured after filtration.)

*3 The results are for a reference, since the water was highly turbid. (γ and Gross β were measured after filtration. If filtration takes a long time, γ will not be analyzed.)

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses. (): 2013, < >: 2014

* "" is provided next to the name of the holes where the sampling could not be performed due to the chemical injection of ground improvement.

<Reference> The Highest Dose Until the Previous Measurement* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4
Cs-134(Approx. 2 years)	1.8 [6/21]	2.8 [12/2]	5.3 [8/5]	89 [10/10]	32 [10/11]	73 [10/10]	87 [10/10]	93 [10/10]	370 [10/9]	52 [12/21]	350 [7/15]	28 [9/16]
Cs-137(Approx.30 years)	3.3 [6/26]	5.8 [12/2]	8.6 [8/5]	190 [10/10]	73 [10/11]	170 [10/10]	200 [10/10]	200 [10/10]	830 [10/9]	110 [10/11] [12/21]	770 [7/15]	53 [12/16]
Gross β	17 <1/6>	46 [8/19]	40 [7/3]	1,400 [11/7]	320 [8/12]	740 [10/28]	1,200 [12/8]	450 [7/16]	1,700 [10/9]	480 [10/7]	1,000 [7/15]	390 [8/12]
H-3 (Approx. 12 years)	8.6 [6/26]	24 [8/19]	340 [6/26]	4,800 [11/7]	510 [9/2]	2,800 [10/28]	2,800 [12/8]	1,600 [9/1]	2,100 [10/28]	1,200 [10/7]	410 [9/2]	650 [8/12]
Sr-90 (Approx. 29 years)	5.8 [6/26] ^{**1}	—	7.4 [6/26] ^{**1}	720 [9/22]	220 [8/19]	480 [10/14]	480 [8/22]	290 [10/20]	430 [10/14]	340 [10/14]	120 [9/23]	190 [9/23]

Unit: Bq/L

	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the south breakwater	Southeast side of the north breakwater	South side of the south breakwater
Cs-134(Approx. 2 years)	62 [9/16]	ND	3.3 [12/24]	3.3 [10/17]	4.4 [12/24]	5.0 [12/2]	3.5 [10/17]	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	140 [9/16]	3.0 [7/15]	7.3 [10/11]	9.0 [10/17]	10 [12/24]	8.4 [12/2]	7.8 [10/17]	ND	ND	1.6 [10/18]	ND	ND
Gross β	360 [10/7]	15 <1/13>	69 [8/19]	74 [8/19]	60 [7/4]	69 [8/19]	79 [8/19]	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	400 [8/12] [10/7]	1.9 [11/25]	68 [8/19]	67 [8/19]	59 [8/19]	52 [8/19]	60 [8/19]	4.7 [8/14]	ND	6.4 [10/8]	ND	ND
Sr-90 (Approx. 29 years)	130 [9/23]	0.36 [6/26] ^{**1}	49 [8/19]	-	-	-	-	-	-	-	-	-

* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

*1 Since reanalysis is ongoing, the figures are just for a reference.

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses. (): 2013, < >: 2014

** "-" indicates that the measurement was out of range.

[Reference] Standard values

Unit: Bq/L

	Cs-134	Cs-137	H-3	Sr-90
Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2)	60	90	60,000	30
WHO Guidelines for drinking-water quality	10	10	10,000	10