


Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Seaside impermeable

— : Location where ground improvement construction was completed, or being implemented (as of April 18, 2014)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8 **	Underground water observation hole No.1-9 (note)	Underground water observation hole No.1-11 **	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16 **	Underground water observation hole No.1-17
Date of sampling										Nov 9					
Time of sampling										7:22 AM					
Chloride (unit: ppm)										19					
Cs-134 (Approx. 2 years)										—					
Cs-137 (Approx.30 years)										—					
The other γ															
Gross β										ND(19)					
H-3 (Approx. 12 years)										ND(100)					
Sr-90 (Approx. 29 years)										—					

	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5 (note)	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5(note)
Date of sampling														
Time of sampling														
Chloride (unit: ppm)														
Cs-134 (Approx. 2 years)														
Cs-137 (Approx.30 years)														
The other γ														
Gross β														
H-3 (Approx. 12 years)														
Sr-90 (Approx. 29 years)														

* Data announced this time is provided in a thick-frame. The other data was announced on November 10, 2014.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses, except "the other γ".

* "-" indicates that the measurement was out of range.

(Note) As of No. 1-9, 2-5, and 3-5, γ was not measured because they are sampled by sampler. Gross β were measured after filtration for references.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9(note)	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Underground water observation hole No.1-17
Date of sampling										Nov 11					
Time of sampling										7:36 AM					
Chloride (unit: ppm)										20					
Cs-134 (Approx. 2 years)										—					
Cs-137 (Approx.30 years)										—					
The other γ															
Gross β										ND(19)					
H-3 (Approx. 12 years)										Under analysis					
Sr-90 (Approx. 29 years)										—					

	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5(note)	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5(note)
Date of sampling						Nov 11								
Time of sampling						8:53 AM								
Chloride (unit: ppm)						—								
Cs-134 (Approx. 2 years)						ND(0.41)								
Cs-137 (Approx.30 years)						ND(0.53)								
The other γ														
Gross β						2500								
H-3 (Approx. 12 years)						Under analysis								
Sr-90 (Approx. 29 years)						—								

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses, except "the other γ"

* "—" indicates that the measurement was out of range.

(Note) As of No. 1-9, 2-5, and 3-5, γ was not measured because they are sampled by sampler. Gross β were measured after filtration for references.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-1-1	Groundwater observation hole No.0-1-2	Groundwater observation hole No.0-2	Groundwater observation hole No.0-3-1	Groundwater observation hole No.0-3-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1 [*]	Groundwater observation hole No.1-2 [*]	Groundwater observation hole No.1-3 [*]	Groundwater observation hole No.1-4 [*]	Groundwater observation hole No.1-5 [*]	Groundwater observation hole No.1-6
Cs-134 (Approx. 2 years)	29 <5/25>	ND	0.61 <3/2>	0.61 [10/13]	0.64 <4/6>	1.3 <9/25>	0.70 <6/29>	13 [8/29]	1.9 [7/8]	11,000 [7/9]	10 [9/2]	1.5 [7/8]	310 [8/5]	67,000 <10/17>
Cs-137 (Approx.30 years)	78 <5/25>	ND	1.5 <3/2>	2.2 <1/12>	1.1 <4/6>	5.1 <9/25>	1.6 <6/29>	31 [8/29]	3.6 [7/8]	22,000 [7/9]	24 [9/2]	3.6 [7/8]	650 [8/5]	200,000 <10/16>
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	ND	0.64 <2/20>	ND	ND	1.0 [7/5]	62 [7/5]	ND	ND	700 <10/13>
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND	3600 <10/13>
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	ND	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12] [8/28]	ND	12 [8/8]	34 <5/19>
Gross β	300 [8/29] <5/18>	21 [12/7]	24 <6/22>	87 [10/13]	ND	74 <10/9>	44 <6/22>	1,900 [5/24]	4,400 [7/8]	9,300,000 [7/8]	160,000 [8/12] [8/15]	380 [8/19]	56,000 [8/5]	7,800,000 <10/13>
H-3 (Approx. 12 years)	45,000 [8/29]	18,000 [12/7]	74,000 [12/15] <1/19>	6,800 <2/16>	ND	76,000 <2/6>	56,000 <2/23>	500,000 [5/24] [6/7]	630,000 [7/8]	430,000 [9/16]	290,000 [7/12]	98,000 [7/11]	72,000 [8/15]	110,000 ^{*2} <2/6>
Sr-90(Approx. 29 years)	140 [8/8]	7.9 [12/7]	2.6 [11/10]	0.73 [9/2]	1.5 [11/20]	2.3 [12/6]	ND(0.83) [10/27]	1,300 [8/22]	2,300 [6/28]	5,000,000 [7/5]	130,000 [8/8]	200 [7/8]	5,100 [8/22]	1,100,000 <8/4>

Unit: Bq/L

	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-10	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-13	Groundwater observation hole No.1-14	Groundwater observation hole No.1-15	Groundwater observation hole No.1-16	Groundwater observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)	Groundwater observation hole No.2	Groundwater observation hole No.2-1 [*]	Groundwater observation hole No.2-2
Cs-134 (Approx. 2 years)	47 [11/25]	170 [9/3]	-	1.1 <1/13>	74 [10/21]	37,000 <2/13>	130 <10/18>	ND	30 <7/28>	1.4 <7/7>	110 [9/23]	0.88 <2/26>	0.66 [9/1]	15 <2/12>
Cs-137 (Approx.30 years)	110 [11/25]	380 [9/3]	-	3.4 <4/28>	170 [10/21]	93,000 <2/13>	390 <10/20>	0.88 <7/10>	86 <7/28>	3.0 <9/29>	250 [9/23]	2.5 <2/26>	1.1 [8/29] [9/1]	38 <2/12>
The other y	Ru-106 (Approx. 370 days)	ND	ND	-	ND	5.4 [10/28]	ND	ND	9.2 [10/28]	5.5 <4/21> <5/1>	25 [9/2]	ND	ND	ND
	Mn-54 (Approx. 310 days)	12 <2/3>	ND	-	ND	ND	2.1 <9/8>	ND	11 <8/25>	ND	54 <11/10>	ND	ND	ND
	Co-60 (Approx. 5 years)	1.3 <2/3>	ND	-	ND	0.51 [10/24]	ND	0.44 <5/29>	ND	0.9 [11/7]	0.61 [11/25]	0.61 <6/9>	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	-	ND	61 [10/21]	ND	ND	24 <6/16>	2.1 [11/25]	ND	ND	ND	ND
Gross β	59,000 <2/3>	2,100 ^{*2} [11/17]	78 ^{*2} <1/27>	2,300 [12/26]	1,100 <5/5>	260,000 <2/12> <2/13>	29,000 <10/3>	110 <7/10>	3,100,000 <1/20> <2/3>	1,200,000 <10/9>	2,100,000 <11/10>	1,700 [7/8]	380 [7/29]	600 <4/16>
H-3 (Approx. 12 years)	33,000 <6/2>	860 ^{*2} [11/14]	270,000 ^{*2} <1/27>	85,000 [9/13]	440,000 [10/31]	88,000 <2/12>	23,000 <2/13>	74,000 <7/10>	43,000 [9/26]	160,000 <10/13> <10/16>	460,000 [8/19]	1,000 <2/23>	440 [8/26]	660 <1/8>
Sr-90(Approx. 29 years)	35,000 <2/17>	300 [10/3]	-	170 <8/4>	290 [10/21]	160,000 <2/12>	13,000 <8/4>	Under analysis	2,700,000 <2/13>	170,000 <8/4>	-	54 [5/31]	5.9 [7/25]	320 [12/25]

Unit: Bq/L

	Groundwater observation hole No.2-3	Groundwater observation hole No.2-5	Groundwater observation hole No.2-6	Groundwater observation hole No.2-7	Groundwater observation hole No.2-8	Groundwater observation hole No.2-9	Groundwater pumped up from the well point (between Unit 2 and 3)	Groundwater observation hole No.3	Groundwater observation hole No.3-1 [*]	Groundwater observation hole No.3-2	Groundwater observation hole No.3-3	Groundwater observation hole No.3-4	Groundwater observation hole No.3-5
Cs-134 (Approx. 2 years)	2.2 <2/26>	41 <5/7>	17 <3/11>	3.5 <2/23>	1.3 <7/20>	ND	2.2 <9/7>	3.5 [7/25]	1.2 [7/25] [8/8]	23 <8/27>	180 <7/2>	5.1 <7/23>	100 <7/30>
Cs-137 (Approx.30 years)	5.5 <2/26>	110 <5/7>	50 <3/11>	9.0 <2/23>	3.4 <7/20>	0.58 ^{*2} <2/11>	5.7 <9/7>	5.9 [8/8]	2.6 [8/1]	68 <9/3>	500 <7/2>	16 <8/27>	310 <7/30>
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	6.5 ^{*2} <2/11>	ND	ND	ND	ND	ND	-
	Mn-54 (Approx. 310 days)	0.29 [12/6]	0.95 <6/4>	ND	ND	ND	ND	ND	ND	ND	ND	0.54 [10/30]	-
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	-
	Sb-125 (Approx. 3 years)	ND	74 <5/7>	ND	ND	ND	ND	ND	1.6 <1/1>	ND	ND	ND	-
Gross β	1,500 [12/6] <1/8>	150,000 <2/12>	3,200 [12/5] <11/6>	1,300 <6/20>	5,800 <7/23>	1,700 <2/7>	240,000 [12/12]	1,400 [7/11]	180 [8/1]	3,100 <8/20> <8/28>	8,900 <7/2>	46 <8/13>	510 <7/16>
H-3 (Approx. 12 years)	1,700 [12/6]	7,900 <4/9>	1,900 <8/10>	1,100 <1/19>	1,700 <4/6> <8/6> <8/13>	13,000 ^{*2} <2/7> <2/11>	13,000 <10/19> <10/26> <10/29>	3,200 [Dec 12,2012]	460 [8/1]	3,700 <7/9>	8,000 <5/7>	170 [9/18]	170 <1/8>
Sr-90(Approx. 29 years)	1,200 [12/6]	34,000 <5/7>	Under analysis	ND(1.4) [11/21]	3,900 <3/30>	1,200 ^{*2} <2/11>	-	8.3 [Dec 12,2012]	4.4 [7/23]	2000 <4/18>	3,600 <4/30>	ND	200 <5/28>

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

*1 Analysis result of pumped water.

*2 The results are for a reference, since the water was highly turbid. (γ and Gross β were measured after filtration.)

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses. () : 2013, < > : 2014

* *** is provided next to the name of the holes where the sampling could not be performed due to the chemical injection of ground improvement.

(Note) As of No. 1-9, 2-5, and 3-5, since September 17, γ was not measured because they are sampled by sampler. Gross β were measured after filtration for references.