

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building <1/3>

(Data summarized on October 24)

Place of Sampling	Upper Part of Unit 1 Reactor Building ① (The Entrance of Cover Exhaust System Filter) (Particulate Filter)		Upper Part of Unit 1 Reactor Building ② (Northwest of cover) (Particulate Filter)		Upper Part of Unit 1 Reactor Building ③ (Northeast of cover) (Particulate Filter)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Oct 2, 2014 5:36 AM - 6:36 AM	Oct 2, 2014 9:41AM - 10:41 AM	Oct 2, 2014 8:40 AM - 9:40 AM			
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	7.6E-06	0.00	7.2E-06	0.00	2E-03
Cs-137 (Approx. 30 years)	ND	-	2.8E-05	0.01	2.5E-05	0.01	3E-03

0.0E-0 is the same as 0.0 x 10⁰

Data of other nuclides is under examination.

* In the case of 2 nuclides or more, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Particulate: I-131: Approx. 7E-7Bq/cm³, Cs-134: Approx.8E-7Bq/cm³, Cs-137: Approx.1E-6Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building<2/3>

(Data summarized on October 24)

Place of Sampling	Upper Part of Unit 1 Reactor Building ④ (Southwest of cover) (Particulate Filter)		Upper Part of Unit 1 the Reactor Building⑤ (Reactor Building operation floor opening) (Particulate Filter)		Upper Part of Unit 1Reactor Building⑥ (ceiling of spent fuel pool) (Particulate Filter)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	6.8E-06	0.00	6.8E-06	0.00	9.2E-06	0.00	2E-03
Cs-137 (Approx. 30 years)	2.4E-05	0.01	2.5E-05	0.01	3.0E-05	0.01	3E-03

0.0E-0 is the same as 0.0 x 10⁻⁰

Data of other nuclides is under examination.

* In the case of 2 nuclides or more, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Particulate: I-131: Approx. 7E-7Bq/cm³

As the detection limit may vary depending on the detectors and sample

properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building <3/3>

(Data summarized on October 24)

Place of Sampling	Upper Part of Unit 1 Reactor Building⑦ (ceiling of spent fuel pool) (Charcoal Filter)						② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
Time of Sampling	Oct 2, 2014 11:06 AM - 11:16 AM						
Detected Nuclides (Half-life)							
I-131 (Approx. 8 days)	ND	-					1E-03
Cs-134 (Approx. 2 years)	ND	-					2E-03
Cs-137 (Approx. 30 years)	ND	-					3E-03

O.OE—O is the same as O.O x 10^{-O}

Data of other nuclides is under examination.

* In the case of 2 nuclides or more, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 3E-6Bq/cm³, Cs-134: Approx.6E-6Bq/cm³, Cs-137: Approx.1E-5Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected. This shows the nuclides analysis results of particulate radioactive materials in the air.