

Nuclides Analysis Result of Unit 1 discharge channel at Fukushima Daiichi NPS

	Shaft water Unit 1 discharge channel	
	Upstream	Downstream
Date of Sampling	Oct 27	Oct 27
Time of Sampling	3:20 PM	3:00 PM
Cs-134 (Approx. 2 years)	31,000	1,700
Cs-137 (Approx. 30 years)	95,000	5,300
All β	120,000	7,600
H-3 (Approx. 12 years)	320	810

Unit: Bq/L

* "ND" indicates that the measurement result is below the detection limit, as of individual Nuclide, detection limit level is showed in parenthesis.

