

Nuclides Analysis Result of Unit 1 discharge channel at Fukushima Daiichi NPS

Unit:Bq/L

	Shaft water Unit 1 discharge channel	
	Upstream	Downstream
Date of Sampling	Nov 4	Nov 4
Time of Sampling	12:30 PM	12:10 PM
Cs-134 (Approx. 2 years)	11,000	2,000
Cs-137 (Approx.30 years)	35,000	6,200
All β	45,000	8,800
H-3(Approx. 12 years)	360	760

* "ND" indicates that the measurement result is below the detection limit, as of individual Nuclide, detection limit level is showed in parenthesis.

