

Nuclides Analysis Result of Unit 1 discharge channel at Fukushima Daiichi NPS

Unit:Bq/L

	Shaft water Unit 1 discharge channel	
	Upstream	Downstream
Date of Sampling	Nov 10	Nov 10
Time of Sampling	11:50 AM	11:30 AM
Cs-134 (Approx. 2 years)	9,000	760
Cs-137 (Approx.30 years)	29,000	2,400
All β	45,000	3,800
H-3(Approx. 12 years)	370	810

* "ND" indicates that the measurement result is below the detection limit, as of individual Nuclide, detection limit level is showed in parenthesis.

