

### Nuclides Analysis Result of Unit 1 discharge channel at Fukushima Daiichi NPS

	Shaft water Unit 1 discharge channel	
	Upstream	Downstream
Date of Sampling	Nov 17	Nov 17
Time of Sampling	4:20 PM	3:05 PM
Cs-134 (Approx. 2 years)	8,300	560
Cs-137 (Approx. 30 years)	25,000	1,600
All β	34,000	3,100
H-3 (Approx. 12 years)	450	690

Unit: Bq/L

\* "ND" indicates that the measurement result is below the detection limit, as of individual Nuclide, detection limit level is showed in parenthesis.

