Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
June 11, 2014
Tokyo Electric Power Company

Unit: Ba/L

	Groundwater around H4 area													
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Date of Sampling	Jun 9, 2014	Jun 9, 2014	Jun 9, 2014	Jun 9, 2014	Jun 9, 2014		/	/	Jun 9, 2014					/
Time of sampling	9:11 AM	9:06 AM	8:57 AM	8:50 AM	8:42 AM				9:00 AM					
Gross β	18,000	ND(19)	ND(19)	26	ND(19)				830					
H-3 (Approx. 12 years)	37,000	340	4,700	1,000	670				ND(110)					

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7	
Gross β	710,000 [11/10]	650 [9/4]	570 (9/18)	1,300 [9/15]	100 [9/24]	46 [9/20]	50 <5/21>	
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	7,700<4/28>	2,600 <2/18,3/1>	3,100 [11/10,11/13]	350 [12/18] <1/1>	1,100 <2/19>	
	E-8	E-9	E-10	E-11	E-12	Well point	F-1	
Gross β	21 <5/21>	8,300 <2/28>	160 <4/8>	110 <2/5>	37 <1/23>	16,000 [11/28]	28 <4/25>	
H-3 (Approx. 12 years)	2,300 [11/13]	51,000 [11/25]	54,000 <1/21>	1,000 <2/12>	2,900 <2/12>	190,000 [11/30]	770 <2/25>	

Unit: Bq/L, sampling date is provided in parentheses. []: 2013, <>: 2014

