

Analysis results of temporary storage tanks for groundwater bypass at Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Gr3 (Group 3)		Operational targets	※1 Notification limit	WHO guidelines for drinking-water quality
	TEPCO	Third party organization			
Sampling Date	Sep 14, 2014	Sep 14, 2014			
Sampling time	9:56 AM	9:56 AM			
The volume of water in storage [m ³]	2,170	2,170			
Cesium 134	ND(0.68)	ND(0.89)	1	60	10
Cesium 137	ND(0.68)	ND(0.55)	1	90	10
Other Gamma Nuclide	Not detected	Not detected	Not to be detected ※2		
Gross β	ND(0.90)	ND(0.56)	5(1) ^(Note)		
Tritium	180	190	1,500	60,000	10,000

* Third party: Japan Chemical Analysis Center

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

(Note) The detection limit value for Grossβ of operational targets are defined as "Less than 1 Bq/L", when sampled once per approx. 10 days.

*1 Notified Concentration Limit Values: Specified in the rules for the safety and maintenance of nuclear reactor

facilities and the protection of specialized nuclear fuel materials in TEPCO Fukushima Daiichi Nuclear Power Station.

(Clause 6, Section 2 in appendix: Concentration limit value in the water outside the supervised area (Values shown in the table are converted to Bq/L from Bq/cm³))

*2 Other gamma nuclides (except naturally-occurring nuclides) must not be detected during the analysis Cs-134 and Cs-137.