

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of March 24 and 25, 2014)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Mar 25, 2014										Mar 24, 2014				
Sampled time		10:02 AM	9:38 AM	10:27 AM	10:30 AM	10:34 AM	10:37 AM	11:30 AM	11:04 AM	9:00 AM	10:36 AM	8:59 AM	9:48 AM	9:26 AM	10:22 AM
Chloride concentration (ppm)		9	12	12	23	82	10	9	9	9	12	9	9	15	8
Tritium (Bq/cm ³)		2.7E-1	<8.1E-3	1.3E-2	5.1E-2	9.2E-3	1.2E-1	7.7E-2	2.5E-2	6.4E-1	2.7E+0	6.7E-2	7.4E-2	4.3E-2	7.5E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.6E-2	<1.6E-2	<1.6E-2	<1.6E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on March 25 and 26.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.