

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of March 31 and April 1, 2014)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Apr 1, 2014										Mar 31, 2014				
Sampled time		10:07 AM	9:39 AM	10:41 AM	10:44 AM	10:48 AM	10:51 AM	10:57 AM	11:34 AM	9:05 AM	10:33 AM	9:59 AM	9:36 AM	10:27 AM	9:09 AM
Chloride concentration (ppm)		9	11	13	26	86	10	9	8	8	12	10	8	12	7
Tritium (Bq/cm ³)		2.6E-1	<8.6E-3	7.1E-3	5.4E-2	<6.3E-3	9.5E-2	7.3E-2	2.4E-2	6.4E-1	2.5E+0	6.2E-2	7.6E-2	4.5E-2	7.1E-2
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<1.6E-2	<1.6E-2	<1.6E-2	<1.6E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on April 1 and 2.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.