

Underground Reservoir Tritium Analysis Results (As of April 16, 2014)

| | Underground Reservoir (Drain hole water) | | | | | | | | | | | | | |
|-------------------------------|--|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | 8:11 AM | 8:32 AM | 8:04 AM | 8:21 AM | 8:00 AM | 7:45 AM | 9:30 AM | 9:37 AM | Out of range | Out of range | 9:13 AM | 8:57 AM | Out of range | Out of range |
| Tritium (Bq/cm ³) | <2.1E-1 | 2.3E-1 | <2.1E-1 | <2.1E-1 | <2.1E-1 | <2.1E-1 | 1.1E+0 | <2.1E-1 | | | 6.1E-1 | <2.1E-1 | | |

Half-life period Tritium: Approx. 12 years

| | Underground Reservoir (Leakage detector hole water) | | | | | | | | | | | | | |
|-------------------------------|---|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | 7:33 AM | 8:27 AM | 7:39 AM | 8:16 AM | 7:56 AM | 7:49 AM | 9:32 AM | Not sampled | | | 9:05 AM | Not sampled | | |
| Tritium (Bq/cm ³) | 2.8E-1 | <2.1E-1 | 7.1E-1 | <2.1E-1 | 2.2E-1 | <2.1E-1 | <2.1E-1 | | | | <2.1E-1 | | | |

Half-life period Tritium: Approx. 12 years

(Note 1) Analysis of tritium is conducted once a week.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.