

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Front of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Front of North Stairs)		② Density Limit in the Air for Workers to Engage in Radiation Related Tasks (Bq/cm <sup>3</sup> )*
Time of Sampling	From September 8, 2014 8:11 AM To September 9, 2014 9:16 AM		From September 8, 2014 8:14 AM To September 9, 2014 9:17 AM		From September 8, 2014 8:36 AM To September 9, 2014 9:13 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	3E-03
Mn-54 (Approx. 310 days)	ND	-	ND	-	ND	-	2E-02
Co-60 (Approx. 5 years)	2.2E-08	0.00	2.8E-08	0.00	5.1E-08	0.00	1E-03
Nb-95 (Approx. 35 days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (Approx. 6 hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (Approx. 370 days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (Approx. 250 days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (Approx. 3 yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (Approx. 70 mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (Approx. 34 days)	ND	-	ND	-	ND	-	4E-03
I-132 (Approx. 2 hrs)	ND	-	ND	-	ND	-	7E-02
I-132 (Approx. 78 hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (Approx. 21 hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
La-140 (Approx. 40 hrs)	ND	-	ND	-	ND	-	1E-02

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

\* O.OE—O is the same as O.O x 10<sup>0</sup>

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits of the major three nuclides not detected are as follows:

Volatile: I-131: Approx. 2E-8Bq/cm<sup>3</sup>, Cs-134: Approx. 4E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 3E-8Bq/cm<sup>3</sup>

Particulate: I-131: Approx. 1E-8Bq/cm<sup>3</sup>, Cs-134: 2E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-8Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Front of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Front of North Stairs)		② Density Limit in the Air for Workers to Engage in Radiation Related Tasks (Bq/cm <sup>3</sup> )*
Time of Sampling	From September 11, 2014 8:33 AM To September 12, 2014 9:06 AM		From September 11, 2014 8:27 AM To September 12, 2014 9:03 AM		From September 11, 2014 8:21 AM To September 12, 2014 9:00 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	3E-03
Mn-54 (Approx. 310 days)	ND	-	ND	-	ND	-	2E-02
Co-60 (Approx. 5 years)	ND	-	2.8E-08	0.00	ND	-	1E-03
Nb-95 (Approx. 35 days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (Approx. 6 hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (Approx. 370 days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (Approx. 250 days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (Approx. 3 yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (Approx. 70 mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (Approx. 34 days)	ND	-	ND	-	ND	-	4E-03
I-132 (Approx. 2 hrs)	ND	-	ND	-	ND	-	7E-02
I-132 (Approx. 78 hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (Approx. 21 hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
La-140 (Approx. 40 hrs)	ND	-	ND	-	ND	-	1E-02

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

\* O.OE-O is the same as O.O x 10<sup>0</sup>

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits of the major three nuclides not detected are as follows:

Volatile: I-131: Approx. 4E-8Bq/cm<sup>3</sup>, Cs-134: Approx. 7E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 1E-7Bq/cm<sup>3</sup>

Particulate: I-131: Approx. 2E-8Bq/cm<sup>3</sup>, Cs-134: 4E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 6E-8Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Front of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Front of North Stairs)		② Density Limit in the Air for Workers to Engage in Radiation Related Tasks (Bq/cm <sup>3</sup> )*
Time of Sampling	From September 14, 2014 8:10 AM To September 15, 2014 9:03 AM		From September 14, 2014 8:12 AM To September 15, 2014 9:05 AM		From September 14, 2014 8:07 AM To September 15, 2014 9:06 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	3E-03
Mn-54 (Approx. 310 days)	ND	-	ND	-	ND	-	2E-02
Co-60 (Approx. 5 years)	ND	-	4.0E-08	0.00	ND	-	1E-03
Nb-95 (Approx. 35 days)	ND	-	ND	-	ND	-	2E-02
Tc-99m (Approx. 6 hrs)	ND	-	ND	-	ND	-	7E-01
Ru-106 (Approx. 370 days)	ND	-	ND	-	ND	-	6E-04
Ag-110m (Approx. 250 days)	ND	-	ND	-	ND	-	3E-03
Sb-125 (Approx. 3 yrs)	ND	-	ND	-	ND	-	6E-03
Te-129 (Approx. 70 mins)	ND	-	ND	-	ND	-	4E-01
Te-129m (Approx. 34 days)	ND	-	ND	-	ND	-	4E-03
I-132 (Approx. 2 hrs)	ND	-	ND	-	ND	-	7E-02
I-132 (Approx. 78 hrs)	ND	-	ND	-	ND	-	4E-03
I-133 (Approx. 21 hrs)	ND	-	ND	-	ND	-	5E-03
Cs-136 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
Ba-140 (Approx. 13 days)	ND	-	ND	-	ND	-	1E-02
La-140 (Approx. 40 hrs)	ND	-	ND	-	ND	-	1E-02

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

\* O.OE-O is the same as O.O x 10<sup>-O</sup>

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits of the major three nuclides not detected are as follows:

Volatile: I-131: Approx. 4E-8Bq/cm<sup>3</sup>, Cs-134: Approx. 7E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 1E-7Bq/cm<sup>3</sup>

Particulate: I-131: Approx. 3E-8Bq/cm<sup>3</sup>, Cs-134: 4E-8Bq/cm<sup>3</sup>, Cs-137: Approx. 6E-8Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.