

Sampling Results of Pump Wells of the Groundwater Bypass at Fukushima Daiichi Nuclear Power Station

<Reference>
May 14, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass											
	No.1	No.2	No.3	No.4	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling		May 12, 2014		May 12, 2014		May 12, 2014		May 12, 2014		May 12, 2014		May 12, 2014
Time of sampling		9:46 AM		9:50 AM		9:58 AM		10:04 AM		10:08 AM		10:20 AM
Gross β		ND(12)		ND(12)		ND(12)		ND(12)		ND(12)		ND(4.6)
H-3 (Approx. 12 years)		31		120		170		74		230		1,200

(Note) The detection limit is set as less than 5Bq/L for gross β obtained in pump well No.7 and No.12.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	No.1	No.2	No.3	No.4	No.5	No.6
Gross β	ND	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	40 [11/26]	84 [12/31]	72 <5/8>	120 <3/25>	48 <3/25>	230 <4/8>

	No.7	No.8	No.9	No.10	No.11	No.12
Gross β	ND	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	690 <4/8>	100 <4/22>	110 <5/1>	330 [9/1,9/2]	480 [10/22,11/5]	1,600 <4/15>

* The sampling date is provided in parentheses. []: 2013, < >: 2014

