

Sampling Results of Pump Wells of the Groundwater Bypass at Fukushima Daiichi Nuclear Power Station

<Reference>
June 7, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass											
	No.1	No.2	No.3	No.4	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Jun 5, 2014	/	Jun 5, 2014	/	Jun 5, 2014	/	Jun 5, 2014	/	Jun 5, 2014	/	Jun 5, 2014	Jun 5, 2014
Time of sampling	8:40 AM	/	8:42 AM	/	8:50 AM	/	8:53 AM	/	8:57 AM	/	9:04 AM	9:07 AM
Gross β	ND(14)	/	ND(14)	/	ND(14)	/	ND(4.2)	/	ND(14)	/	ND(14)	ND(4.2)
H-3 (Approx. 12 years)	ND(3.8)	/	10	/	15	/	95	/	67	/	400	1,700

(Note) The detection limit is set as less than 5Bq/L for gross β obtained in pump well No.7 and No.12.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	No.1	No.2	No.3	No.4	No.5	No.6
Gross β	ND	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	40 [11/26]	84 [12/31]	72 <5/8>	120 <3/25,5/12>	48 <3/25>	230 <4/8>

	No.7	No.8	No.9	No.10	No.11	No.12
Gross β	ND	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	690 <4/8>	100 <4/22>	110 <5/1>	330 [9/1,9/2]	480 [10/22,11/5]	1,700 <5/26,27>

* The sampling date is provided in parentheses. []: 2013, < >: 2014

