

# Sampling Result of Pump Well No.12 of the Groundwater Bypass at Fukushima Daiichi NPS

<Reference>  
 June 10, 2014  
 Tokyo Electric Power Company

Unit: Bq/L

	Pump well No.12 of the groundwater bypass	
	TEPCO	Third party organization
Date of Sampling	Jun 5, 2014	
Time of sampling	9:07 AM	
Gross $\beta$	ND(4.2)	<b>ND(2.4)</b>
H-3 (Approx. 12 years)	1,700	<b>1,600</b>

- \* Data announced this time is provided in a thick-frame. The other data was announced on June 7.
- \* Third party organization: Japan Chemical Analysis Center
- \* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

