

Sampling Result of Pump Well No.12 of the Groundwater Bypass at Fukushima Daiichi NPS

<Reference>
 August 8, 2014
 Tokyo Electric Power Company

Unit: Bq/L

	Pump well No.12 of the groundwater bypass	
	TEPCO	Third party organization
Date of Sampling	Aug 5, 2014	
Time of sampling	8:34 AM	
Gross β	ND(3.9)	ND(2.5)
H-3 (Approx. 12 years)	1,900	1,800

* Data announced this time is provided in a thick-frame. The other data was announced on August 6.

* Third party organization: Japan Chemical Analysis Center

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

