

# Sampling Result of Pump Well No.12 of the Groundwater Bypass at Fukushima Daiichi NPS

<Reference>  
 August 21, 2014  
 Tokyo Electric Power Company

Unit: Bq/L

	Pump well No.12 of the groundwater bypass	
	TEPCO	Third party organization
Date of Sampling	Aug 14, 2014	
Time of sampling	9:34 AM	
Gross $\beta$	ND(3.9)	<b>ND(2.7)</b>
H-3 (Approx. 12 years)	620	<b>740</b>

- \* Data announced this time is provided in a thick-frame. The other data was announced on August 16.
- \* Third party organization: Japan Chemical Analysis Center
- \* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

