

# Sampling Result of Pump Well No.12 of the Groundwater Bypass at Fukushima Daiichi NPS

<Reference>  
 August 26, 2014  
 Tokyo Electric Power Company

Unit: Bq/L

	Pump well No.12 of the groundwater bypass	
	TEPCO	Third party organization
Date of Sampling	Aug 21, 2014	
Time of sampling	10:39 AM	
Gross β	ND(4.7)	<b>ND(2.8)</b>
H-3 (Approx. 12 years)	750	<b>750</b>

\* Data announced this time is provided in a thick-frame. The other data was announced on August 23.

\* Third party organization: Japan Chemical Analysis Center

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

