

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Desalination RO membrane system>

	Radioactive density [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (9.1E-01)	ND (5.6E-01)	Treated water tank	June 3, 2014	4:00 PM
Cs-137	ND (5.8E-01)	ND (8.2E-01)			
Gross β	ND (4.4E+00)	ND (2.6E+00)			
Tritium	1.2E+02	ND (1.2E+02)	Receiving tank	Jun 2, 2014	10:20 AM
Notification density rate	0.17	0.11			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.