

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Desalination RO membrane system>

	Radioactive density [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (6.6E-01)	ND (6.2E-01)	Treated water tank	June 10, 2014	4:00 PM
Cs-137	ND (7.5E-01)	1.1E+00			
Gross β	ND (9.4E-01)	ND (1.3E+00)			
Tritium	ND (1.0E+02)	ND (1.1E+02)	Receiving tank	Jun 9, 2014	9:40 AM
Notification density rate	0.05	0.07			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.